


# **SULTANATE OF OMAN**

## **MINISTRY OF ELECTRICITY AND WATER**



### **STANDARD – OES 27 VOLUME – 1**

#### **132/ 33KV SUBSTATION 2 X 125 MVA, 132/33KV SUBSTATION WITH GIS 132 KV SWITCHGEAR**

**FIRST EDITION - JULY 1991**

## **CONTENTS**

<b>CLAU SE</b>	<b>DESCRIPTION</b>	<b>PAGE</b>
1.1	SCOPE	1
1.2	Major Equipment	
1.3	Building and Foundations	2
2.0	132KV OUTDOOR EQUIPMENT	
2.1	General	
2.2	Line Connections	2
2.2A	Structural Steel Work	2
2.3	Insulators	3
2.4	Surge Arrestors	4
2.5	Earthing	
3.0	132KV, METALCLAD SF6 INSULATED SWITCHGEAR	5
3.1	General	
3.2	Circuit Breaker	
3.3	Disconnecting Switches	6
3.4	Circuit Earthing Switches	
3.5	Circuit Breaker Earthing Switches	
3.6	Busbar Earthing Switches	7
3.7	Current Transformers	
3.8	Voltage Transformers	
3.9	Control Units	
3.10	Power Cable Terminations	8
3.11	SF6 Gas Density and Pressure	
3.12	SF6 Gas Purity	
3.13	Gas Monitoring Devices	9
3.14	Gas Filling and Evacuating Plant	
4.0	33KV SWITCHGEAR	
4.1	General Requirements	
4.2	Rating	10
4.3	Isolation and Interlocks	
4.4	Circuit Breaker Carriage and Isolating Equipment	
4.5	Integral Earthing	
4.6	Earthing	
4.7	Heaters	11
4.8	Auxiliary Switches	
4.9	Healthy Trip Indication	
4.10	Local/Remote Selector Switch	
4.11	Test Terminal Blocks	
4.12	Circuit Breakers	
4.12.1	Special Requirements – SF6 Breakers	12
4.12.2	Special Requirements – Vacuum Breakers	
4.12.3	Isolating Features	
4.12.4	Interlocks	

4.12.5	Circuit Breaker Operating Mechanism	13
4.13	BUS WIRES	
4.14	Labels and Secondary Fuses	14
4.15	Instruments	
4.16	Small Writing	
4.17	Voltage Transformers	
4.18	Current Transformers	
4.19	33KV Cable End Terminations	15
4.20	Additional Equipment	
5.0	TRANSFORMERS AND ASSOCIATED EQUIPMENT	
5.1	General Requirements	
5.2	125MVA, 132/33KV Transformers	
5.3	Marshalling Kiosk	26
5.4	Instruments	27
5.5	Rating and Diagram Plates	
5.6	Capitalization of Losses	28
5.7	Earthing and Auxiliary Transformers	
6.0	33KV NEUTRAL EARTHING EQUIPMENT	30
6.1	General	
6.2	Neutral, Earthing Resistor	
7.0	PROTECTION, CONTROL AND METERING	
7.1	General	32
7.2	Protection	37
7.3	Automatic Reclose Equipment	38
7.4	Metering	39
7.5	Control Boards	42
7.6	Supervisory Control and Telemetering Marshalling Cabinets	
7.6.1	General	43
7.6.2	Transmission of Alarms and Indications	45
7.6.3	Reception of Remote Controls	
7.6.4	Tele-Protection Signals	
8.0	BATTERIES, CHARGERS, DC SWITCHBOARDS	46
8.1	General	
8.2	DC System Arrangement	
8.3	Type of Batteries	47
8.4	Battery Duty	
8.5	Battery Mounting Connections and Accessories	48
8.6	Battery Fuses	
8.7	Control and Charging Equipment	49
8.8	D.C. Switchboards	
9.0	EARTHING	50
9.1	General	51
9.2	Earthing Points	
9.3	Earthing Conductors	

9.4	Earth Bars	
9.5	Earthing Conductor Connections	52
9.6	Anti Corrosion Protection	53
9.7	Fixing Details	

10.0	FIRE FIGHTING EQUIPMENT	
10.1	Scope	
10.2	Portable Fire Extinguishers	
10.3	Transformer Fire Protection	54
10.3.1	Water Spray Projector System	
10.3.2	Alarm and Indication	55
10.3.3	Drawings and Information Required for Approval	

11.0	LIGHTING AND SMALL POWER SYSTEM	56
11.1	General	
11.2	Electricity Supply	
11.3	Description of Installation	
11.4	Drawings	
11.5	Type of Switch	57
11.6	Types of Light Fitting	
11.7	Type of Socket Outlet	58
11.8	Lighting and Socket Requirements	59
11.9	Conduit and Fittings	60
11.10	Interior and Exterior Installations	
11.11	Earthing and Bonding	
11.12	Erection of Light Fittings	
11.13	Distribution Boards	61
11.14	Small Power Cables	63
11.15	Cable Trays	
11.16	Trunking	
11.17	Telephone Socket Outlet	

12.0	AIR CONDITIONING AND VENTILATION	
12.1	Air Conditioning	64
12.2	Ventilation Systems	
12.3	Internal Noise Levels	
12.4	Vibration	
12.5	Radio Interference Suppression	65

13.0	CABLES	
13.1	General	
13.2	Cable Size	
13.3	Type Approval	66
13.4	Outer Coverings	
13.5	Cable Drums	
13.6	Joining Accessories	

13.7	Cable Jointing Instructions	67
13.8	Schematics and Routing Diagram	
13.9	132 and 33KV Single Core XLPE Cables	
13.10	PVC Insulated Power and Control Cables	68
13.11	Telephone Type Cables	69
13.12	Cable Installation and Earthing	71
13.13	Erection on Steel Work	
13.14	Pulling into Ducts and Troughs	72
13.15	Laying Direct in the Ground	
13.16	Cable Pulling	
13.17	Jointing and Terminating	73
13.18	Cable Identification	
13.19	Bonding	
14.0	POWER LINE CARRIER	74
14.1	General	
14.2	Carrier Frequency Allocation	
14.3	HV Line Coupling	
14.4	Power Line Carrier High Frequency Units	76
14.5	Automatic Telephone System	81
14.6	Technical Specification for the Telecontrol Equipment	82
14.7	Technical Specification for Tele-Protection Equipment	83
14.8	Alarm Facilities for Internal Faults	85
14.9	48V Battery Charger/Battery Supplies	
15.0	PERFORMANCE PENALTIES	87
16.0	INSPECTION AND TESTING	
	PART : A – MANUFACTURE	
16.1	General Requirements	
16.2	Inspection & Testing During Manufacture	
16.3	Tests at Manufacturer's Works	88
16.4	Test Certificates	
16.5	Rejection of Plant	
16.6	Part : B – Tests at Site	89
16.7	Civil Works	
16.8	Lighting and Small Power Installation	
16.9	Schedule of Tests	
	General	
16.10	Transformers	
16.11	Cables	93
16.12	Power Line Carrier and Associated Equipment	96
16.13	Switchgear and other substation Equipment	100
16.14	Site Tests	101
16.15	Commissioning Tests	
	Schedule of Requirements "A"	103
	Schedule of Technical Guaranteed	
	Particulars "B"	118

## DRAWINGS

S. No.	Description	Drawing Number
1	132KV SUBSTATION (TYPICAL)	MEW/132/33KV/001
2	132/33KV SUBSTATION (TYPICAL) 132/33KV Single Line Diagrame	MEW/132/33KV/002
3	132/33KV SUBSTATION (TYPICAL) Single Line Diagram for Protection on 132KV Switchgear	MEW/132/33KV/003
4	132/33KV SUBSTATION (TYPICAL) Single Line Diagram for Protection on 125MVA Transformers and 33KV Feeders	MEW/132/33KV/004
5	132/33KV SUBSTATION (TYPICAL) Single Line Diagram of 125MVA Transformer Metering	MEW/132/33KV/005
6	132/33KV SUBSTATION (TYPICAL) Single Line Diagram of A.C. Auxiliaries Supplies	MEW/132/33KV/006
7	Single Line Diagram of 2x125MVA 132/33KV Transformer Feeder Substation	MEW/132/33KV/007
8	132/33KV Transformer Feeder Outdoor Yard Arrangement	MEW/132/33KV/008

**SULTANATE OF OMAN**  
**MINISTRY OF ELECTRICITY AND WATER**

**STANDARD – OES 27**

**132/33KV SUBSTATION**

**VOLUME – 1**

**132/33KV SUBSTATION**

**2 X 125MVA, 132/33KV SUBSTATION WITH GIS 132KV SWITCHGEAR**

**1.1 SCOPE**

The specification covers complete supply, erection and commissioning of all Electrical and Mechanical Plant and Equipment and Construction of Building and all Civil Works for a typical 132/33KV Substation.

The scope of work shall include the complete design, construction, manufacture, shop testing, packing and marking, shipment, insurance, delivery to site, loading and unloading, complete erection, start-up, commissioning, initial operation, trial run, acceptance testing, putting into commercial operation including construction services during the guarantee period until final acceptance of the complete plant and equipment.

**1.2 MAJOR EQUIPMENT**

**Major equipment for the substation includes:**

- a) 132 KV Overhead terminal equipment on gantry structures comprising slack span steel work, surge arrestors, sealing ends, line couplers and wave traps and capacitor coupling voltage transformer.
- b) 132KV XLPE insulated links between overhead terminal equipment and 132KV switchgear.
- c) 132KV metalclad SF6 insulated double indoor switchgear comprising 7 bays.
- d) 2 Nos. 125MVA 132/33KV transformers Vector Group Ynd5 associated earthing transformers and 33KV neutral earthing resistors. Earthing transformers to include secondary 415/240V winding for substation auxiliary supplies.
- e) 33KV metalclad indoor switchgear comprising 24 panels in two switchboards.
- f) Power line carrier equipment including tele-protection and communications equipment suitable for connection with front and computer through R.T.U.
- g) Supply and installation of separate floor mounting marshalling cabinet for interfacing with future remote supervisory control system.

The substation shall be complete with control and relay equipment, alarm facilities, auxiliary DC supplies with batteries and chargers, auxiliary LV switchboards, small power and lighting, fire fighting equipment, earthing and all necessary equipment for the safe and efficient running of the substation.

No central supervisory control scheme is included, provision shall however, be made for the supply of separate floor mounting cabinets and all wiring from the switchgear, control and relay panels to these cabinets for all connections to the remote control and supervisory equipment.

This contract shall, therefore, include all local/remote/supervisory selector switches, auxiliary contact on circuit breakers, isolators etc. for position indication, additional contacts on protection, tripping and alarm relays etc. necessary for a central supervisory control system, shall be included.

### **1.3 BUILDING AND FOUNDATIONS**

All foundations, walls, roof coverings, concrete floor fittings, ducts and pipe work embedded in the foundations, trenches with floor plates for cables etc. shall be provided.

- 1.4** All plant, equipment and materials shall conform to the Ministry's Standard OES-11 : General Specifications for Electrical Materials and Equipment.

### **2.0 132KV OUTDOOR EQUIPMENT**

#### **2.1 GENERAL**

The outdoor equipment shall be suitable for operation on a 3 phase, 50 Hz system of 132KV nominal voltage with the neutral multiple earthed. The system highest voltage will be 10 percent in excess of the nominal voltage.

The design symmetrical 3 phase short circuit rating shall be 31.5KA R.M.S. at 145KV and all current carrying equipment shall be capable of withstanding this current for a period of three seconds.

The withstand impulse levels of equipment shall not be lower than the following when tested in accordance with IEC recommendations.

132KV equipment – 650KV

Clearances between live metal work and earth shall be not less than those in the appropriate sections of IEC 54 or BS 162 or the clearances and dimensions given in this specifications and attached drawings whichever is the greater.

The 132KV terminal equipment for connections from the overhead lines to 132KV cable links shall be mounted on structures. Drawing MEW/132/33KV/001 shows the proposed arrangement.

Creepage distances shall be not less than 45mm per KV of rated system voltage.

#### **2.2 LINE CONNECTIONS**

The overhead line electrical connections to 132KV cable sealing ends shall be of copper and shall be in accordance with BS 125, 159 and 1977 in respect of current rating and material analysis.

Conductors shall be in continuous lengths between supports. Connectors shall be of approved bolted clamps type.

Conductors and connections shall be so arranged and supported that under no circumstances, including short circuit conditions, can the clearances between live metal and earth or earthed metal work or between other conductors be less than the specified distances.



Conductors shall consist of either stranded copper wire or tubes. Stranded copper having hollow cores shall be stranded around non-ferrous metal spacers of approved type. The number and diameters of the individual wires forming the finished conductor and the thickness of the tubes shall be subject to approval.

Where dissimilar metals are in contact, approved means shall be provided to prevent electro-mechanical action and corrosion. Joints and surfaces of copper or copper alloy fittings shall be tinned.

Hollow stranded copper conductors shall be supported against crushing at clamping positions by sweating solid or plugging.

## **2.2A STRUCTURAL STEEL WORK**

Steel structures shall be provided for supporting the insulators, switchgear, overhead conductors, earthwires and other equipment and fittings generally as shown on the drawings.

The design and arrangement of supporting structures shall be subject to approval by the Engineer, such structures shall be rigid and self-bracing against all dead, wind, pull-off and other applied loads. Wherever such an arrangement can be adopted, structures shall be braced by horizontal beams at intermediate or high level to provide an integrated framework such that all bending moments shall be distributed in the structures with zero overturning moments at ground level. At or near ground level, all uprights shall be provided with generously designed base plate footings for securing with holding down bolts provided.

The whole of the rolled steel sections, tubes, flats, plates, bolts, nuts and bars shall employ weldable structural steel of an approved quality to BS. 4360 grades 43A and 50C or equivalent.

Components shall be designed to have a Factor of Safety against failure not less than the main member of the structure.

The design shall be such as to keep the number of different parts as small as possible and to facilitate transport, erection and inspection.

Pockets and depressions likely to hold water shall be avoided and all parts of the structures shall be properly drained.

Steel sections forming the framework shall be heavily galvanised in accordance with OES 11.

Main members and bracings of lattice structures shall be not less than 8mm and 5mm thick respectively.

Bolts and nuts shall be galvanised and fitted with galvanised spring washers. Taper washers are to be added where necessary. Threads of bolts shall be spun galvanised and the threads of nuts shall be oiled. No bolt shall be of less diameter than 7mm.

Bolt holes shall not be more than 1.5mm larger in diameter than the corresponding bolt diameter. For bolts greater in diameter than 25mm, such as foundation bolts, the clearance shall be approved.

All members shall be cut to jig and holes shall be drilled or punched to jig. Parts shall be carefully cut and holes accurately located so that when the members are in position the holes can be accurately aligned before being bolted up. Drifting of holes will not be permitted.

## **2.3 INSULATORS**

Insulators shall satisfactorily withstand the site climatic and service conditions.

Adjustable arcing horns are require don substation insulators.

Porcelain insulators shall be in accordance with IEC 137 and 273 where applicable. Porcelain shall be sound, free from defects and thoroughly verified and the glaze shall not be depended upon for insulation.

Glaze shall be smooth, hard, of a uniform shade of brown and shall completely cover all exposed parts of the insulators. Outdoor insulator fittings shall remain unaffected by atmospheric conditions producing weathering, acids, alkalis, dust and rapid changes in temperatures that may be experienced under working conditions.

The insulators shall be station post type or long rod type with aerofoil self cleaning open profile.

Porcelain insulators shall be secured in an approved manner, preferably by means of bolts or metal clamping plates with suitable packing material inter-posed.

Retaining pins or locking devices for insulating units shall be of phosphor bronze or other approved material, and shall effectively prevent accidental separation of the units.

Creepage distance shall not be less than 45mm per KV of rated system voltage.

## **2.4 SURGE ARRESTORS**

Surge arrestors shall be of the gapless zinc oxide type. Arrestors shall be housed in porcelain containers sealed against the entry of moisture and oxygen. Internal components shall be desinged to minimise internal corona and also to ensure minimal capacitive coupling with any conducting layer of pollutant on the outside of the porcelain housing.

The surge arrestors shall be of the long duration discharge class (3) and of minimum energy absorption capacity of 2.5 KJ/KV rating.

The porcelain containers shall have open aerofoil self leaning open profile with minimum creepage of 45mm per KV of system voltage.

Arrestors shall comply in all respects with IEC 99-1 or BS 2914:1972, shall be entirely suitable for operation under all system conditions including system voltage rises on unloading long transmission lines and shall have sufficient capacity to discharge the system charging current without damage.

The standard nominal discharge current shall be 10,000 Amps. Rated voltage is to be 120KV for 132KV heavy duty.

Each arrestor shall be fitted with a surge counter of an approved type. Arresters shall be of the station type.

## **2.5 EARTHING**

A main hard drawn high conductivity earth bar, but not less than 300 sq.mm shall be provided to which the frames of all electrical apparatus and structural steel work shall be connected by branches of the same cross sectional area to this main bar or to subsidiary bars running to a group of equipment.

All overhead line earthwire terminations at substation, post insulator bases, sealing end bases, neutral current transformers, power transformers, surge arrester bases, HF coupling equipment shall be connected to the earthing system which shall also be extended to indoor switchgear, control, relay and ancillary equipment as mentioned in Section 9.

The ohmic resistance of the earthing system to the general mass of earth shall be less than 1 Ohm. The earthing must be capable of carrying short time withstand current of the switchgear for the time specified.

### **3.0 132KV METALCLAD SF6 INSULATED SWITCHGEAR**

#### **3.1 GENERAL**

The 132KV switchgear shall be indoor, metalclad and sulphur hexafluoride (SF6) insulated type. The switchgear shall preferably be of single phase enclosure and shall be constructed for duplicate busbar system and shall include the necessary busbar and circuit isolating switches, the circuit earthing switches as well as the current and voltage transformers as shown-in single line diagrams and as detailed in the Schedule of Equipment.

In addition to the local control cubicles associated with the 132KV switchgear, a separate control board made up of a suite of the panels, shall be located in the control room of the station. The mimic diagram, control switches for circuit breakers and isolators, as well as the instrumentation and alarms mounted on the board, shall enable switching operations from the control room. However, all facilities shall be provided to enable telecontrolling from a load dispatch centre at a later date.

The design symmetrical 3 phase short circuit rating shall be 31.5KA R.M.S. at 145 KV and all current carrying parts shall be capable of withstanding this current for a period of 3 seconds.

The withstand impulse levels of switchgear shall not be lower than the following when tested in accordance with IEC recommendations.

Phase to Earth : 650 KV

Busbars and connections shall be constructed of tubes of appropriate material and thickness to withstand the mechanical and thermal stresses due to short circuits.

Suitable arrangements shall be provided for the thermal expansion and contraction of the busbars. Busbars and all electrical connections shall be of such a construction that partial discharge shall be avoided and suitable measures shall be taken to minimise corona discharge and radio interference especially at sharp edges and corner. All insulated parts (cast resin parts) shall be subjected to partial discharge test and the results of the respective fabrication tests shall be recorded. The switchgear units and busbar systems shall be divided into several gas filled compartments, sealed from each other by gas-tight bushings and each gas filled chamber shall have its individual SF6 pressure monitoring so that any leakage may be quickly localised. Each individual gas filled compartments shall be further equipped with static filters to absorb any water vapour over a long period in service.

The gas-tight bushings between gas filled chambers should furthermore confine any internal faults to the respective section of the switchgear. Each gas compartment shall be capable of withstanding a fault arc of 1.0 second duration.

Facilities should be provided in each compartment of the switchgear to allow for a pressure relief and a high degree of protection under fault conditions. It shall be ensured that nobody standing in the control aisles is exposed to any

danger. Particular attention shall be paid to the sealing of all gas fitted chamber joints so that the SF6 gas leakage is extremely low. Particular preference will be given to switchgear with a low gas loss. The expected gas loss per annum and guaranteed maximum values for individual compartment shall be provided. The costs for replenishing lost gas will be considered when evaluating.

The switchgear shall be equipped with a gas supervisory unit on each switchgear bay for monitoring and checking SF6 pressure in each compartment and for replenishing/evaluating SF6 from a common service connection in this unit. The annual gas loss shall not exceed 1% per annum (gas supervisory units) to be added.

### **3.2 CIRCUIT BREAKER**

The three phase circuit breakers shall incorporate SF6 gas as insulating as well as arc quenching medium. Restrike free switching must be guaranteed for capacitive currents as per IEC 56. A lock-out shall be incorporated in each circuit breaker to prevent operation whenever the gas pressure is less than the set value for satisfactory operation of the circuit breaker at the specified rating.

An auxiliary switch for remote switch position indication shall be connected to the switch contact by means of mechanical linkages. A drive system which performs three phase switching operations will be adequate. The driving energy for the motor shall be provided by the 110V DC supply. This energy for switching must be stored in a nitrogen cylinder of the hydraulic system or by other suitable means in each circuit breaker. The capacitor of the energy storage system shall be large enough to permit operations as specified in the Technical Schedule without recharging.

The circuit breakers shall comply with the requirements of IEC 56/BS 5311 and shall have the ratings specified in the Technical Schedule for that ambient conditions specified. The circuit breakers shall be covered by test certificates issued by a recognised testing station. The breakers shall have been tested in accordance with BSS 5311 – Part 4/IEC 56-4 and for a duty at least as onerous as the specified in the Technical Schedule. The transient recovery voltages recorded during the tests must not be less severe than those specified in BSS 5311 – Part 4/IEC 56-4.

### **3.3 DISCONNECTING SWITCHES**

Cable and busbar motor operated disconnecting switches to IEC 129 shall be provided as indicated on the single line diagrams. They should be capable of switching practically under conditions of zero current. Provision shall be made for locking the switches in either open or closed position. Fluttering of the contacts shall never occur. The driving energy shall be provided by 110V DC supply. In the event of a supply failure, emergency hand operating facilities must be available. The mechanical position indicators shall be provided.

### **3.4 CIRCUIT EARTHING SWITCHES**

The circuit earthing switches shall be designed similar to those described in 3.3 and rated to the short circuit level. In addition, however, they shall be designed and constructed to withstand the short current conditions when they are accidentally switched into a live circuit; i.e. they should be made proof against short circuit.

They shall be electrically operated with provisions for hand operated stored energy drive mechanism. Provisions shall be made for the operating mechanism to be securely locked in either open or closed positions.

### **3.5 CIRCUIT BREAKER EARTHING SWITCHES**

Earthing switches shall be provided on both the incoming and outgoing sides of the circuit breaker unit in order to ensure safe maintenance and/or repair work to be carried out.

### **3.6 BUSBAR EARTHING SWITCHES**

Busbar earthing switches shall be provided where indicated. They should be of the triple pole type and should be located at the bus coupler bay or at other suitable places except at the end of the busbar to avoid the provision of extra space for these earthing switches. They should again be designed similar to those as described under item 3.3

The driving energy shall be provided by the 110V DC supply. In the event of a supply failure, emergency hand operating facilities must be available.

### **3.7 CURRENT TRANSFORMERS**

The current transformers shall be of the toriodal core type complying to BS 3938/IEC 185. The ring and secondary windings (upto a maximum of 3 secondary windings) shall be embedded in cast resin and installed in the earthed part of the switchgear. The windings shall be designed for a constant 50% overload. The rated secondary current shall be 1A.

### **3.8 VOLTAGE TRANSFORMERS**

SF6 insulated voltage transformers shall be of an inductive type fully enclosed design complying with BS 3941/IEC 186. The rated secondary voltage shall be 110/ 3V and tertiary voltage 110/3.

**3.8A** All voltage and current transformers shall be provided with an identifying label giving type, ratio, class, output and serial number.

### **3.9 CONTROL UNITS**

The control units allocated to each bay shall contain all operating and interlocking controls, the protective circuit breakers for the drives and voltage transformers, indication instruments as well as a sufficient number of connection terminals. Operating controls must be provided for all switching devices and the switch positions shall be exactly represented on a mimic diagram.

The interlock system shall prevent all incorrect operations of the disconnecting and earthing switches and must fulfill the following requirements:

- Operation of the disconnecting switches only under the condition that the circuit breaker is switched off.
- Switching off a circuit breaker only under the condition that the disconnecting switches of the corresponding bay have attained their fully closed position or if they are completely switched off.
- Switching in a circuit disconnecting switch only in the event that the earthing switch is switched off and switching in the earthing switch only in the event that the associated circuit disconnecting switch is switched off.
- Operation of the bus bar disconnecting switches only under the condition that the associated bus bar earthing switches are switched off and operation of the associated earthing switches only in the event that the bus bar disconnecting switches are switched off.
- Blocking of the second bus bar disconnecting switch in the event that a bus bar disconnecting switch is not fully switched in or switched off.

- The failure of the auxiliary power supply shall not lead to the release of an interlock. Each disconnect shall be provided with indication signalling switches with 12NC and 12NO contacts for the system blocking incorrect operation. It shall be equipped with disconnecting controls, indicators and signalling equipment. Two NC and 2NO spare contact shall also be available.

Furthermore, each bay shall be provided with SF6 maintenance and supervisory equipment for the gas filled chambers, indicating instruments as specified, protective circuit breakers for the protection of the secondary windings of the voltage transformers as well as the switchgear drives and a socket with earth contacts.

Small wiring terminations shall be provided in such numbers that all auxiliary cables which will run from other sections of the station into the bay can be connected, taking into account the connection facilities for the remote control and tele measuring equipment to be added at a later date. Over and above these terminals, facilities shall be provided for the testing of current transformers so that instruments may be disconnected without opening the secondary circuit of the current transformer.

### **3.10 POWER CABLE TERMINATIONS**

Suitable means shall be provided for terminating 132KV XLPE insulated power cables.

The cable termination housing shall be segregated from the sealed gas compartment of the switchgear. An electrode with an interconnector and the cable end terminated at the switchgear shall be in a housing filled with SF6 gas and the cable entry points shall be sealed effectively.

Access for the removal of interconnector between the electrode and the cable for carrying out DC high voltage test on cable at site shall be provided.

### **3.11 SF6 GAS DENSITY AND PRESSURE**

The nominal operating pressure of the SF6 insulating gas in the metacrad equipment shall be as low as is compatible with the requirements for electrical insulation and space limitations to reduce the effects of leaks and to ensure that there is no chance of the gas liquefying at the lowest ambient temperature. The initial gas pressure or density at the time of charging the equipment shall provide a sufficient margin above the minimum allowable operating pressure for the plant to be safely operated for a reasonably long period before recharging is necessary.

### **3.12 SF6 GAS PURITY**

The SF6 switchgear shall be designed for use with SF6 gas complying with the recommendations of IEC 376 at the time of the first charging with gas. All SF6 gas supplied as part of the contract shall comply with the requirements of IEC 376 as a minimum.

### **3.13 GAS MONITORING DEVICES**

Temperature-compensated gas density or pressure monitoring devices shall be provided. The devices shall provide continuous and automatic monitoring of the state of the gas and a separate device shall be provided for each gas compartment so that each can be monitored simultaneously.

The monitoring device shall have an alarm setting and an additional trip setting appliance. These shall be set so that:

- a) advanced warning can be given that the gas density/pressure is reducing to an unacceptable level;

b) after an urgent alarm, measures can be taken to immediately isolate the particular compartment electrically by tripping circuit breakers and opening isolators.

### **3.1.4 GAS FILLING AND EVACUATING PLANT**

All apparatus necessary for filling and evacuating the SF<sub>6</sub> gas into and from the switchgear equipment shall be supplied to enable any maintenance work to be carried out.

Where any item of the filling and evacuating apparatus is of such a weight that it cannot easily be carried by maintenance personnel, it shall be provided with facilities for lifting and moving with the overhead cranes.

The apparatus for filling or evacuating all gases to be used shall be provided with all necessary pipes, couplings, flexible tubes and valves for coupling to the switchgear equipment.

The gas compartment shall preferably be fitted with permanent valves through which the gas is pumped into or evacuated from the compartments.

Details of the filling and evacuating apparatus that will be supplied, as well as a description of the filling and evacuating procedures, shall be provided at the time of tendering.

## **4.0 33KV SWITCHGEAR**

The 33KV switchgear offered shall be of the indoor, single bus bar, totally enclosed metal clad type with vertical or horizontal draw out circuit breakers or metal clad SF<sub>6</sub> insulated with vacuum of SF<sub>6</sub> circuit breakers for installation in brick-built substation. The switchgear shall be arranged in the form of a single switchboard and equipped as shown on the attached single line diagram and detailed in the schedule of equipment.

## **4.1 GENERAL REQUIREMENTS**

The switchgear shall be of robust construction and shall be unaffected in part or whole by the forces imposed by short circuit or other fault currents, operation, vibration or temperature changes. The switchboard shall be strictly in accordance with BSS 5277/IEC 298 unless otherwise specified herein, and shall be extensible at both ends. Phase rotation and colour markings shall comply with BSS 158. All instruments, instrument transformers, all components and all materials used in switchgear shall conform to appropriate BSS/IEC. The switchgear shall be designed to facilitate inspection, cleaning, maintenance and repairs. The switchboard shall be dust and vermin proof.

The switchboard shall be of compartmental design divided into separate compartments for the circuit breaker, the bus bars and the cable circuit.

The system voltage, rated symmetrical short circuit and impulse level shall be as follows:

- Normal system voltage	33 KV
- Highest system voltage	36 KV
- Symmetrical short circuit current at rated voltage	25 KA RMS
- Impulse level	170 KV

The 33KV system neutral shall be resistance earthed. All current carrying parts shall be capable of withstanding the specified short circuit current for three seconds.

#### **4.2 RATING**

The normal continuous rating of the switchgear and bus bars in temperature conditions of Oman shall be as specified in Technical Schedules.

All current carrying parts of the switchgear, namely the circuit breakers, bus bar, current transformers, isolating contacts, connections, joints etc. shall be capable of carrying the specified rated current continuously under climatic conditions of Oman without forced cool ventilation or air conditioning plant. The temperature rise in any part shall comply with BSS 5311 and BSS 159 or other relevant BSS taking into account the site ambient temperature. BSS rating along side the Oman rating shall be specified.

#### **4.3 ISOLATION AND INTERLOCKS**

The locking arrangement in general should conform to Oman safety rules books Second Edition – January 1989 or latest.

Each switchboard shall be provided with approved means of isolation of circuit breakers and circuits and be complete with automatic shutters to screen off all live parts. The switchgear must be fully interlocked to prevent mal operation. To obviate unauthorized operations, locks each with two keys of approved make shall be included for:

- i) Locking out each circuit breaker in the isolated or off position to obviate unauthorised operation shall be numbered locks each with one key or approved make included for.
- ii) Locking movable shutters screening live parts (lock to be coloured red).
- iii) Locking circuit breakers control switch.
- iv) Locking voltage transformer in the racked in position.
- v) Locking voltage transformer spout shutter.

All locks to differ and have individual keys. Each key is to bear the number of the lock and carry a tag identifying the circuit or plant to be locked.

To facilitate phasing out of any incoming circuits against the bus bars, arrangements shall be provided to enable manual opening or closing any of the related shutters independently with the circuit breaker withdrawn and for locking any of these shutters independently in the open or closed position.

#### **4.4 CIRCUIT BREAKER CARRIAGE AND ISOLATING EQUIPMENT**

Circuit breaker isolating equipment and wheeled carriage for removal of the circuit breaker shall be an integral part of the circuit breaker. Suitable external guide rails shall be supplied for fixing in the substation in front of the switchgear carriage while inserting or removing from the board.

#### **4.5 INTEGRAL EARTHING**

Integral means shall be provided in the switchboard for circuit and bus bar earthing preferably through incomer circuit breaker. The earthing shall be complete with all necessary mechanical interlocks to prevent mal operations.

#### **4.6 EARTHING**

Each switchboard shall be provided with a copper earth bar of sectional area not less than 50mm x 6mm. All metal, instrument and relay cases of the panels shall be connected to the earth bar by copper conductors not less than 2.5 Sq. mm cross section.



#### **4.7 HEATERS**

In view of the high humidity prevailing at the site, each panel shall be provided with suitably rated heater for operation from 240V AC supply as per OES-11 Clause 0.28.

#### **4.8 AUXILIARY SWITCHES**

Auxiliary switches shall be provided to interrupt the DC supply to trip coils immediately after their operation has been completed.

All necessary interphasing/auxiliary switches for control, protection, metering and indication for supervisory control which may be adopted at a future date, shall be provided on each circuit breaker panels plus two spare ways normally close and two spare ways normally open. The auxiliary switches shall be wired to a suitable terminal block on the panel.

#### **4.9 HEALTHY TRIP INDICATION**

15 Watt 110V DC lamp with series limiting resistance operated through a spring loaded push button test over switch shall be provided on each circuit breaker panel. Alternatively, continuously monitoring scheme with low consumption (less than 5 A) may be provided for consideration.

#### **4.10 LOCAL/REMOTE SELECTOR SWITCH**

A local/remote selector switch to be provided on each circuit breaker panel to facilitate control of the breaker from a remote location.

#### **4.11 TEST TERMINAL BLOCKS**

Current transformer secondary wiring shall be connected through terminal blocks with change over links to permit easy ratio change over and testing.

The terminal blocks shall be mounted in front of the panel and suitably insulated and provided with a detachable dust proof cover.

#### **4.12 CIRCUIT BREAKERS**

The circuit breakers shall be sulphur hexafluoride (SF6) or vacuum type. The breakers shall have a guaranteed rupturing capacity of not less than 1500MVA at 33000V and must conform to BSS 531/IEC 56 taking into account the climatic conditions of Oman. Type test certificate for the circuit breakers from an internationally recognized testing authority shall be submitted.

Motor (240V single phase or 3 phase 415V 50 Hz) charged spring closing mechanism, which can be recharged after the circuit breaker has closed shall be provided.

Circuit breakers shall be independently secured in position by means of bolts, irrespective of the raising and lowering gear. Except for those joints which have to be broken for maintenance purposes, all other joints shall be machines faced and packing shall be of approved material and thickness.

Circuit breakers and mechanisms shall be capable of a minimum 1000 load operations without major overhauls. Preference will be given to circuit breakers having minimum maintenance during this period.

A pressure equalizing pipe shall be provided between the pressure relief device and the oil conservator. Spring operated pressure relief device shall be provided with contacts to initiate alarm and trip circuits.

**s) Breather**

Each conservator vessel shall be fitted with oil seal type silicagel breather with replaceable elements. The breather shall be arranged at such a height that it may be readily accessible from ground level and suitable observation window to be provided in the breather.

In view of the high humidity prevailing in Oman, silicagel breather shall be at least one size larger than the size for a temperate climate.

**t) Earthing Terminals**

Two earthing terminals, each capable of carrying the full lower voltage fault current for a period of not less than 30 seconds, shall be provided. They shall be located one on either side, and near to the bottom of the transformer to facilitate connection to the local earthing system.

**u) Cooling Plant**

The cooling plant shall be designed to have two banks of radiators each of 50% rated capacity and shall have independent facility for isolation from service. Radiators and coolers shall be designed so that all painted surfaces can be thoroughly cleaned and easily painted in situ with brush or spray gun.

The design shall also avoid pockets in which water can collect and shall be capable of with standing the pressure tests specified for the transformer main tank. Where separate coolers are provided, the conservator tank specified in Clause 5.2 (n) shall be counted thereon.

Preference will be given to offers of an arrangements whereby cooling radiators are mounted on separate foundations and connected to the main tank by pipe work.

A valve shall be provided on the tank at each point of connection to the tank.

All coolers shall be suitable for mounting on a flat concrete base.

Valves in the oil flow and return connections to the coolers shall be mounted on the transformer tank.

Each cooler bank shall be provided with:

- A) A valve at each point of connection to the transformer tank.
- B) A valve in the main oil connection at the bottom of each cooler in addition to those mounted on the transformer tank.
- C) Loose blanking plates to permit the blanking off of the main oil connection to the top.
- D) A 50mm filter valve of the type specified in Clause 5.2 (n) at the top of each cooler.
- E) A 50mm drain valve at lowest point of interconnecting oil pipes.
- F) A thermometer pocket, fitted with captive screw cap, in the inlet and in the outlet oil pipes.

- c) The closing of a circuit breaker except when correctly located in the service, earthed or isolated positions.
- d) A circuit breaker from being plugged into the isolating contacts if the arc chutes or circuit breaker chambers are not in position.
- e) A circuit breaker being closed in the service position when the secondary circuits between the fixed and moving portions are not completed.

#### **4.12.5 Circuit Breaker Operating Mechanisms**

Circuit breaker operating mechanism of the 240 Va c motor wound wpring type are preferred.

Motor wound spring operating mechanisms shall be such that the closing spring is automatically charged while the circuit breaker is closed.

The operating mechanism shall be designed so that the circuit breaker is free to open immediately once the trip coil is energised. A direct acting mechanical trip via an emergency button shall be provided on each breaker.

Means shall be provided for the manual operation of the circuit breaker for maintenance purposes. Manual slow closing shall be possible in the maintenance position only.

An approved mechanically operated indicator shall be provided to show whether the circuit breaker is open or closed.

In the event of failure to latch in the closed position it shall not be possible for the circuit breaker to open except at normal speed.

Means shall be provided to prevent the local and remote control apparatus from being in operation simultaneously. It shall not be possible, without the use of tools, to gain access to the tripping toggle or any part of the mechanism inoperative when used in the earth position. For test purposes it shall be possible to complete the closing, tripping an interlock circuits when the circuit breaker is isolated.

#### **4.13 BUS WIRES**

The following bus wires of appropriate cooper section in no case less than 2.5 sq.mm PVC insulated in appropriate colour code shall be provided on the switchboard.

- DC trip circuit
- DC closing spring release coil circuit
- Remote group alarm circuit
- Circuit breaker close and open red and green lamp indication circuit (110V DC)
- Circuit breaker panel heater circuit (240V AC)
- DC auto trip amber lamp indication circuit

The bus wires shall be neatly cleated and terminated on both sides of each individual panel on terminal blocks with adequately rated terminal studs complete with all necessary provisions for inter panel connection.

#### 4.14 LABELS AND SECONDARY FUSES

Each panel of the switchboard shall have a blank circuit label approximately 30cm x 8cm mounted on the front of the panel in a prominent position.

These label shall be made of suitable engraving material approximately 2mm thick, white surface with black engraving. Small blank labels of similar material shall be mounted on the rear of the panels. The circuit names shall be engraved at site later. All other labels shall be of similar and engraved in English.

All necessary fuses and links shall be supplied and they shall be fitted with clearly legible label indicating the circuit and shall be grouped according to their functions to facilitate identification. Fuse label shall indicate the current rating of the fuses and code symbols shall correspond with the diagrams. All secondary fuses shall be of the cartridge type to BSS 88.

M.C.B.'s in lieu of fuse are acceptable.

#### 4.15 INSTRUMENTS

Dial type, full deflection 270 Deg. 96 x 96mm switchboard pattern, flush mounting type moving iron voltmeters and ammeters shall be provided.

#### 4.16 SMALL WIRING

All wiring shall be 2.5 sq.mm stranded copper conductor, 600V tropical grade PVC insulated. All small wiring shall be suitably terminated and fitted with captive identification ferrules and marked with circuit number. Trip circuit shall have an additional ferrule coloured red and marked "Trip".

Each circuit identification number shall be suffixed with the panel identification letter. All terminal blocks shall be provided with detachable covers. The trip circuit cables shall be coloured black. The current transformer secondary wires shall preferably be coloured with their respective phase colours.

#### 4.17 VOLTAGE TRANSFORMERS

3 Phase voltage transformers shall be cast resin type and shall be as specified in the details of equipment and shown on the single line diagram. The voltage transformers shall comply with IEC 186/BS 3941. Secondary voltage shall be  $\frac{110}{\sqrt{3}}$

and tertiary voltage  $\frac{110}{3}$  The voltage transformer shall be having a rating of 200VA per phase class B

accuracy. Cartridge type secondary fuse or MCB's shall be provided.

#### 4.18 CURRENT TRANSFORMERS

Current transformers shall be cast resin insulated and conform to BS 3938/IEC 185. Current transformers shall be so rated and designed that they shall not sustain any damage due to through fault currents expected on a system fault level of 25 KA. All secondaries shall be one ampere.

The secondary windings of each set of current transformers shall be earthed at one point only via an accessible bolted disconnecting link, preferably located within the relay cubicle.

Design magnetisation curves and D.C. resistance values shall be submitted for approval before manufacture for each current transformer used for protective purposes and shall be subsequently verified by works routine tests and also by site commissioning tests.

Current transformers shall be located on the non-busbar side of the circuit breaker. The primary conductors shall be accessible for primary current injection testing on site.

#### **4.19 33KV CABLE END TERMINATION**

The cable end terminations shall be suitable for 33 KV XLPE insulated cable as specified in the details of equipment.

The cable terminations shall be of the dry type and shall be complete with gland armour clamps, connecting copper bonding straps, cable lugs and all necessary making of material.

Cable terminations shall be separated from all other compartments such as CT chambers, bus bar compartment etc. A channel iron bracket with cleats shall be provided for cable support.

#### **4.20 ADDITIONAL EQUIPMENT**

The switchboard shall be supplied with a set of three test plugs, insulated for test voltages usually applied to 33KV switchgear and cables.

The terminals of the test plugs shall be arranged for connecting flexible copper cables for current injection tests.

Facilities to be inherent in design for primary injection tests.

### **5.0 TRANSFORMERS AND ASSOCIATED EQUIPMENT**

#### **5.1 GENERAL REQUIREMENTS**

The transformer shall be robust construction and shall be unaffected in part or whole by the forces imposed by short circuit or other fault current, operation, vibration or temperature changes. The transformers shall comply with IEC 76/BSS 171 unless otherwise specified. The transformers shall be of the double wound shell or core type, three phase oil immersed, suitable for outdoor installation and operation under the climatic conditions referred to in OES 11.

The transformers shall be suitable for continuous operation on the system as detailed in OES 11.

Phase to phase and phase to earth clearances shall not be less than the clearances specified in the appropriate sections of IEC 54/BS 5227. The height from ground level to bushing insulator base shall not be less than 2500mm.

The transformers shall be guaranteed to carry continuously their continuous maximum rating applicable without exceeding the maximum temperature rise specified in Clause 5.2. The transformers shall be provided with the required accessories as specified in the details of equipment.

The transformers shall be suitable for cyclic overloading in accordance with IEC 353.

The auxiliary transformers shall be ONAN. Transformers shall be capable of operating satisfactory in parallel with each other, sharing the load within BS limits.

### **5.2 125MVA 132/33KV TRANSFORMERS**

Two 125 MVA 132/33KV power transformers complete with all associated equipment are required to be supplied and installed at the station.

#### **a) Continuous Maximum Rating**

The transformers shall be capable of carrying their maximum specified load continuously under worst temperature conditions encountered in Oman and at any tapping without the temperature rise of oil in the

hottest region exceeding 40 Deg. C as measured by winding resistance. If any transformer exceeds the above temperature rise limits on test, it may be rejected.

**b) Method of Cooling**

The cooling of the transformers shall be ONAN/ONAF and each transformer shall be capable of operating under ONAN condition upto 75% or more after which the cooling equipment shall come into operation and operate as an ONAF unit. Transformers shall be capable of remaining at full load for 20 minutes after failure of blowers without the calculated winding hot spot temperature exceeding 140 Deg. C.

**c) Voltage Ratio**

The voltage ratio shall be on normal tapping and on load 132/33KV, the higher voltage winding shall have tapping in steps of 1.11% from + 5% to -15% (total number of taps 19).

**d) Impedance Voltage and Regulation**

The impedance at normal ratio and M.C.R. (Maximum Continuous Rating) shall be 18%.

**e) Electrical Connections**

The transformers shall be connected in accordance with BSS 171 as follows:

- H.V. Winding – connected in Star
- L.V. Winding – connected in Delta
- Vector Group reference – Ynd5
- The neutral of the 132KV winding shall be brought out through external bushing.

**f) Duty Under Fault Conditions**

The transformers shall be capable of withstanding without damage or distress an external fault between phases for three seconds with the voltage on the other side of the transformers maintained as its full normal value.

Evidence shall be submitted with the tender as to the extent to which the manufacturer has proved or is able to prove either by calculation or test the ability of the specified transformers to withstand on any tapping, without damage under service conditions, the mechanical stresses arising under short circuit in accordance with IEC 76.

A brief description of those transformers or parts thereof which have been subjected to short circuit test or for which short circuit calculations are available shall be stated in the Schedule of Particulars. It is preferred that this information relates to designs comparable with the transformers relating to this specification but in the event this is not so, calculations are to be submitted to prove that the design of transformers will satisfactorily comply with this Clause.

**g) Harmonic Suppression**

Transformers shall be designed with particular attention to the suppression of harmonic voltage, especially the third, fifth and seventh harmonic and to minimise the detrimental effects resulting therefrom.

**h) Vibration and Noise**

Every care shall be taken to reduce noise and vibration to the level obtained in good modern practice and special attention should be given to this point.

The transformers shall be designed considering that noise generated during the normal operation of the transformer under 100% loaded condition is limited to and shall not exceed 85 dBA when measured at a distance of 300 mm from the transformer body all around at a height above ground level corresponding to one half of the height of the tank or at a height of 1.2 metres whichever is less.

The vibration generated due to magnetostriction of core laminations shall be limited to a minimum.

**i) Windings**

132KV star connected windings shall have graded insulation as defined in IEC 76. All transformers windings for 33KV and below shall have uniform insulation as defined in IEC 76. All neutral points shall be insulated to withstand applied voltage tests in accordance with IEC 76.

The transformers shall be designed to withstand the impulse voltage levels specified in OES 11 and shall withstand the power frequency voltage tests specified in the Schedule of Tests.

The windings shall be located in a manner which will ensure that they remain electrostatically balanced and that their magnetic centers remain coincident under all conditions of operation.

The windings also be thoroughly seasoned during manufacture by the application of axial pressure at a high temperature for such length of time as will ensure that further shrinkage in unlikely to occur in service. Provision shall however be made for taking up any further contraction by means of spring loaded and adjustable clamps or other similar devices. Drawings shall be submitted showing types of windings, methods of bracing and clamping details of electrical connection within windings and details of oil cooling ducts and precautions taken to prevent shrinkage of insulating material in service.

The windings and leads of all transformers shall be braced to withstand the shocks which may occur through rough handling and vibration during transport, switching and other transient service conditions.

The design maximum current density in the windings shall not preferably exceed 2.6 amperes per sq.mm at continuous maximum rating of the transformer with normal voltage plus normal frequency. The conductors shall be of high conductivity electrolytic copper.

The design of the magnetic circuit shall be such as to avoid static discharges, development of short circuit paths internally or to the earthed clamping structure and the production of flex components normal to the plane of the laminations. Each laminations shall be insulated with a material stable under the action of pressure and hot oil.

**j) Magnetic Circuit**

The design of magnetic circuit shall be such that to avoid static discharges, development of short circuit paths internally or to the earthed clamping structure and the production of flux components shall be insulated with a material stable under the action of pressure and hot oil.

The winding structure and major insulation shall be designed to permit unobstructed flow of cooling oil through core cooling ducts to ensure efficient core cooling.

The magnetic circuit shall be insulated from all structural parts and shall be capable of withstanding a test voltage to core bolts and to the frame of 2500 volts RMS for one minute.

**k) Flux Density**

Cores shall be constructed from cold rolled grain oriented steel sheets.

Design shall be such that there will be adverse effects due to core or stray flux heating with quality of steel employed and that when operating under most worst onerous conditions envisaged in IEC 76 and IEC 354 the flux density in any part of the magnetic circuit does not exceed 19,000 lines per square centimeter (i.e. 1.9 Tesla).

**l) Internal Earthing Arrangements**

The following provision shall be made for internal earthing:

- i) The main core clamping structure and its clamping bolts, and the coil clamping rings (if at earth potential) shall be bonded together and to the transformer tank by copper strip.
- ii) The magnetic circuit shall be electrically bonded to the main clamping structure at one point only by means of a removable link.

The link referred to in (l)-ii above, shall be located on the same side of the core as the main earth connection, and shall be accessible from the manhole in the tank cover after lowering the oil to the level of the top yoke.

Coil clamping rings at earth potential shall be connected to the adjacent core clamping structure on the same side of the transformer as the main earth.

Earthing connections are to have a cross sectional area of not less than 100 sq.mm.

**m) Main Tank**

The main tank shall be designed to house the transformer core and winding and arranged to prevent any movement of the core structure inside the tank. Provision shall be made to enable the core to be lifted out with ease for maintenance and inspection.

The tank shall construction, employ weldable structure steel grade to BS 4360 of adequate dimensions and braced and reinforced as necessary with rolled steel sections to prevent any distortion due to transportation, lifting, internal pressures and temperature variations.

The top of tank shall have provision to give access to termination of windings and earthing point etc. without completely draining the tank of oil. Suitable lifting lugs designed to carry the whole weight of the transformer, including the fittings and oil, shall be welded to each tank.

Transformer tank shall be flat bottomed, designed and reinforced so that the complete equipment may be skidded in any direction. The means to be used is to protect the tank bottom when in service. The design of the tank, the tank cover, and the under carriage, the radiator tank etc. of the transformer shall be such that:

- i) Internally there are no pockets in which oil can remain when draining the tank, or in which air can be trapped when fitting the tank.
- ii) Externally there are no pockets in which water can lodge.
- iii) It shall be possible to gain easy access to all external surfaces for painting.



Pockets shall be provided on each transformer tank for a stem type thermometer and the bulb of a temperature indicator. These pockets shall be located in the position of maximum oil temperature at continuous maximum rating (C.M.R.) at it shall be possible to remove any bulb without lowering the oil level in the tank. The stem type thermometer pockets shall be provided with captive screw-caps to exclude water and dirt. A flange with captive screw-caps to exclude water and dirt. A flange type air release plug shall be provided at the highest point in each tank covering. The tank shall be designed to withstand when empty a vacuum of 50cm of mercury or the vacuum required during drying out whichever is greater. The minimum plate thickness shall be as follows:

Side plates	16mm
Bottom plates	32mm

The whole of the tank and fittings shall be sand blasted inside and outside to remove all scale and rust before painting. The inside of the tank shall be painted with an approved oil resisting varnish.

**n) Jacking Lugs**

Each transformer shall be provided with atleast four jacking lugs located at the four corners of the transformer tank. The lugs shall be approximately 50cm above the ground level.

**o) Conservator**

Each transformer shall be provided with an overhead conservator tank formed of substantial steel plates and above the highest point of the oil circulating system. Connections into the main tank shall be at the highest point to prevent the trapping of air or gas under the main tank cover.

The capacity of each conservator tank shall be adequate for the expansion and contraction of oil in the whole system under the specified operation conditions. Conservator tanks shall also be provided with a cleaning door, filling, cap draining valve with captive cap and oil level gauge at each and which can be easily read from ground level. Temperature range to be expected under Oman conditions in the open is 0 Deg. C to 90 Deg. C.

The pipework between the conservator and the transformer shall comply with the requirements of Clause 5.2(0) and a valve shall be provided at the conservator to cut off the oil supply to the transformer.

**p) Valves**

Valves shall be of the sluice type, have non-rising spindles and shall be closed turning the hand wheel in a clock wise direction. They shall have machined flanges and provision for locking in the closed and open positions. Details of the locking devices shall be clearly shown on the general arrangement drawing.

Every valve shall be provided with an indicator to show clearly the position of the valve and each hand wheel shall be fitted with a brass name plate with engraved and filled letters or figures to provide an approved inscription which will indicate the purpose of the valve.

Each transformer shall be fitted with the following valves as a minimum requirement:

**Main Tank**

- A) One 50 mm bore filter valve located near to the top of the tank.
- B) One 50mm bore filter valve located near to the bottom of the tank and diagonally opposite to the filter valve required against (A).

- C) One 50mm drain valve with such arrangements as may be necessary inside the tank to ensure that the tank can be completely drained of oil as far as practicable.
- D) One valve in gas actuated relay connection.
- E) One valve at the conservator to cut off oil supply to transformer.
- F) Separate oil sampling valve near to the bottom of tank and another at top of the tank.

#### **Conservator Tank**

- G) One drain valve for oil conservator tank so arranged that the tank can be completely drained of all oil.

#### **Tap Changer Tank**

- H) 50mm filter and 50mm filter drain valve as required.

#### **Diverter Switch Tanks**

- I) One 50mm filter valve, one 50mm drain valve and one drain plug to be fitted to each tank. An approved oil sampling device shall also be provided and located near to the bottom of each tank.

#### **Air Blast Oil Coolers**

- J) One 50mm filter valve at the top and one 50mm filter drain valve at the bottom of each section.

Blank flange plates or captive screw caps shall be fitted to all valves and pipe ends not normally connected in service. Air release and drain plugs shall be provided as required.

#### **g) Joints and Gaskets**

All joint faces shall be machined or ground and arranged to prevent the ingress of water or leakage of oil with a minimum of gasket surface exposed to the action of oil or air.

Oil resisting synthetic rubber gaskets are not permissible except where the synthetic rubber is used as a bonding medium for cork or similar material or where metal inserts are provided to limit compression.

Gaskets are to be as thin as possible consistent with the provision of a good seal and full details of all gaskets sealing arrangements shall be shown on the Plant drawing.

#### **r) Pressure Relief Device**

Proven pressure relief device of sufficient size for the rapid release of any pressure that may be generated in the tank and designed to operate at a static pressure lower than the specified hydraulic test pressure shall be provided.

Spring operated pressure relief device shall be provided with 2 sets of normally open contacts to initiate alarm and trip circuits.

The relief device is normally to be mounted on the tank, but if mounted on the cover, it is to be provided with a skirt to project at least 25mm into the tank to prevent gas accumulation.

If a diaphragm is used, it shall be of approved design and material and located above the maximum oil level.

#### **4.12.1 Special Requirements – SF6 Breakers**

SF6 enclosures shall be capable of withstanding the maximum pressures that can occur in service without leakage or permanent distortion.

Unless otherwise agreed, gas density and/or pressure indicators shall be provided. Circuit breakers must be suitable for breaking normal loads if the gas is reduced to atmospheric pressure.

If SF6 circuit breakers are sealed for life they shall be guaranteed for a minimum of ten years normal duty. For refillable circuit breakers gas loss shall be less than one percent per annum.

#### **4.12.2 Special Requirements – Vacuum Breakers**

The composition of the contact material and the design of the contact shape shall be such that the switching characteristics do not deteriorate with use.

All vacuum units shall be stored before use before installation in the circuit breaker for a minimum of 20 days. The vacuum shall be tested before and after storage and no deterioration shall have taken place.

The Contractor shall retest the vacuum at site as part of the precommissioning procedures.

The technical submission in respect of vacuum breakers shall include details of precautions taken to prevent X-ray emission.

Details shall be provided of the maximum current chop level.

#### **4.12.3 Isolating Features**

The following circuit breaker operating locations shall be provided:

- a) Maintenance
- b) Busbar Earth
- c) Service
- d) Circuit Earth

Mechanical indication shall be provided to show the location of the circuit breaker. Such indications shall be visible from the front of the equipment at all times.

In each operating location the circuit breaker shall be positively registered in its housing before the circuit breaker can be closed or opened.

#### **4.12.4 Interlocks**

All mechanical interlocks shall be of the preventive type and shall be arranged to prevent maloperation of the equipment if the interlock is defeated.

Electrical interlocks shall also function so as to prevent the closing operation of the circuit breaker.

Clearly labelled mechanical interlocks shall be provided which are designed to prevent:-

- a) A closed circuit breaker from being withdrawn from or inserted into the isolating contacts.
- b) Tripping by attempted isolation.

G) Flanged air release plugs.

The oil piping shall be of approved material with machined flanged joints. Cast iron must not be used for oil pipes.

Copper pipe work shall comply with BS 61 or equivalent.

Dimensions of steel pipes shall be in accordance with BS 3600 : 1973 or equivalent and the drilling of all pipe flanges shall comply with BS 4504 : 1969 or equivalent.

An approved expansion piece shall be provided in each oil pipe connection between the transformer and the oil coolers.

It should be possible to drain any section of pipe work independently of the rest and drain valves shall be provided as necessary to meet this requirement.

Air blowers shall be complete with all necessary air ducting, and to reduce noise to the practical minimum, motors shall be mounted independently from the coolers or alternatively an approved form of anti-vibration mounting shall be provided.

It should be possible to remove the blower complete with motor without disturbing or dismantling the cooler structure frame work.

Blades shall be of galvanised steel unless otherwise approved and blades or runners fabricated to form hollow sections are not to be used.

Ducts and blower casings shall be made of galvanised steel of thickness not less than 2.6mm (14 SWG) and shall be suitably stiffened by angles, or tees.

Galvanised wire mesh guards shall be provided to prevent accidental contact with the blades. Guards shall also be provided over all moving parts. Guards shall be suitably stiffened by angles or tees.

Guards shall be designed such that neither blades nor other moving parts can be touched by test finger types II and / or III, 1-4 to BS 3042 : 1971 or equivalent.

Where multiple fan cooling using small single phase motors is employed the motors in each cooling tank shall be grouped so as to form a balanced three phase load.

Each motor or group of motors shall be provided with a three pole electrically operated contactor and with control gear of approved design for starting and stopping manually.

Provision shall be included under this contact for automatic starting and stopping from the contacts on with winding temperature indicating device as specified in Clause 5.4 (a). The control equipment shall be provided with a short time delay device to prevent the starting of more than one fan, or group fans in case of multiple fan cooling, at a time.

Where motors are operated in groups, the group protection shall be arranged so that it will operate satisfactorily in the event of a fault occurring in a single motor.

The control arrangements are to be designed to prevent the starting of motors totalling more than 15KW simultaneously either manually or automatically.

All contacts and other parts which may require periodic renewal, adjustment or inspection shall be readily accessible.

All wiring for the control gear accommodated in the marshalling kiosk together with all necessary cable boxes and terminations and all wiring between the marshalling kiosk and the motors shall form part of the contract works.

#### v) **Buchholz Protection**

Each transformer shall be fitted with a gas and oil actuated relay of approved make and pattern, having alarm contacts which close on collection of gas or low oil level conditions and tripping contacts which close for oil surge condition. The contacts shall be wired to a weather proof terminal block on the buchholz protection, for connection by mineral insulated copper clad PVC sheathed cable (2.5 sq. mm) to terminal blocks in the marshalling kiosk described in Clause 5.3. The circuits shall be electrically connected by PVC/PVC/SWA/PVC control cables (2.5 sq.mm copper conductor) to auxiliary "Alarm" and "Trip" relays on the remote tap change panel. The buchholz device shall be inserted in the pipe work between the main tank and conservator and provided with suitable valves on both sides of the device to facilitate easy servicing. The bucholz device shall incorporate a test cock for testing purposes. A compressed air bottle fitted with a control cock, pressure gauge, a foot operated air pump and the necessary connecting rubber hose for compressed air tests on the bucholz device shall be included.

Each gas and oil-actuated relay shall be provided with a test cock to take a flexible pipe connection for checking the operation of the relay.

To allow gas to be collected at ground level, a small bore pipe shall be connected to the gas release cock of the gas and oil-actuated relay and brought down to a point approximately 140mm above ground level, where it shall be terminated by a cock which shall have provision for locking to prevent unauthorised operation.

The design of the relay mounting arrangements, the associated pipework and the cooling plant shall be such that maloperation of the relays will not take place under normal service conditions, including starting or stopping of oil circulating pumps whether by manual or automatic control under all operating temperatures.

The pipework shall be so arranged that all gas arising from the transformer will pass into the gas and oil-actuated relay. The oil circuit through the relay must not form a delivery path in parallel with any circulating oil pipe, nor is to be teed into or connected through the pressure relief vent. Sharp bends in the pipe work shall be avoided.

When a transformer is provided with two conservators the gas and oil-actuated relays shall be arranged as follows:

- a) If the two conservators are connected to the transformer by a common oil pipe one relay shall be installed in the common pipe.
- b) If the two conservators are piped separately to the transformer two relays shall be installed, one in each pipe connection.

The clearance between oil pipework and live metal is to comply with the requirements of BS 5227.

**w) Terminal Arrangements**

The terminal arrangements for 132 and 33KV sides shall be as follows:

132 KV	Phase	Cable box
132 KV	Neutral	Outdoor bushing
33 KV	Cable Box	

132KV neutral bushing as well as the neutral of the 132 KV windings may be rated to withstand power frequency voltage of 40KV.

132KV neutral current transformers for earth fault (ratio 600/1 accuracy Class 5P10) and restricted earth fault protection (ratio 800/1 Class X) to be incorporated in the 132KV neutral bushing. Creepage of outdoor bushings shall be 40mm/KV of neutral withstand voltage.

Creepage of bushing inside cable box (dry type terminations) shall be 23mm/KV of highest system voltage.

**x) Cable Boxes**

Dry type termination eliminating the use of filling compound will be preferred. The terminations shall be accommodated in cable dividing boxes complete with cable gland, cable bonding clamps, earth bonding straps. Insulated cable glands shall be used for single core cables. Cable clamp supports shall be fitted below the box (at a suitable height above ground level), and these should be nonferrous material.

The boxes shall be arranged for bottom entry of the cables. The 33KV cables box shall be suitable to receive six single core of compacted copper conductor 630 sq.mm copper XLPE insulated aluminium armoured PVC sheathed cables.

**Y) On-load Tap Change Gear – General Requirements**

On-load tap change gear shall comply with IEC 214/BS 4571. The on-load tap change gear shall be of robust construction and shall be unaffected in part or whole by the forces imposed by short circuit or other fault currents, operation vibration and temperature changes. It shall be capable of varying the effective transformation ratio of the transformer without producing pause displacement.

The tap changing shall be effected on the high voltage winding and the oil in the chamber housing the tap change selector switch may be in communication with the oil in the main transformer tank, but the tap change circuit making and breaking switch shall be accommodated in a separate oil filled chamber separated from the main transformer tank.

**i) Duty**

The duty rating on the switches shall have a continuous current rating equivalent to the continuous maximum rating of the transformer and shall give trouble free operations under Oman conditions. Limiting devices shall be provided to limit the operation of switches to the range of tapping specified.

Tap changer shall be high speed resistor type. Tap changer shall comply with IEC 214 and shall be suitable for power flow in both directions.

Full details of the equipment offered shall be submitted with each offer. The equipment shall be designed to ensure that, when a tap change has commenced, it shall be completed independently of the operation of the control relays or switches. In the event of failure of auxiliary electrical supply during a tap change or any other contingency which would result in the tap change not being completed, approved means shall be provided to safeguard the transformers and auxiliary apparatus.

**ii) Selection**

The equipment shall be arranged for operation giving the following selection:

- A) ON-LOAD Automatic group operation from the master control (for two transformers).
- B) ON-LOAD Manual Electrical Remote group operation (for two transformers).
- C) Individual ON-LOAD Automatic operation of each transformer.
- D) Individual ON-LOAD Manual Electrical Remote Operation of each transformer.
- E) Individual Manual Hand and Electrical Operation shall be provided in a suitable weather, vermin and insect proof marshalling kiosk.

Remote tap change control panel which shall be located in the control room shall include the following:

- Tap position indicator
- Tap changer "Raise" push button
- Tap changer "Lower" push button
- Tap changer in progress – white lamp
- Tap changer out of step indication lamp – amber
- Voltage regulating relay with time delay
- Tap changer control Auto/Non-Auto selector switch
- Master/Follower/Individual Selector Switch
- Remote/Supervision tap change control selection
- ARV voltage reference adjuster
- Air forced
- Air forced cooling equipment running indication lamp – white
- Air forced cooling over current alarm - amber
- VT fail alarm – amber
- Supply voltage of OLTC failure – amber lamp
- 0-40 KV voltmeter

The automatic regulation of the 33KV voltage of the 132/33KV transformers shall be initiated by means of voltage regulating relay.

The relay shall be rated for AC 100 volts 50 cycles. A time delay element operated off 110V DC supply shall be included to give setting range between 10 and 120 seconds.

The relay sensitivity shall be adjustable to any value between 1.25 times to 2 times the transformer tap step percentage. The relay shall be in operative if the reference voltage falls below 80% of nominal value and shall be automatically restored for operation on recovery of the nominal voltage. In the event of the transformers falling out of step, while operating in parallel, a device shall be incorporated in the control circuit, to make the

automatic tap change in-operative; this device shall also set off an alarm to indicate the condition electrically at a remote point, apart from lighting the "out-of-step" indication lamp provided on the existing panel.

### **iii) Inter-Locks and Control**

The equipment shall be arranged to comply with the following:

- a) The hand gear operation of mechanism shall be inter-locked to prevent the electrical motor drive operation while the hand gear is in use.
- b) It shall not be possible for any two electrical points to be in operation simultaneously.
- c) Operation from any control switch shall cause one tap movement only unless the control switch is returned to the off position between successive operations.
- d) All electrical control switches and hand operating gear shall be clearly labelled to indicate the direction of tap change.
- e) The local control switches and other apparatus shall be mounted inside the marshalling kiosk.
- f) A mechanical tap position indicator shall be fitted on the transformer and shall be visible from ground level. A device for registering the total number of tap change operations and a hand reset register device for counting tap change operations between period of maintenance shall be fitted.
- g) A remote indicating device shall be provided for installation in the control room. The device shall indicate the tap position and shall be scaled 1-19.
- h) The tap change mechanism shall be provided with additional set of "clean contacts" wired to a suitable terminal blocks in the control panel, to transmit, "tap position" to a "remote supervisory and control center".

### **z) Low Level Alarm**

The conservator tank of all main transformers shall be fitted with a low oil level alarm device. The device may be incorporated in the oil level indicator and shall be arranged to close a pair of contacts when the oil level drops below a predetermined level. The alarm contacts shall be cabled to the marshalling kiosk.

## **5.3 MARSHALLING KIOSK**

Each transformer shall be provided with a Marshalling Kiosk located adjacent to the transformer. The Kiosk shall be of the outdoor type, of sheet steel construction, fitted with access doors, open from rear. Alternatively the Kiosk may be mounted on the transformer. The Kiosk must be dust, damp, rain and vermin proof and shall be designed for temperature conditions of Oman. The front access door shall be fitted with wire reinforced glass inspection panels and operating equipment shall be accessible only after opening of this door. Locks and handles shall be fitted to the doors.

The Kiosk shall be accommodate the following:

1. Transformer oil temperature indicator Clause 5.4 (b).
2. Transformer winding temperature indicator Clause 5.4 (a).
3. Terminal blocks and test links for (1) and (2).
4. Local "Tap change" selector and control switches.
5. Marshalling terminal blocks for connections between transformer auxiliaries and remote control panel.
6. Control switches, fuses, protective device associated with tap-change motor circuits, which normally cannot be accommodated in the "Tap Change Motor" compartment.
7. The Kiosk shall be provided with heater elements suitably controlled by a switch, temperature and/or humidity relay duty relay.



## 5.4 INSTRUMENTS

### a) Winding Temperature Indicator

A dial type indicator calibrated to show the temperature of the hottest region of the windings shall be provided. This device may be of the type comprising a current transformer, heating coil, hot oil pocket, temperature measuring device and arranged to produce the desired relationship between winding temperature and hot oil temperature.

The indicator shall be fitted with two sets of fixed and moving contacts one for "Trip" and one for "Alarm"; adjustable to close between the range of 60 Deg. C to 120 Deg. C. The contacts shall reopen when temperature has fallen not more than 10 Deg. C of the set temperature. For controlling external cooling fans, one more set of contacts shall be included. A maximum temperature pointer shall be incorporated with the indicator to show highest temperature reached and arranged for hand re-setting.

### b) Oil Temperature Indicator

A dial type instrument together with capillary tube to indicate the temperature of oil in the hottest region of the Main Tank shall be provided. The indicator shall be fitted with two separate sets of fixed and moving contacts, one for "Alarm" and one for "Trip", adjustable to close between the range 60 to 120 Deg. C. The contacts shall re-open when the temperature has fallen not more than 10 Deg. C.

A maximum temperature pointer shall be provided to show the highest temperature reached and shall be arranged for hand re-setting.

#### Note:

The winding temperature indicator and the oil temperature indicator shall be accommodated in the Marshalling Kiosk described in Clause 5.4.

## 5.5 RATING AND DIAGRAM PLATES

Each transformer shall be provided with substantial diagram, valve location and rating plates and shall give all the information relating to the transformer, and cooling medium.

The following information shall be included:

- Rating in MVA
- Temperature rise by oil Deg. C
- Temperature rise by resistance Deg. C
- Volts at no load and normal tapping:
  - H.V. Side
  - L.V. Side
- Current at rated load and normal tapping:
  - H.V. Side
  - L.V. Side
- Impedance voltage at normal ratio
- Transformer ratio for each tap
- Number of phases

- Diagram of connections
- Manufacturer's serial number
- Frequency
- Vector group reference and diagram
- Weight of core and winding
- Weight of oil
- Total weight of transformer
- Contract Number
- Employer's name and address
- Location and function of all valves and air release locks or plugs

The plates shall not be less than 2.5mm thick and the marking shall be engraved thereon. The dimensions shall be subject to approval.

## 5.6 CAPITALIZATION OF LOSSES

The transformer iron and copper losses and input to cooling plant (where applicable) will be capitalised during evaluation. The capitalization will be based on the following:

- |                   |                   |
|-------------------|-------------------|
| a) No load losses | R.O. 800/- per KW |
| b) Load losses    | R.O. 300/- per KW |
| c) Cooling plant  | R.O. 200/- per KW |

If the acceptance tests of the transformers show that the actual losses exceed the values stated in the Schedules of Technical Particulars, then the "Excess Lossess" will be capitalised according to the above assumption and the sum thus obtained deducted from the monies due to the Contractor as a penalty. For this purpose no tolerance will be allowed on the figures stated in the Schedule of Particulars and Guarantees.

In any case, the actual losses shall not exceed the figures stated in the Schedule of Technical Particulars by more than 10%.

The losses to be stated in the Schedule of Particulars and Guarantees shall be given without tolerance.

## 5.7 EARTHING AND AUXILIARY TRANSFORMERS

### a) General

Earthing transformers shall be of the oil immersed ONAN type suitable for outdoor installation and are to have a main interconnected star 33KV winding which will be directly connected to the lower voltage terminals of the associated MVA 132/33KV transformer. The earthing transformer shall comply with BS 4944.

The neutral point of the interconnected star winding shall be brought out of the tank through a bushing insulator. This point may be isolated or connected to earth directly or through an impedance in order to provide an earthing point for the neutral of the 33KV system.

The earthing transformers shall also be provided with a star connected auxiliary winding arranged to give a 415/240 volts, 3 phase, 4 wire supply. The auxiliary winding shall have the continuous site rating of 315KVA and shall conform to BS 171 and IEC 76.

The earthing transformer shall be connected to IEC group symbol ZY11.

The auxiliary transformer shall be carefully designed and proper high grade material shall be chosen such as it gives true and undistorted LV phase to phase and phase to earth voltages as specified. Factory test results must be confirmed at site by the Contractor before handing over.

**b) Electrical Short Circuit Characteristics**

Earthing transformers shall, when operating continuously at any load upto continuous maximum rating of the auxiliary winding be capable of withstanding for a period of 3 seconds the application of normal three phase line voltage to the line terminals of the interconnected star winding with one line terminal and the neutral terminal connected solidly to earth. The zero phase sequence impedance and resistance of the interconnected star winding under these conditions shall be as stated in the Schedule of Particulars and Guarantees.

Additionally, earthing and auxiliary transformers shall, when operating continuously at any load upto CMR, be capable of withstanding for 3 seconds the current obtained when a short circuit is applied between any or all of the lower voltage terminals with full line voltage maintained at the higher voltage terminals.

The foregoing conditions shall assume an initial winding temperature which is the sum of the maximum ambient temperature and the temperature rise obtained by continuous operation at CMR.

The interconnected star winding of each earthing transformer when at its maximum temperature due to continuous full load on the auxiliary winding shall be designed to carry for 30 seconds without injurious heating an earth fault current not less than the full load lower voltage current of the main transformer to which it is connected.

**c) Tanks and Fittings**

Earthing transformers shall be provided with the following fittings:

- A) Conservator vessel with removable end cover and prismatic oil gauge.
- B) Buchholz Protection.
- C) One thermometer pocket with captive screw cap.
- D) Silicagel Breather of the oil seal type at least one size larger than would normally be supplied for the use in a temperature climate.
- E Pressure relief device.
- F Filter valve and combined filter and drain device.
- G Oil sampling device.
- H Cable boxes on 33KV and 415V sides.
- I Rating, diagram, valve location plates.

**d) Auxiliary Winding**

The 3 phase 4 wire auxiliary windings shall be terminated at a 3 pole combined switch fuse unit with bolted neutral link and gland entry for a 4 core XLPE insulated wire armoured PVC sheathed cable. This shall be accommodated in a lockable, fully weather proof compartment together with a neutral earthing link. The purpose of the neutral earthing link into connect the 415 volts system neutral to earth. It shall be connected between the transformer winding end of the neutral link and a suitably located earthing terminal to which the system earth can be connected.

3 phase fuses shall be supplied with each transformer.

**e) Tappings**

The 33KV windings of the earthing transformers shall have tappings at + 2.5% or - 2.5% and + 5 or + 5% operated by an off circuit tapping switch, with clearly marked position indicator. Locking facilities shall be provided for locking only on a definite tap.

**f) Rating and Diagram Plates**

Each earthing transformer shall be fitted with plates complying with Clause 5.5. In addition to the information called for in IEC 76/BS 171, the 30 second continuous fault current rating of the primary winding full current on the secondary winding and the zero phase sequence impedance of the transformer shall be given on the rating plate.

**6.0 33KV NEUTRAL EARTHING EQUIPMENT**

**6.1 GENERAL**

The 33KV neutral earthing arrangement shall be as shown on Drawing No. PL/SLD-P-03. The 33KV system neutral earthing equipment for each 125MVA transformer shall comprise:

- 1 Earthing Resistor 12.80 Ohms 1500 Amps
- 2 Earthing Isolators
- 3 Neutral Current Transformers

**6.2 NEUTRAL EARTHING RESISTOR**

The earthing resistor shall be of metallic element type suitable for outdoor installation to provide earthing of 33KV three phase 50 cycles system neutral.

The housing for the resistor shall be of substantial steel construction heavily galvanised.

The electrode shall be adequately insulated supported and designed to withstand fault operating conditions.

In the case of liquid type, the tank shall be complete with electrolyte level indicator, drain, filling and relief valve, access manhole and first filling of electrolyte and distilled water.

**7.0 PROTECTION, CONTROL AND METERING**

**7.1 GENERAL**

Separate control and relay boards and integrating metering panel shall be provided and installed in the substation control room.

Control boards shall incorporate all necessary control and indication facilities for the operation of the plant and equipment at the substation.

Relay boards shall incorporate all the protective gear and the metering panel, the integrating and summation metering equipment.

Each cubicle shall form a complete enclosure accommodating the equipment associated with only one circuit of main equipment.

The cubicles shall be self supporting, floor standing and shall provide for bottom entry of power and control cables,

through bottom plate and compression type brass glands for single wire armoured power and multicore control cables. Floor plates shall not be used as gland plates.

The cubicles shall be provided with close fitting lockable and lift-off rear access doors hinged to open through 180°. The inside shall be finished with a matt white surface and shall include a lamp controlled by a door operated switch. the outside shall be finished semi-matt to colour Eau de Nil BS 381 C No. 216. Heaters shall be provided in each cubicle as in Clause 4.7.

Panels shall be rigidly constructed from folded sheet steel of adequate thickness to support the equipment mounted thereon, above a channel base frame to provide a toe recess. Alternatively a separate kicking plate shall be provided.

Overall height, excluding cable boxes, shall not exceed 2.5m. Operating handles and locking devices shall be located within the operating limits of 0.95m and 1.8m above floor level. All panels shall be fitted with padlock. The minimum height for indicating instruments and meters shall be 1.5m unless otherwise specified.

Panels shall be mounted on an approved form of antivibration mountings whenever necessary.

All panels and cubicles shall be vermin proof. All cable entries to equipment shall be sealed against vermin as soon as possible after installation and connecting-up of the cables to the approval of the Engineer. Ventilation shall be provided for natural air circulation. All control equipment shall be designed to operate without forced ventilation.

All metal surfaces shall be thoroughly cleaned and particular care taken during painting to ensure that both internally and externally a first class cover and finish is achieved.

All nuts, bolts and washers shall be plated.

Door sealing materials suitable for the specified site conditions shall be provided. Doors shall be fitted with handles and locks. The doors shall be capable of being opened from within the panels without the aid of a key after they have been locked from the outside. Hinges shall be of the lift-off type.

The bottom of all panels shall be sealed by means of removable gasketed steel gland plates and all necessary glands shall be supplied and fitted within the Contract.

Panels shall be suitably designed to permit future extension.

Each panel shall include rear access doors and door-operated interior lamp, and be clearly labelled with the circuit titled at front and rear, with an additional label inside the panel. Panel sections accommodating equipment at voltage higher than 110V shall be partitioned off and the voltage clearly labelled. Each relay and electronic card within panels shall be identified by labels permanently attached to the panel and adjacent to the equipment concerned. Where instruments are terminated in a plug and socket type connection both the plug and the socket shall have permanently attached identifying labels.

Instrument and control devices shall be easily accessible and capable of being removed from the panels for maintenance purposes.

For suites of panels interpanel bus wiring shall be routed through apertures in the sides of panels and not via external multicore cabling looped between the panels.

Relays shall be of approved makes (GEC, REYROLLE OR ABB) and where appropriate, shall be provided with LED\* flag indicators, phase coloured where applicable. Indicators shall be of hand reset pattern and shall be capable of being reset without opening the case. Where two or more phase elements are included in one case separate indicators shall be provided in the event of failure.

Relays movements and other sensitive equipment shall not be fitted on cubicle doors or hinged panels. No equipment shall be mounted on rear access doors.

Relays which rely for their operation on an external DC supply shall utilise for this purpose the trip supply of the associated circuit breaker. This supply shall be monitored at the relay and an alarm provided in the event of failure.

Relays, whether mounted on panels or not, shall be provided with clearly inscribed labels describing their application and rating in addition to the general purpose labels.

Approved means shall be provided on the relay panels for the testing of protective relays and associated circuits. If injection test plugs are required for this purpose the same shall be supplied.

Attention is particularly drawn to the tropical climate and relay designs should be entirely suitable for duty under these conditions.

To minimise the effect of electrolysis, relay coils operating on DC shall be so connected that the coils are not continuously energised from the positive pole of the battery. Suitable CT short circuiting facility shall be provided in the relays terminal blocks. All C.T. and V.T. circuits shall have disconnecting link type terminal.

**\* LED: Light Emitting Diodes**

## **7.2 PROTECTION**

### **a) General**

The performance and testing of protective devices shall be in accordance with British Standard 3950. Protection equipment shall be designed and applied to provide maximum discrimination between faulty and healthy circuits. All equipment shall remain in-operative during transient phenomena which may arise during switching or other disturbances to the system.

**\* LED: Light Emitting Diodes**

Relays shall be of approved makes and types, electromagnetic/electronic complying with BS 1452, IEC Publication 255, shall have approved characteristics and be flush mounted draw out type in dust proof cases.

The construction of the relays shall be sturdy and shall be such that all parts are readily accessible for easy adjustment.

Relay contacts shall be suitable for making and breaking the maximum currents which they may be required to control in normal service. Separate contacts shall be provided for alarm and tripping functions. Relay contacts shall make firmly without bounce and the whole of the relay mechanisms shall be unaffected by vibration or external magnetic fields.

**b) Distance Protection**

Distance protection for 132 and 33KV overhead line feeder circuits shall be of high speed type with 1 amp rating.

To ensure necessary safety of the protection system, the following criteria shall be strictly observed:

- Individual measuring elements for each zone and for each type of fault should be provided, without the need for switching any current or voltage circuit.
- Protection shall detect phase and earth faults.
- A switch on the fault facility shall provide an instantaneous trip if the line is energised onto a three phase fault with line VT's.
- Transient over-reach shall be reduced to less than 5%, thus allowing increased zone 1 setting, without mal-operation on external faults.
- Measuring elements of the polarised MHO type shall be provided.
- Every kind of fault shall be measured separately, without change over of measuring system.
- Undesired tripping on power swings shall be avoided.
- To detect faults with currents less than the rated current, the protection shall be equipped with impedance starters.
- For 33KV feeder circuits switched version of the distance relay covering phase and earth fault with a single common measuring element would be considered adequate and acceptable.

**c) Pilot Wire Protection for 33KV Cable Circuits**

For 33KV underground cable feeder circuit, pilot wire protection 15KV insulated shall be provided.

**d) 132KV Busbar and Breaker Back-up Protection**

The protection system shall be able to work on CT's which may have different ratios. The protection system shall preferably be of the electronic type to achieve the lowest possible response time (less than 20 ms).

To ensure the necessary safety of the protection system the following criteria shall be strictly observed:

- CT circuits shall not be switched via the auxiliary contacts of the busbar isolators.
- Two independent measuring criteria shall be used both of which shall be independent of the voltage to ensure in case of a metallic short circuit (voltage 0) safe tripping.
- Full selectivity shall be guaranteed for each busbar zone. All busbar coupling circuit breakers as well as sectionalising circuit breakers shall be incorporated within the protection system to achieve the necessary selectivity.

- The complete protection system shall be fully tested in the factory, the only remaining work on site being the connection of the auxiliary cables.
- An automatic test facility shall be provided which will automatically test the protection system approximately every week. Furthermore, the start of this test shall also be possible by manual operation.
- As the short circuit currents within the network are, under low load condition, rather small the protection system shall already work at short circuit currents in the range of the maximum possible operating current.
- Incorporated with the electronic busbar protection shall be a breaker back-up protection which shall work and be incorporated with the busbar protection as follows:-
- The isolator replica of the busbar protection shall be used to guarantee a selective protection of the busbar zones.
- Two independent measuring criteria shall be used to prevent undesired tripping.
- After a delayed time the breaker back-up protection shall give a tripping command to a separate tripping coil of the same breaker to operate the circuit breaker. If this has no effect the protection shall give a different tripping command after a second delay time to all circuit breakers of the concerned busbar zone to interrupt power supply.
- In addition to the above criteria, the following should be observed for both busbar and breaker back-up protection.
- The extension of the protection system shall easily be possible. The protection shall also be wired for the whole number of feeders required in the future. Thus, later on the respective parts can be easily fitted to the protection.

Alternatively, high impedance circulating current busbar protection will be considered for 132KV busbar and breaker back-up protection, similar to 33KV busbar protection as described , (c) below.

#### e **33KV Busbar Zone Protection**

##### **High Impedance Circulating Current Busbar Protection**

33KV switchgear shall be provided with a high impedance balanced busbar protection scheme and shall be capable of extension as the system develops.

The protection shall be capable of detecting 3 phase, phase-phase and phase-earth busbar faults and have two independent sets of protective equipment for each zone, one as a check on the fault sensing of the other. Both sets of equipment must operate to initiate tripping in the event of a busbar fault in any zone.

The check set of equipment may be common to all discriminating zones to form one overall zone.



In addition, automatic and continuous supervision of the current transformer circuits shall be provided to give warning of the out of balance current having reached an undesirable value.

The supply shall include the provision of all necessary current transformers, auxiliary switches, relays, panels and multicore cable marshalling boxes.

Each zone of protection shall be capable of being switched out of service separately whilst leaving the other zone or zones in service.

The following indication lamps shall be installed on the busbar protection panels:

- a) Busbar fault
- b) Protection defective
- c) "Protection in Service" for each zone
- d) "Protection out of Service" for each zone
- e) Trip supply faulty

Of these, the following shall initiate an audible alarm:

- a) Busbar fault
- b) Protection defective
- c) Trip supply faulty

In the event of a busbar fault, means shall be provided by flag indications on relays to indicate, the zone in which the fault has occurred.

Trip isolation links for each circuit shall be provided on the control and relay panels.

Suitable CT test and change-over links shall be provided at or in the marshalling kiosks adjacent to each circuit breaker. These links shall enable the current transformers to be shorted and/or isolated from the protection in order that testing and maintenance can be carried out. Links are to have a switch protective cover and warning label.

#### **f) Overcurrent and Earth Fault Inverse Time Protection**

Overcurrent and earth fault relays shall be of the induction disc/electronic inverse definite minimum (IDMT). Directional delays of this type shall incorporate directional element which gives maximum torque in a closing direction for an operating current of 45 Deg. lagging power factor when applied to transformers and 30 Deg. for plain feeders.

Overcurrent relay shall have a current range from 50 to 200% in steps of 25% and the time setting adjustable from 0 to 3 seconds at 10 times the normal operating current.

Inverse time earth fault elements shall comply with the foregoing but shall have a range of settings from 10 to 40% in steps of 10%.

Thermal rating of relay shall be such that operating time shall not exceed the relay thermal withstand.

**g) Transformer Overall Protection**

Transformer overall protection shall be of the biased differential type to cover 132 and 33KV windings for phase and earth faults.

The protection shall incorporate harmonic restraint against third and fifth harmonic and shall remain stable during magnetising inrush surges without introducing any intentional time delay during fault operation.

The minimum operating settings shall be not more than 30% of rated full load of the current transformers.

The protection shall remain stable under maximum through fault conditions corresponding to rated system short circuit level of any tap position.

**h) Transformer Restricted Earthy Fault Protection**

Transformer windings shall be provided with restricted earth fault protection. Relays shall preferably be of the high impedance circulating current type with necessary protection against over voltages.

Relays shall have maximum sensitivity and minimum operating times consistent with stability for faults outside the protected zone and on magnetising inrush surges.

132KV neutral current transformers shall be incorporated in the high voltage neutral bushings of transformers and 33KV neutral current transformers in the metal clad neutral earthing switchgear.

The line and neutral current transformers shall have identical turns ratio and matching magnetisation characteristics.

**i) Stand-by Fault protection**

For thermal protection of fault current limiting 33KV neutral earthing resistors in the event of an uncleared fault two stage definite time stand-by earth fault protection shall be provided on the 33KV neutral circuit with current setting range 10% to 40% of the rated current, and time setting adjustment from 2 to 30 secs.

**j) Definite Settings and Definite Time Delay Earth Fault Protection**

Transformer neutrals (132KV) which are solidly earthed shall be provided with neutral earth fault protection of a definite current/definite time delayed type.

The relays shall be supplied with adjustable settings such that protection can be provided for the maximum proportion of the windings.

A time delay relay with two stages of adjustable settings shall be provided and the characteristics and setting range of both relay shall be to approval.

**k) Buchholz Protection**

Transformers shall be fitted with Buchholz devices. The Buchholz device will be of the two element type giving operation under gassing and under surge conditions.

All necessary flag indication tripping relays and alarm relays associated with this protection shall be supplied and connected.

## **7.3 AUTOMATIC RECLOSE EQUIPMENT**

### **a) 132KV Overhead Line Feeders**

At present, auto reclose shall be provided on 132KV overhead line feeders and shall be initiated only for zone 1 phase to phase and zone 1 phase to earth faults from the 132KV distance protection for these lines.

Auto reclose shall be blocked for all three phase faults and any zone 2 or zone 3 fault and also following the operation of the 132KV feeder relays.

The range of dead times i.e. the delay between tripping due to a fault and reclosing the circuit breaker, shall cover the range 2-25 seconds and the range of reclaim times shall be suitable for the 132KV circuit breakers offered.

After the 132KV breakers at both ends have been tripped due to a zone 1 phase to phase or phase to earth line fault detected by distance protection relays at either end, the feeder will be re-energised from one end after the expiry of the reclose dead time followed by reclosing of the breaker at the other end after a predetermined time interval which shall not be completed unless the system is in synchronism i.e. the line has been energised and the check synchronising relay permits reclosure.

### **b) 132KV Overhead Line Feeder Transformer Circuits**

The 132KV feeder transformer circuits shall be controlled by 132KV breakers at the substation, trip with auto reclose on the 125MVA transformer 33KV breaker at the receiving end shall be initiated by zone 1 phase to phase and phase to earth faults from the 132KV distance protection at the substation.

Auto reclose shall be blocked for all three phase faults and any zone 2 or zone 3 fault and also following the operation of the 132 overcurrent and earth fault relays at the substation. Similarly, if the 132KV line fault is of permanent nature, auto reclose of the 132KV circuit breaker at the substation shall be blocked.

After the 132KV breaker at the substation and the 33KV transformer breakers at the receiving end have been tripped due to a zone 1 phase to phase or phase to earth line fault detected by distance relay at the substation the feeder transformer shall be energised after the expiry of the reclose dead time.

### **c) The auto reclose scheme shall provide for selection of “auto reclose on” or “auto reclose off” and operations will normally be single shot with repetitive reclose cycles.**

The auto reclose equipment shall be arranged to lock out and sound an alarm after the unsuccessful reclose attempt.

The relays shall have provision for adjusting the dead and reclaim times, the range of adjustment being suitable for the protective gear and circuit breaker types employed.

A counter to record the number of operations shall be provided.

The reclose relays shall in all cases incorporate means for locking out the circuit breaker after predetermined number of reclose cycles for circuit breaker maintenance to initiate an alarm when this situation is approaching.

## 7.4 METERING

### a) General

Statistical metering shall be installed on the 33KV side of 132/33 KV transformers. Each 33KV circuit shall be equipped with a commercial grade integrating KWH meter including maximum demand indication and KVARH meter. Non reversing ratchets shall be fitted. Summation equipment shall be provided and all equipment shall be installed on a separate panel. Requirements are shown on Drawing MEW/132/33/005.

### b) KWH Meters

Kilowatt hour integrating meters shall be of the induction disc 3 phase unbalanced load type.

Case shall be subject to approval and shall be finished in bright black enamel.

Kilowatt hour meters shall be provided with a maximum demand indication on a pointer dial arranged for half hour resetting. The half hour resetting signal shall be obtained from a time clock.

33KV metering shall be fitted with a transmitting unit to provide a pulse or switched output to operate a summation scheme and to transmit information (magnitude and direction) via a future supervisory system to a central control area. Six digits shall be provided, direct reading type without use of multiplying factor.

### c) KVARH Meters

KVARH meters shall be of the induction disc three phase unbalanced load type of the same manufacture as the KWH meters with six digits and direct reading type.

KVARH meters shall be equipped with impulsing contacts having a pulsing rate of 10 KVARH per pulse.

### d) Summation Equipment

The summated half hourly KW demand shall be recorded at 30 minute intervals on a printometer. The integrated total KWh shall be separately indicated on a total register. The 30 minutes printing interval shall be signalled from the time clock used for the maximum demand indicator.

The KVARH pulses shall be summated and the integrated total KVARH shall be indicated on a register.

Both KVARH and KWh summated values shall be used to drive a total KVA demand indicator which shall be integrated over a 30 minutes period. The total KVA demand shall be indicated on a pointer dial. The pointer shall be reset after the integration period which will be signalled as for the KW maximum demand indicator described above. A manually reset KVA maximum demand pointer shall be included.

The summated KVAH pulses shall be registered on the printometer.

### e) Time Clocks

The time clock used for measuring the half hour intervals shall be operated from the 110V DC supply.

**f) Construction**

All metering equipment shall be suitable for panel mounting in flush draw-out cases and be in accordance with the general requirements of the specification.

**g) Auxiliary Supplies**

Auxiliary equipment should be suitable for operation from the 110V DC supply.

- h)** Each 33KV feeder shall be equipped with a commercial grade integrating KWh meter including maximum demand indication.

**7.5 CONTROL BOARDS**

**a) General**

Separate control boards shall be provided for 132KV switchgear and for 33KV switchgear.

Control panels shall provide all facilities necessary for the safe and effective control of the plant and equipment being supplied under this Contract.

132 and 33KV circuit breakers shall be provided with electrical controls at the circuit breaker, suitably mounted on local control cubicles for 132KV and in front of switchgear panels for 33KV for use under maintenance or emergency conditions. A multiple lockable changeover selector switch shall be provided at the circuit breaker and labelled ‘Local’ and ‘Remote’.

When the circuit breaker is selected to the ‘Local’ position, it shall not be possible to open or close the breaker from remote positions.

132 and 33KV circuit breakers shall be capable of being controlled from the substation control room and also in the future from a central control room via a remote supervisory system. Circuit breaker control switches on remote panels should be incorporated with the discrepancy type indication switches. Changeover selector switches for remote/supervisory control shall be multiple lockable and labelled ‘Remote’ and ‘Supervisory’. Selector switches shall be installed on the appropriate circuit breaker control panel.

All terminals from the selector switch for the future supervisory system shall be wired to the control panel terminal block. Controls at each substation shall be operated at 110V DC.

**b) Indications**

A single line schematic mimic diagram showing the main power equipment and connections shall be provided on 132 and 33KV control panels. The diagram shall incorporate discrepancy type indication switches to show the position of circuit breakers, isolators and line earthing links. Discrepancy indication switches shall be provided for all circuit breakers, isolators and line earthing links except where specified.

The diagram shall be at a convenient height to allow easy operation of discrepancy switches.

Control boards and panels shall except where specified otherwise, be finished in semi matt Eau De Nil BS 381 C No: 216 colour. System voltage shall be distinguished by the following colours on the mimic diagram:

<b>System Voltage KV</b>	<b>Colour to BS 381 C</b>
132	Black
33	Green No : 221
11	Signal Red No : 537
0.415	Light Orange No : 557

Control switches and push buttons shall comply with OES 11.

Position indication signals of switches and breakers for transmission by a future supervisory control scheme shall be derived from separate normally open and closed auxiliary contacts, provided and connected upto terminal blocks in the associated control panels. A discrepancy condition shall sound a buzzer in the control room.

All discrepancy lamps shall be arranged to light and give an audible alarm when the position of the equipment, e.g. circuit breaker is at variance with that of the indicator and shall be arranged to extinguish when the indicator is set to the correct position.

#### **c) Trip Circuit Supervision**

Relays shall be provided to monitor continuously the trip circuit for each circuit breaker and provide an alarm in the event of failure of continuity of supply. Series resistances shall be provided as necessary to ensure that the trip coil will not operate in the event of short circuit of any one component of each monitoring circuit.

The relays shall be designed such that under normal healthy conditions they should be energised. If the tripping supply fails or the trip circuit becomes open circuit the relay should “drop off” after a short time delay and initiate audible and visual alarms.

The time delay on “drop off” should be suitable to prevent spurious operation due to transient trip supply voltage reductions or tripping of other circuits.

#### **d) Synchronising**

Manual/Remote synchronising facilities on the 132 and 33KV circuit breakers shall be provided.

The system provided is to be such that the synchronising circuit must be established before the circuit breaker can be closed.

Synchronising check relays to prevent circuit breaker closing out of synchronism are to be included. Synchronising check relays shall check the phase and magnitude of the voltage difference at synchronising, to prevent inadvertent manual closing outside acceptable at limits. Means shall be provided the synchronising panel to by-pass these relays when switching dead equipment or lines, together with warning lamp indication that the relays are out of circuit.

Synchronising check relays shall be suitable for the use with a future remote supervisory control scheme, without further modification.

#### **e) Indicating Lamps**

Normally, energised indicating lamps if employed shall in general be energised from the station LVAC supply via an auxiliary transformer. In addition, facilities shall be provided for manual changeover from the

AC supply to the station DC supply via an automatically resetting switch arranged to reset after a time interval of approximately five minutes.

Common switches shall be provided in approved locations so that all normally lit indicating lamps and the audible alarm can be switched off. Auxiliary contacts on the common substation switch shall be arranged to cut out the flasher relays of alarm circuits to prevent unnecessary wear on flasher relays.

Lamp fittings shall allow adequate ventilation and allow for easy removal for replacement of the lamp in the event of failure.

Lamp test facilities shall be provided so that all lamps on one panel can be tested simultaneously by operation of a common key. Where alarm facias are specified, all alarm and monitoring indications shall be incorporated in the facia.

Indicating lamps and fittings shall generally be in accordance with OES 11.

## **7 Alarm Schemes**

Alarms shall be sub divided into trip and non trip (urgent and non urgent) function and each arrange to operate a common bell or buzzer as specified.

Means shall be provided for silencing audible alarm whilst leaving the bell or buzzer free to sound if any other alarm circuit is energised.

Alarm indicating lamps shall remain alight until cancelled by the resetting of the devices initiating the alarms or the operation of a separate cancellation switch as appropriate.

Where devices initiate alarms when breakers tripped manually the circuits shall avoid unnecessary display of the alarms.

A common facia for each circuit shall be provided and mounted on the associated control panel. Common alarm facia shall be of the multi window type (preferably with individually replaceable windows) with individual alarms operated from self seal-in relays and indicated by flashing illumination of an inscribed transparent window. Operation of a common accept key shall cause the light to become a steady and silence the audible alarm due to be cutout by the auxiliary contacts specified in 'e' above. Resetting of the interposing alarm relays shall only be possible after the initiating contacts have been reset.

The supply shall include all necessary interposing relays, cables, wiring and channels in the power line carrier system necessary to enable four group alarms to be transmitted to supervisory control center.

- a) Trip alarm
- b) Non-Trip alarm
- c) Spare
- d) Spare

When testing the lamps, provision for blocking transmission of alarms to Remote Control and resetting after test shall be provided.

**g) Fuses and Links**

Fuses and links shall be in accordance with OES 11. Fuses shall be of the high rupturing capacity cartridge type. Fuse holder shall be designed to lock the cartridge firmly into position.

Fuses and links shall be positioned at the bottom of the front face of relay boards but at the rear of control boards on the outside of the cubicle and above the access door.

Carners and bases for 16 amp fuses shall be coloured green and those for 6 amp fuses shall be black. Link carriers and bases shall be white or other distinctive colour.

Miniature circuit breakers are acceptable in lieu of fuses.

**h) Earthing**

Each control relay or metering panel shall be provided with a copper earth bar of not less than 100 sq.mm cross section and arranged so that the bars of adjacent panels can be joined together to form a common bus.

The common earthing busbar of control and relay panels shall be connected to the main station earthing system via a copper earthing connection.

**i) Test and Earth Links**

Test facilities shall be provided for each current and voltage transformer secondary circuit, in order to give access for testing of protection relays and associated circuits. The facilities shall comprise test terminals of an approved type for front of panel mounting with provision for short circuiting and earthing current transformer secondary circuits by means of a switch or by movement of secondary links from their normal operating position.

Each current and voltage transformer circuit shall be earthed through a removable link at one point only. Current transformer circuit links shall be arranged so that the current transformers can be safely short circuited whilst the circuit is on load.

Links shall be clearly labelled, mounted in accessible positions and the link covers coloured white.

**j) Multi-core Cables**

Protection and control schemes should, in general, be based on the use of single 2.5 sq. mm cores, except where 0.9mm 2 telephone cores are specified.

## **7.6 SUPERVISORY CONTROL AND TELEMETERING MARSHALLING CABINETS**

### **7.6.1 General**

The supply of separate floor mounting marshalling cabinets and all wiring from the switchgear, control and relay panels to these cabinets for all connections to the remote control and supervisory equipment is included in this contract. These cabinets will form the interface between the substation and the remote supervisory control center.

Terminals for current transformer circuits are to incorporate short circuiting links on the switchgear side of the terminals. All terminals shall incorporate open circuiting links to permit isolation and testing of circuits to the telemetering and control equipment.



Where provision for transducers is specified, a block of ten spare terminals shall be provided adjacent to the current and voltage transformer wiring terminals to enable the future Supervisory Control and Telemetering Centre to marshall output leads from transducers. Five spare terminals shall be provided for transformer tap position indication transducer output.

Marshaling cabinet shall be located in PLC room.

#### **7.6.2 Transmission of Alarms and Indications**

Wiring, auxiliary contacts etc. to enable the following signals (wherever applicable) to be transmitted by the telemetering and supervisory equipment is to be cabled to the marshalling cabinet:

##### **a) For Each Feeder Circuit Breaker**

Alarm indications for:-

- i) Main protection trip
- i) Back-up protection trip (over current, earth fault, distance protection zone 2 or 3 etc., connected to one common alarm circuit)
- iii) Auto reclose initiated (where applicable)
- iv) Auto reclose lockout (where applicable)
- v) Circuit breaker inoperative
- vi) Trip circuit fail
- vii) VT fail
- viii) Protection pilot or channel fail (as applicable)
- ix) Intertrip receive (where applicable)
- x) 110V DC supply fail
- xi) Space for 5 future alarms

“ON/OFF” indications for:

- i) Circuit breaker
- ii) Busbar isolators
- iii) Line or cable isolator
- iv) Line or cable earth switch
- v) Supervisory control in service
- vi) Local/Remote control in service

For transducer connections for remote measurements:

- i) 3 Phase + Neutral current transformer connections
- ii) 3 Phase + Neutral voltage transformer connections

##### **b) For each Transformer Circuit Breaker**

Alarm indicators for:

- i) Main protection trip (including cable low oil pressure trip if applicable)
- ii) Back-up protection trip
- iii) Circuit breaker inoperative
- iv) Trip circuit fail

- v) Intertrip receive
- vi) Transformer alarm (including cable low oil pressure alarm if applicable)
- vii) 110V DC supply fail
- viii) Trip relay operated
- ix) Space for 5 future alarms

“ON/OFF” indications for:

- i) Circuit breaker
- ii) Busbar isolators
- iii) Cable or transformer isolator
- iv) Cable or transformer earthing switch
- v) Supervisory control in service
- vi) Local/Remote control in service

For transducer connections for remote measurements:

- i) 3 Phase + Neutral current transformer connections
- ii) 3 Phase + Neutral voltage transformer connections

### c) For Earth Bus Coupler or Bus Section Circuit Breaker

Alarm indications as follows:

- i) Main busbar protection trip
- ii) Reserve busbar protection trip (if applicable)
- iii) Busbar protection fail
- iv) Back-up protection trip
- v) Circuit breaker in-operative
- vi) Trip circuit fail
- vii) 110V DC supply fail
- viii) Trip relay operated
- ix) Space for 5 future alarms

“ON/OFF” indications for:

- i) Circuit breaker
- ii) Busbar isolators
- iii) Busbar earthing switches
- iv) Supervisory control in service
- v) Local/Remote control in service

For transducer connections for remote measurements:

- 1 Phase current transformer connection

**d) For Each Transformer**

Indications as follows:

- i) Control selection ("Auto/Manual")
- ii) Control selection ("Supervisory On")
- iii) Tap change in progress
- iv) Tap changer incomplete alarm
- v) Tap changer out-of-step
- vi) Tap position indication ("Potential Free" contacts on multi-position stepping switch)
- vii) Space for 5 future alarms or indications

**e) For Station Alarm Panel or Desk**

Alarm indications for:

- i) AC supply to 110V DC battery charger fail
- ii) AC supply fail
- iii) Alarm DC supply fail
- iv) Battery alarm
- v) Telecommunications fail (urgent)
- vi) Telecommunications fail (non-urgent)
- vii) Under frequency relay operated
- viii) Station attended/Unattended
- ix) Fire protection operated
- x) Space for 5 future alarms

**f) For Each 33KV Neutral Isolator**

– Indication "Open/Closed"

**7.6.3 Reception of Remote Controls**

Wiring to enable the following signals to be received from the telemetering and supervisory equipment is to be cabled to the marshalling cabinets:

- a) Control (trip/close) of all circuit breakers
- b) Control (open/close) of all power operated isolators
- c) Control (raise/lower) of all on-load tap changers
- d) Resetting of electrically reset type trip relays

Interposing relays are to be provided in the control or relay panels with contacts capable of handling the switchgear tripping and closing currents. The operating coils of these relays are to be suitable for operation from the substation 110V battery.

**7.6.4 Tele-Protection Signals**

Cables for the Tele-Protection signals between the protective relays panels and the Tel-Protection signalling equipment are to be provided and installed. At the Tele-protection signalling equipment end, the cables are to be terminated in the cable glands, cable cores identified and marked with identification ferrules. Cable glands are to be provided. Cable cores to be connected to terminals of the Tele-Protection equipment. Separate cables are to be used for each Tele-Protection channel.

At the protective relay panel, the cables for the Tele-Protection signals are to terminate on terminals which are wired directly to isolating links mounted on the front of the relay panel. The purpose of these links is to enable the Tele-Protection equipment to be readily isolated from the protective relays and the 110V DC tripping and control supplies. Disconnecting links incorporated in the terminal blocks will not be acceptable for this purpose.

A two position test switch ('Test/Normal') is to be installed on the front of the relay panel to enable the functioning of the inter-tripping channel to be tested. The switch is to be lockable and provided with a lock and duplicate keys. An indication lamp is to be provided for indicating that the test switch is in the "test" position. A push-button is to be provided to initiate a test trip signal to the Tele-Protection equipment. A second indicating lamp or an auxiliary relay shall be provided to indicate that a test trip signal has been received.

**7.6.5** The size of supervisory panel should be such as to accommodate specified number of current, var/watts and other transducers. The preferable general arrangement of supervisory panel will be such that transducers are installed in central portion in multi vertical rows with all a.c. and control wiring as vertically arranged terminals on the sides and transducer output wiring at the centre where transducers are not specified as part of supply, necessary space provision for mounting of transducers and wiring in future to be kept.

## **8.0 BATTERIES, CHARGERS, DC SWITCHBOARDS**

### **8.1 GENERAL**

Two sets of 100% duty batteries, battery charging equipment and one DC switchboard shall be provided.

All batteries, chargers and distribution equipments shall be suitable for switchgear tripping and closing duties, alarm and indications and emergency lighting requirements.

### **8.2 DC SYSTEM ARRANGEMENT**

Nominal voltage shall be 110V DC and the voltage measured at the main distribution switchboard shall not vary by more than plus 20% and minus 10% of the nominal voltage when operating in accordance with the requirements of this section.

The schematic arrangement of the main DC system shall comprise distribution board, 2 x 100% automatic float cum boost charger and two 100% duty batteries. Each battery shall be connected to the main distribution board via a double pole changeover contactor. This arrangement avoids applying over voltages to the connected load when a battery is being boost charged by switching that battery from the distribution board to the boost charger.

The batteries and chargers shall be arranged such that under normal conditions i.e. with A.C. supplies available to the chargers, both chargers operate in parallel to supply the specified D.C. load and at the same time automatically float charge the respective batteries to keep them fully charged. With one charger out of service the other shall be able to fulfill the full D.C. load requirements and at the same time the total battery float charge requirements.

It shall not be possible to switch more than one 100% capacity battery and one charger out of service at one time.

The 110V batteries, chargers and distribution switchboard shall be provided to operate the control, alarm and indication schemes at the substation.

All DC equipment for the carrier equipment shall be as specified in sections.

### 8.3 TYPE OF BATTERIES

Batteries shall be of the nickel cadmium alkaline type with cases of plastic. The battery to comply IEC 623 · 1978 and shall be designed for a life of 25 years under site conditions.

Cells shall be numbered consecutively and terminal cells marked to indicate polarity.

Cells shall be marked with the following:

- Manufacturer's name and code
- Year and month of manufacture
- Voltage and nominal capacity at the 10 hour discharge rate
- Electrolyte shall be potassium hydroxide.

### 8.4 BATTERY DUTY

Each battery shall have sufficient capacity to supply the following loads for the periods specified with the chargers out of service.

Emergency lighting	-	six hours
Control and relay panels normal DC loading	-	eight hours

At the end of the eight hours the battery shall have sufficient capacity to complete the operations listed below, at the end of which duty the system voltage shall not have dropped below 90% of the nominal voltage with the above standing loads connected.

- 1) Two closing operations on all circuit breakers in the station.
- 2) Two tripping operations on all circuit breakers in the station, with simultaneous tripping of all circuit breakers in any one busbar protection zone.
- 3) Charging of DC motor wound circuit breaker closing springs (where applicable) to enable the closing operations to be carried out.

The electrolyte capacity and general design of the batteries shall be such that the inspection and maintenance, including topping up of the electrolyte shall be at intervals of not less than twelve months.

### 8.5 BATTERY MOUNTING CONNECTIONS AND ACCESSORIES

Batteries shall be mounted in double tiers in framed timber stands of robust construction. The stands shall be treated with electrolyte resisting enamel or gloss paint and any metal fittings shall be painted so that will not be exposed to corrosion. the cells shall be arranged in the tiers so that each cell is readily accessible for test and inspection. The stands shall be mounted on porcelain insulators and be so dimensioned that the bottom of the lower tier is not less than 300mm above the floor.

Batteries shall be supplied and erected complete with all necessary connections and cabling. Connections between tiers, between end cells and between porcelain wall bushings shall be of solid copper rod of suitable cross section supported on porcelain electrolyte resisting enamel gloss paint. Disconnecting links shall be provided for each battery at the terminals.

Before jointing, joint faces shall be bright metal, free from dirt and shall be protected by a coating of petroleum jelly.

Each battery installation shall be provided with a durable instruction card and a full set of test accessories, mounted in a strong wooden box. One syringe hydrometer shall be included for each nickel cadmium alkaline battery installation.

Suitable containers shall be provided for making up electrolyte for each type of battery.

## **8.6 BATTERY FUSES**

This is to be included as Clause 8.6. (Consequently the clauses already assigned with Nos. 8.6 and 8.7 shall be renumbered 8.7 and 8.8).

Cartridge fuses shall be provided in both positive and negative leads and positioned as close to the battery as possible and shall be rated for at least three times the maximum battery discharge current at the highest operating voltage.

The two fuses shall be mounted on opposite ends of the battery stand or rack. These fuse links shall comply with BS 88 clause DC 40 and shall be bolted in position without carriers.

Fuses shall be contained in poly carbonate fume proof boxes.

Warning labels shall be fitted to warn personnel of the danger of removing or replace a fuse whilst the load is connected and that fuses should not be removed immediately following boost charge due to the possible ignition of hydrogen gas.

It shall not be possible to leave the battery disconnected without some local/remote indication that such a state exists.

## **8.7 CONTROL AND CHARGING EQUIPMENT**

Each battery charging equipment shall comply with the requirements of BS 4417 : 1969 (IEC 146 : 1973), shall be of the thyristor controlled, automatic constant voltage type with current limit facilities.

The whole of the charging equipment shall be contained in a ventilated steel cubicle. The charger cubicles shall normally be mounted immediately adjacent to the DC distribution panel to form a board and shall be of matching design, colour and appearance, both with it and the substation control and relay panels.

The automatic charger shall maintain the batteries normally floating so that no discharge occurs under normal loading and the batteries remain fully charged.

Chargers may be designed for operation from either 3 phase or single phase AC auxiliary supplies with nominal voltages of 415/240V and shall maintain the float charge automatically irrespective of variations in the voltage of the AC supply within specified limits.

The automatic float charger output voltage shall not vary by more than plus or minus 4% of the nominal float charge value, or exceed a maximum of 130V when connected to the load and operating under any combination of the following conditions:

- a) Frequency variation 49.5/50Hz
- b) Rated input AC voltage variation plus or minus 6%
- c) Output between 0 and 100% of rating

The output voltage regulator shall be adjustable and shall be so designed that special tools are required for such adjustment.

The rating of the charger on float charge shall be equal to the normal battery standing load plus the recommended finishing charge rate for the battery of the normal standing load. The charger shall be capable of charging fully discharged batteries in 12 hours.

A boost charger shall also be provided to recharge the battery after a heavy discharge. The voltage/current characteristics of the boost charger shall have a tapering characteristic in order to minimise gassing during the finishing period of a conditioning charge.

When a battery is being boost charged, it shall be disconnected from DC bus bars. It shall only be possible to boost charge one battery at a time.

At normal rated input voltage and frequency the boost charger output shall be not less than its specified rating at any battery voltage within the range 100/130V or such other range as is approved. The maximum voltage of the boost charger when delivering the recommended finishing charge shall be not less than 1.8V per cell.

The charger shall be capable of charging fully discharged batteries in 12 hours. Each charger shall be provided with the following instrumentation, indication and alarm facilities:

- Red/Green-on/off indicating lamps for the incoming AC supply
- Voltmeter – input voltage
- Voltmeter – output voltage with low voltage alarm contact
- Ammeter – output current (centre zero type)
- Alarm – charger fail
- Amber indicating lamp – Boost charge

The minimum requirement for the charger fail device shall be the detection of AC supply voltage failure. The voltage failure detecting device shall not operate on switching surges or transient loss of voltage due to faults on the power system.

Suitable blocking diodes shall be provided to prevent the battery voltage being supplied to charger equipment so that in the event of D.C. output failure from charger or reduced D.C. output voltage from a charger failure indication/alarm is not prevented.

In addition each charger shall be equipped with a switchfuse for the incoming AC supply and either an off load isolator or disconnecting links for the DC output. Two sets of disconnecting links shall be fitted to the boost charger, one for each battery. Each charger shall also be capable of sustaining without damage to itself, a continuous permanent short circuit across its output terminations.

## **8.8 D.C. SWITCHBOARDS**

The switchboard shall comply with the requirements of BS 5486 (IEC 439).

Distribution panels shall be mounted adjacent to the charger control panel and shall be of the cubicle type complying with the general requirements of this specification for cubicle type control panels.

Distribution panels shall incorporate double-pole switches and fuses for each of the outgoing DC circuits and double

pole isolators for the incoming DC supply from the charger and for battery connections. The panel shall be provided with a voltmeter and centre zero ammeter on each incoming battery circuit.

Battery earth fault detecting relay with centre tap earth the 110V system via a high resistance and battery low voltage alarm device shall be incorporated in the distribution panel. Each device shall have three alarm contacts, one for local visual annunciation, one for the station control panel alarm indication and one for audible alarm. The battery low voltage alarm device shall be adjustable over an approved range. No-volt relays will not be accepted for this device.

An over voltage detection equipment to give local and remote alarm when the D.C. voltage rises more than 5% above the normal automatic float voltage. A time delay shall be incorporated to prevent operation when a battery with high open circuit voltage is switched from the boost to float condition.

Double pole changeover contactors shall be included in each incoming battery circuit to obtain the charging conditions specified in Clause 8.2. The contractors shall be both electrically and mechanically interlocked so that it is not possible for both batteries to be connected to the boost charger at the same time. Both batteries shall be automatically reconnected to the main DC distribution board on failure of either the boost or auto charger. Connections between the batteries and the distribution cubicle shall be made in solid copper rod or PVC insulated cables as required. Cable laid in runs where it may be subject to damage shall be protected by wire armouring and be sheathed overall.

Copper rod connections shall enter the cubicle near the top through suitably insulated plates and shall be so arranged within the cubicle that they do not impede the making of connection to distribution circuits.

Cable boxes shall be provided as appropriate for all incoming and outgoing circuits of the distribution switchboard and associated battery chargers.

Each circuit shall be suitably labelled at the front of the panel and at the cable termination where the terminals shall be additionally identified.

Charging and distribution switchboards shall be provided with copper earthing strip in accordance with the requirement of Section 9 of this Specification.

## **9.0 EARTHING**

### **9.1 GENERAL**

Transformer neutrals shall be earthed as detailed below:

132KV neutrals	solidly earthed
33KV neutrals of transformer	Resistance earthed
415V neutrals	solidly earthed

Earthing electrodes and connections at each substation shall be in accordance with the recommendations in the BS Code of Practice CP 1013:1965. Earthing electrodes buried in the ground in suitable locations as close to the electrical plant as is feasible. The groups of earthing electrodes shall be interconnected with each other and connected via links.

The earthing system specified in OES 11 shall be provided and it shall incorporate the relevant requirements specified in this section.



All equipment necessary for a complete earthing system shall be provided including electrode chambers and covers, positioning of all earth electrodes, installation and connection of all earthing conductors and testing of each earth point.

A detailed layout for the earthing system shall be submitted.

## **9.2 EARTHING POINTS**

A minimum of six earthing points at the substation shall be provided. The number of rods and earthing points shall be based on the substation and earthing system layout, the resistance between any point on the earthing system and the related earthing electrodes and the overall resistance of the system to the general mass of the earth.

Each earthing electrode shall consist as required of clusters of 15mm diameter copper rods, each at least 3.5 meters long driven into undisturbed soil. The spacing between each rod electrode shall be not less than the length of the rod and shall complete with approved non-ferrous clamps for the connections of earthing conductors and with a hardened steel tip and cap for driving by means of a power hammer. Each cluster or group of electrodes shall comprise at least four electrodes.

Electrode link chambers and concrete covers shall be provided to facilitate ready inspection of the connection.

Locations for the electrode chambers and the interconnection arrangement shall be based on the result of the earth tests.

The resistance between any point of each system and the related earthing electrode shall not exceed one ohms and the overall resistance between the earthing installation and the general body of the earth shall be less than one ohm under any climatic conditions.

## **9.3 EARTHING CONDUCTORS**

Conductors for interconnection between the electrode in any group and between groups shall have a cross sectional area of 300 sq.mm and there shall be at least two such connections to each electrode group.

Conductors for connection between the electrode groups and station earthing main bars shall have a cross sectional area of 300 sq.mm.

Earthing conductors shall be of annealed high conductivity copper and shall be stranded in accordance with IEC 55. They shall be protected with an extruded PVC sheath of 1000 volts grade.

Where due to site earth resistivity conditions it is found necessary for electrode groups to be driven in locations remote from the substation earth bar system insulated earthing conductors shall be employed.

Earthing conductors shall be buried directly in the ground between the electrode chambers and buildings. Inside buildings they shall be cleated to walls and ceilings of fixed to cable racks or laid in the cable trenches as convenient.

## **9.4 EARTH BARS**

Main earth bars shall comprise annealed tinned copper strip approximately 50mm by 6mm with a cross sectional area at least 300 sqmm interconnected at suitable points buried in the ground or supplied on building structures, cable trench walls etc. by means of brass clamps spaced at not more than 1.25 metre centres.

Branch connections from the main earth bars shall comprise annealed copper strip, the size of which shall be as detailed below, connected to all equipment containing or supporting electrical apparatus, earth batteries etc.

Substation fencing shall be provided with an independent earthing system less than 4 ohms.

The size of copper earthing strip or conductor to the various items of equipment shall not be less than the following and shall be adequate for the maximum earth current likely to be encountered:

<b>EQUIPMENT</b>	<b>MINIMUM</b>
132 surge arrestors, switchgear, transformers, systems neutral points etc.	300 mm <sup>2</sup>
33KV switchgear, transformers, steel structures, overhead line earth wire, terminations etc.	200 mm <sup>2</sup>
Control and relay panels etc.	100 mm <sup>2</sup>

Structure and supports forming a 3 phase set may be earthed in groups using a separate branch connection to each item of the group with a single subsidiary connection to the main earth bar. High frequency coupling equipment shall be earthed by separate connections taken direct to earth electrodes.

Earth connections to 132KV surge arrestors, switchgear, transformer neutral points and earthing resistors shall be made in 50mm by 6mm copper section direct to groups of earth rods and interconnected to the remainder of the earth systems.

Capacitor voltage transformers and surge arrestors shall be connected to a single earth rod, driven to a depth of not less than 5M, in addition to earth grid, in order to provide a low reactance path for high frequency signals.

Isolator and earthing switch operating mechanisms and circuit breaker control boxes not integral with circuit breakers shall be connected to the earth system by a branch entirely separate from the employed for earthing the isolator, earthing switch or circuit breaker structure.

Such branches shall be connected to a ground mat which shall be provided beneath the position where an operator will stand.

The fences shall be earthed separately from the electrical plant. The fence shall be electrically continuous at all points. This shall be ensured by bonding between the fence section by minimum 100mm<sup>2</sup> copper conductor.

The gates shall be bonded to the fixed section by means of flexible copper jumpers of not less than 100mm<sup>2</sup>.

The fence shall be earthed through earth rods electrodes, with at least one rod for every 20 metres of fence run.

**9.5 EARTHING CONDUCTOR CONNECTIONS**

Connections between the main earthing conductors and the main earth bars shall be made with lugs compressed onto the 300 mm<sup>2</sup> copper strand. The lugs shall then be tinned and rivetted to the main earth bars.

Stranded earthing conductors shall be in the one continuous length and straight through jointing is prohibited.

Connections to plant and equipment shall be made using the earthing terminals specified in the contract.

Joints in earthing strip shall have the surface cleaned and tinned and shall be rivetted with copper rivets (not less than four 3mm rivets per joint) and soldered.

Non corrosive flux shall be used in all soldered joints.

Alternative approved methods employing chemical welding or high compression joints or clamps are acceptable.

## **9.6 ANTI CORROSION PROTECTION**

Earth conductors laid in exposed positions outdoors or buried in ground which is chemically corrosive shall be painted with two coats of bitumastic paint after installation and before covering. Earth conductors run inside buildings battery rooms etc. shall be painted with two coats of anti corrosive paint during erection.

## **9.7 FIXING DETAILS**

All fixing bolts, foundation bolts, screws, saddles, clips, jointing material and any other components required for fixing and mounting the earthing conductors and for connection of any equipment thereto shall be provided.

## **10.0 FIRE FIGHTING EQUIPMENT**

### **10.1 SCOPE**

The fire protection shall be provided as follows:

- |  |                       |
|--|-----------------------|
| – Portable extinguishers                             | 132KV switchgear room |
| – 1 x 50 KG dry powder trolley mounted extinguishers | 33KV switchgear room  |
| – 2 x 10 KG dry powder wall mounting extinguishers   | Control relay room    |
| – 1 x 10 KG dry powder wall mounting extinguishers   | Battery room          |
| – Water sprinklers                                   | Transformer yard      |

## **10.2 PORTABLE FIRE EXTINGUISHERS**

All apparatus shall be suitable for operation by one person and is to be easily recharged. The discharge is to be non corrosive and free of chemicals prone to give off toxic gases when heated.

The extinguishers shall be manufactured to BS 5423 : 1977.

The scope shall include for the supply and installation of all wall brackets and fittings for small units and the provision of wheeled trolleys for units which cannot be carried easily.

Operating instructions shall be clearly printed on each unit.

Four ‘‘recharge’’ units shall be provided for each type and size of equipment.

## **10.3 TRANSFORMER FIRE PROTECTION**

### **10.3.1 Water Spray Projector System**

The system shall be designed to provide complete protection for the transformer employing quick water spray projectors, designed to produce extinguishment by forming a complete spray envelope over protected equipment causing emulsification of the oil and water discharged. The system shall have a designed discharge rate of not less than 15 litres per sq.m. of protected surface area per minute and shall provide the complete spray coverage for a minimum period of 20 minutes.

The system shall as a minimum standard comply to the latest edition of NFPA rules (No. 15.1 to 15.51) where appropriate.

All proprietary items of equipment shall be FOC approved of UL listed.

The system shall be of the dry type (i.e. all parts of the systems downstream from the deluge valves shall be empty when in use). The water shall be supplied by fire protection pumps to the respective deluge valves which shall be normally held in the closed position by compressed air or hydraulic pressure in the detection system. Release of the pressure in the detection system shall cause immediate opening of the valve, starting the pump and flooding of the system.

The detection pressure shall be released by separate detectors suitably positioned within the zone protected.

The detector shall consist of a valve located in the air or hydraulic escape pipeline and locked in the closed position by a quartzoid bulb or fusible link designed to fail at a predetermined temperature, thus allowing the valve to open with consequent release of the pressure and operation of the deluge valve.

The detection system shall be provided with automatic arrangements such that small pressure losses in the detection piping will be automatically compensated for without manual operation of valves. Reliable air tight non-return valve and orifice plates shall be provided on the upstream side of such switches in order that the arrangements do not retard the operation of the system. Detector reservoir arrangements shall be designed to keep "cut in/out" of the jacking compressor to a minimum.

The pumping arrangement for the system comprise two main pumps, one of which shall be coupled to an electric motor and the other to a diesel engine.

Each of the pumps shall have characteristics such that they will operate satisfactorily in parallel. Either pump shall be capable of providing the flow and pressure required at every nozzle in any zone when the whole of that zone is in operation. The diesel engine shall be independent of mains electric supply for its automatic starting arrangements. The electric motor shall be suitable for use with a 415 V, 3 phase 50Hz supply.

Water in the supply main (upto the deluge valves) shall be kept under pressure by a small capacity jacking pump which shall only be capable of dealing with leakage from the system. When the deluge valve operates, the jacking pump will be unable to maintain the pressure and the consequent drop in pressure shall activate two separate pressure switches which will start the main fire pumps simultaneously.

It is intended that the substations will normally be unattended. The protection system must therefore be designed in such a manner that it may be left without attention for long periods, yet remain reliable in all respects and without possibility of false actuation due to pressure losses. Cue allowance shall be made during design for possible vibration of equipment protected. In addition to automatic topping up arrangements described above, the system shall be

provided with full indication facilities. Automatic cutout arrangements shall be provided for main fire pumps, such that they shall be stopped when water supply becomes exhausted.

A twin fire services department inlet to BS 336 shall be incorporated into the system and shall be enclosed within a glass fronted box to the satisfaction of the relevant fire authority. Flow requirements of the system may make it desirable that two twin inlets be provided.

In addition to electrical alarms, local hydraulic alarm bells suitably indicated, shall be provided for each zone.

The system shall be suitably undercoated and painted after completion of the erection; water system in red, air systems in white and indication wiring conduits in black.

### **10.3.2 Alarm and Indication**

The system shall as stated above, be provided with full indication facilities. Indicator panels and wiring between systems and panels, which shall be run in conduits shall be included in the supply. Alarm and indication panels shall be installed in the substation control room.

Water spray projector system (each zone).

The following indications shall be incorporated into the indicator panel which shall be both audible and visual:

**a) Fire**

To be operated by a pressure switch inserted into the detection pipework to react to loss of air pressure/hydraulic pressure.

**b) Deluge Valve Open**

To be operated by a pressure switch inserted into the projector pipework immediately downstream of the deluge valve, set to react to a positive pressure.

**c) Low Detection Pressure**

To be operated by a pressure switch inserted into the detection pipework. This switch also initiate automatic cut in/out of the compressor.

**d) Deluge Valve Incorrectly Set**

To be operated by limit switches with contacts arranged to close down when isolating valves are not fully open, or drain or test valves are not fully closed.

**e) Reservoir Water Level Low**

To be operated by level switches, with contacts arranged to initiate alarm when the water level reaches below the normal level.

### **10.3.3 Drawings and Information Required for Approval**

- a) Approximate layout of the transformer showing position and target point for each detector and spray projector nozzle.
- b) Diagram of pipework and pumps for the complete water spray system.

- c) Illustrated literature giving details of all proprietary items of equipment including detectors etc.
- d) Electrical schematic diagram.

## **11.0 LIGHTING AND SMALL POWER SYSTEM**

### **11.1 GENERAL**

The completed installation shall comply with OES 4. All materials shall comply with this Standard and shall be suitable for the climatic conditions at site.

All lamp fittings, plugs, sockets, circuit breakers and general accessories of the same size and types shall be similar and interchangeable throughout the installation.

All supports, connections, accessories and other items necessary for the satisfactory completion of the installation shall be provided.

### **11.2 ELECTRICITY SUPPLY**

The 415/240V auxiliary supplies shall be obtained from the LV side of the 33/0.415 KV earthing transformers. The LV supplies shall be 415/240V 3 phase 4 wire 50Hz systems with the neutrals solidly earthed.

### **11.3 DESCRIPTION OF INSTALLATION**

AC supplies for lighting small power, air conditioning units etc. shall be supplied from a main distribution board located in the control room.

The main distribution board shall be of the single busbar air insulated metal clad type incorporating air break manually operated switch fuse units for incoming circuits from each of the 33/0.415 KV transformers. The main distribution board shall incorporate a bus section isolator and this shall be interlocked with the incoming switch fuse units to ensure that it is not possible to parallel the two incoming 415V supplies.

A separate sub distribution board shall be provided for essential services e.g. battery charger, emergency lighting, power line carrier, auxiliaries etc. The essential services sub distribution board shall include an automatic changeover contactor for selection of the incoming supply from the main distribution board.

A no volt relay shall be fitted to include a "LV/AC supply fail" alarm when the supply to the sub distribution board is interrupted for more than 30 seconds.

Under AC failure conditions, the DC emergency lighting shall be automatically switched on.

A voltmeter shall be included on each bus section of the main distribution board and on the essential services sub board. Ammeters shall be provided in each incoming circuit to the main distribution board and to the essential services sub board. Drawing No. New/132/33KV/006 shows the general layout of the AC supplies.

### **11.4 DRAWINGS**

Detailed working drawings for the lighting and power installations shall use a code to identify each light fitting and socket outlet.

The code shall comprise letters and figures to identify the following information:

- a) The distribution board to which the fitting or socket outlet is connected.
- b) Into which section (AC or DC) of the distribution board, the light fitting is connected.

- c) The circuit number and phase of a particular section into which the fitting is connected.
- d) The sequence of the fitting in the particular circuit.

## **11.5 TYPE OF SWITCH**

Switch shall be rated for 5 Amps and shall be provided with an earth terminal.

### **Type L1**

Switches for use in areas designated for surface installation shall be quick-make-quick-break fixed grid industrial types mounted in galvanised malleable iron boxes with protected dolly and arranged where necessary for multigang switching.

### **Type L2**

Switches for use in areas designated for flush installation shall be micro-break types fixed to white plastic cover and mounted in PVC flush type box.

### **Type L3**

Switches for external use shall be of the surface mounting 5 Amp quick-make-break pattern, industrial type housed in a cast iron galvanised weatherproof box, operated by means of a brass crutch handle.

## **Type L12 and L22**

Identify two way versions of Type L1 and L2 respectively.

## **11.6 TYPES OF LIGHT FITTING**

Each light fitting shall be manufacturer's nearest standard type to the type specified.

Light fittings for interior and exterior use to be manufactured and tested in accordance with the appropriate code or standard and together with all components shall be suitable for service and operation in the tropical climate stated. Each fitting shall be complete with all lamp holders, control gear, internal wiring, fused terminal blocks, earth terminal and reflectors or diffusers as specified hereinafter. The design of each fitting shall be such that the ingress of dust, vermin and insects is prevented and where open type fittings are used it should not be possible for insects to become lodged therein. The control gear for fluorescent and discharge lamps shall incorporate power factor correction and interference suppression capacitors and be suitable for use on a 240 volt 50 Hz system. Chokes shall be manufactured to restrict the third harmonic component to a minimum.

Internal connections shall comprise stranded conductors not less than 0.75 sq.mm covered with a heat resistant insulation such as silicone rubber or asbestos compound. All internal wiring shall be adequately cleated to the fitting chassis with an approved form of cleat. The finish of fittings for interior use shall have a vitreous enamel, natural aluminium or galvanised finish according to the manufacturer's standard product. The various types of lighting fittings which shall be supplied and installed are listed below:

### **a) Mercury Vapour Lamp**

Mercury vapour lamp shall be provided for road lighting and car park. The lamp shall have non-ferrous cast alloy housing with hinged non-yellowing type bowl complete with optical system to give CIE cut off light distribution neoprene gasket heat baffles, porcelain lamp holder all suitable for 250 W high pressure power factor corrected mercury lamp (HPMV).

**b) Tungsten Lamp**

Bulkhead type fitting having a body cast from corrosion resistant LM 6 aluminium alloy with light control by means of a prismatic glass held firmly in position in a hinged glazing ring complete with porcelain type lamp holder for 240V 100 Watts tungsten lamp shall be provided at entrance and exist of substation building. Fitting shall be weather proof.

All fittings shall be completely weatherproof and specifically designed to withstand the high temperature imposed by this particular light source. The casings and reflector shall be manufactured from aluminium and shall be complete with armour glass front, suitably rated HRC fuse and heat resistant cables to a fixed terminal block.

**c) Fluorescent Lamp**

For normal and emergency lighting within the substation building the fittings shall be weather proof, fluorescent fittings, twin tube light, industrial type with glass diffuser.

The emergency fittings mounted near the escape doors shall have exit sign written both in Arabic and English.

**d) Sodium Lamp**

For the security lighting weather proof Sodium Vapour Lamps fittings shall be provided. The fittings shall be of cast aluminium housing with control gear and lamp holder and stirrup for mounting. The fitting shall be suitable for 250 or 400 watt Sodium Vapour Lamps.

**e) Lamps**

The scope includes the supply and erection of all lamps and tubes necessary to complete the installation.

## **11.7 TYPE OF SOCKET OUTLET**

The various types of socket and switch fused spur outlets to be supplied and installed shall comply with OES 4.

All sockets and spur outlets shall be mounted at 0.5 meters above floor level and are to have terminals adequate to receive 2-4 sq.mm conductors, with the exception of those for use with clocks which are to be mounted at 2 meters above floor level and have terminal capacity for 2-1.5mm<sup>2</sup> conductors.

**Type S2**

To comprise a one gang 2 Amp two pin socket outlet with galvanised iron base and baseplate suitable for use with synchronous electric clock. The necessary plug is to be provided with each socket.

**Type S13**

To comprise a one gang metal clad 13 Amp, 3 pin interlocked and shuttered surface mounted switch socket outlet with galvanised iron box to the requirements of the appropriate code or standard.



#### **Type S23**

To comprise a one gang metal clad, 13 Amp switched fused spur outlet with fuse manufactured to the appropriate code or standard suitable for surface mounting with aluminium box.

#### **Type S100**

To comprise a one gang weatherproof galvanised iron clad 100 Amp, heavy duty, 3 pole, 415V socket outlet with scrapping earth connection. A screwed dust cap and cable gland shall be included.

### **11.8 LIGHTING AND SOCKET REQUIREMENTS**

The lighting installations shall be designed to give the illumination levels for the respective areas set out in the following schedule. The installations shall also meet the limiting glare index requirements as set out in the approved code.

This schedule also gives proposals for the types of fittings to be used in each area, type of control to be employed, number of socket outlets and the type of mounting expected to be suitable for the respective areas.

The word "remote" under the heading Type of Control indicates that it is proposed that the lighting fittings be switched by the contactors controlled from ON/OFF push-button stations or time switches located at suitable positions in the area of the lighting circuit.

The word "local" indicates the lighting fittings shall be switched by 5 Amp single pole switches positioned in the area to be lighted.

The emergency lighting system shall be supplied from the 110 volt battery at the substation.

Emergency lighting shall be arranged to illuminate all exits and entrances, and provide some illumination in the switchgear rooms and in the control rooms. DC supplies for emergency lighting shall be obtained from the DC distribution board via an emergency lighting contactor in the event of failure of AC supplies.

A battery operated, self contained quartz clock.

## SCHEDULE OF REQUIREMENTS

AREA	LIGHTING LEVELS	TYPE OF FITTINGS	TYPE OF MOUNTING	CLOCK	TYPE OF CONTROL & SWITCH	SOCKET OUTLET
	LUX	INDEX	MAIN	EMERG		
<b>SUBSTATION</b>						
Control Room	400	19	F	T	C	L1/Local S2 2/room
Switch gear Room	100	-	F	T	W	L1/Local S13 4/room
Offices	400	19	F	T	C	L1/Local S13 4/room
Toilets	100	-	F	-	C	L1/Local S23 1/room
Stores	200	-	F	T	C	L1/Local S13 4/room
Battery Room	100	-	F	T	C	L1/Local S13 2/room
Outdoor Yard	100	-	F	T	Flood Lights	L1/Local S100
<b>EXTERNAL AREA</b>						
Road Ways	10	-	M	-	8 pole	Remote
Car Park	10	-	M	-	8 pole	Remote
Fence	10	-	M	Flood light	Height to suit	Remote
<b>NOTE :</b> <div> <div>"C" denotes "CEILING MOUNTING"</div> <div>"W" denotes "WALL MOUNTINGS"</div> <div>"F" denotes "FLUORESCENT LAMP"</div> <div>"T" denotes "TUNGSTEN FLAMENT LAMP"</div> <div>"M" denotes "HPTW LAMP"</div> </div>						

### 11.9 CONDUIT AND FITTINGS

Conduit and fittings shall conform to OES 4 Clause 3.12.

### 11.10 INTERIOR AND EXTERIOR INSTALLATIONS

Installations shall be in accordance with OES 4.

### 11.11 EARTHING AND BONDING

Earthing and bonding of electrical installations in the substation building shall be in accordance with OES 4.

### 11.12 ERECTION OF LIGHT FITTINGS

Fittings shall be mounted direct in ceiling, walls. Where fittings are to be suspended, rod type suspension units shall be employed, with ball joints between the rods and ceiling plates.

Final connection to all suspended lighting fittings shall be with the fire resistant flexible silicon rubber cable terminated in porcelain clad connectors in the ceiling or junction box which shall also terminate the main circuit cable. The cable length shall be such that the rod suspension supports the full weight of the lighting fittings.

Where fittings are mounted direct on walls or ceilings the main cable tail may be wired into the fitting terminal block. Where terminal blocks do not exist flexible heat resistance cable shall be used to connect to a separate junction box.

## 11.13 DISTRIBUTION BOARDS

### a) Types and Breaking Capacity

Distribution boards and sub distribution boards shall be of the single busbar air insulated a metal clad type incorporating air break manually operated switch fuse units or miniature circuit breakers (MCB) or fuses.

All switchboards shall be suitably rated for a prospective rupturing capacity of 31.5KA at 415 volts.

### b) Busbars

Switchboards and fuseboards shall each include 3 phase busbars and one neutral busbar of high conductivity copper supported to withstand all normal and fault condition stresses.

The neutral busbar shall have a rating not less than that of the associated phase busbars.

### c) Construction

Each switchboard shall be constructed in accordance with OES 4. The switchboards shall be of a type which are readily extendible and shall be suitable for indoor or outdoor use as specified in a tropical climate.

Cubicle type switchboards shall be suitable for floor mounting with arrangements for bottom entry of cables. Provision must be included for gland plates so arranged that there can be no access by vermin and insects to the interior of the switchboard.

Distribution fuse or MCB boards shall be of the metal clad type with protective insulating barriers between the phases and between phase and neutral. Neutral connections for each circuit shall be made direct to the neutral busbar in each fuseboard via removable links.

The metal casing of the fuseboards shall be provided with knock out or other approved cable entries for accommodation of the cable and cable glands, the number and size of such knock outs being such that the fuse ways can be used in any combination of single phase and 3 phase circuits.

A no volt relay shall be fitted to the essential services sub boards to indicate a "LVAC" fail alarm when the supplies to both busbar sections is interrupted for more than 30 seconds.

### d) Switch Fuses

Each switch fuse unit shall be housed in a separate metal compartment and provided with a hinged metal door interlocked with the switch mechanism so that:

- i) The door cannot be opened whilst the switch is closed.
- ii) The door, on opening, automatically locks the switch in the "OFF" position. Facilities shall be incorporated to allow for the deliberate release of this interlock should for maintenance purpose, it be desired to observe the switch in operation.

An insulating barrier shall be fitted to segregate the fuses and neutral link from the switch and the connections of the later shall be effectively shielded by an inner screen when the compartment door has been opened to obtain access to the fuses.

The switch fuses may be either of the combination fuse switch type or of the type with the switch and fuse in separate units.

In either case, inter locking shall be provided to prevent access to the fuses until the associated switch is opened and provision shall be made for pad locking the switch in the "ON" and "OFF" positions.

The switch shall have a quick make and quick trip action independent of the speed at which handle is operated and shall be entirely suitable for switching the inductive loads associated with motor circuits.

#### **e) Miniature Circuit Breakers**

Circuit breakers shall be of the thermal/magnetic type to BS 3871 or equivalent with quick make and quick trip free mechanisms which prevent the breaker being held in against overloads or faults.

Tripping arrangements shall be such as to ensure simultaneous opening of all phases. Arc extinction shall be by de-ionising arc chutes.

The dolly shall have three positions, "ON", "OFF" and "TRIPPED". To reset from the "TRIPPED" position the dolly shall first pass into the "OFF" position.

MCBs on the main switchboard shall have facilities for locking in the "OFF" position.

The rupturing capacity of the MCB shall not be less than that of the switchboard itself, or if this is not the case back up fuses must be included.

#### **f) Contactors**

Contactors for controlling supplies to the "ESSENTIAL SERVICES" switchboards shall be of the 3 phase type with neutral links. The contactors shall be provided with electrical closing and hold-on-coils, the no-volt release being provided with a time delay feature adjustable between 0 and 30 seconds.

When in the "STANDBY SUPPLY" position, the contactors shall automatically revert to the "NORMAL SUPPLY" position as soon as such supply is restored.

The contactors shall be provided with an indicating lamp coloured amber to indicate when the contactors are in the standby position, and with clearly indicated "NORMAL" and "STANDBY" mechanical indications visible with the distribution board door in the closed position. It shall not be possible for incoming auxiliary supplies to be paralleled.

#### **g) Fuses**

Fuses shall be of the HRC cartridge type for operation at a prospective fault level of 31.5 KA and conforming to IEC 269. The mountings of the fuses shall be such that they can be readily withdrawn and replaced whilst the associated busbars and circuits are alive.

Incoming circuits at switchboards and fuseboards shall not be provided with fuses, the circuits being protected in each case at the point of supply. Interconnector circuits with other 415 volt boards shall be provided with fuses at both boards.

#### **h) Interlocks**

In addition to the integral interlocks specified above to prevent access to the fuses until the associated switch is

open, "MAIN DISTRIBUTION" switchboards shall be provided with mechanical key type interlocks of the "CASTELL" type in order to prevent the two normal incoming supplies being paralleled with interconnector circuits from other boards.

The interlocking arrangements shall be as follows:

- a) The switches controlling the normal incoming supplies and the switchboard bus section switch shall be interlocked so that only two of these three can be closed at any one time.
- b) The switch controlling the interconnectors with other boards shall be interlocked so that it can be closed only with the bus section switch and/or the switches controlling the normal incoming supplies open and vice versa, in order to prevent the interconnector being paralleled with either of the normal supplies.

**i) Earthing**

Earthing of metal of switchboard, switch fuse units and distribution boards shall be bonded together and connected to earth pit for substation building. Earthing connection shall be carried out in bare finished copper strip with main connections approximately 25 x 4mm but atleast 100 sq.mm and subsidiary connections of 2.5 sq.mm.

**j) Oil Treatment Outlet**

The "Main Distribution" board shall include a suitably rated switch circuit for a three phase and neutral interlocked plug and socket. The interlock shall prevent withdrawal of the plug with the switch in the "ON" position.

The socket shall be suitable for an outgoing flexible trailing cable to the oil treatment plant. The plug shall be provided with a "SCRAPING EARTH" connection to the socket and means for connecting the cable earth screen/conductor to the plug cap. The socket outlet shall be installed adjacent to each transformer.

**11.14 SMALL POWER CABLES**

The supply and installation of cables and wires shall generally be as specified in OES 4.

**11.15 CABLE TRAYS**

Cable trays where required shall be provided and they shall conform to OES 4.

**11.16 TRUNKING**

Trunking where required shall be provided and shall be in accordance with OES 4.

**11.17 TELEPHONE SOCKET OUTLET**

Telephone socket outlet shall be provided in the following places:

- 1) Control Relay Room
- 2) Office
- 3) 33KV Switchgear Room
- 4) 132KV Switchgear Room

**12.0 AIR CONDITIONING AND VENTILATION**

**12.1 AIR CONDITIONING**

Air conditioning of the following areas of substation building as per requirement shown below shall be provided:

AREA		CONDITION TO BE MAINTAINED
1) Office, Control/Relay rooms power line carrier room, office room		25 plus or minus 1 Deg. C
		with 55 plus or minus 5%
		relative humidity
2) 33KV Switchgear room		32 Deg. C
3) 132KV Switchgear room		32 Deg. C

Detailed design calculations and plant details to be submitted for approval.

**12.2 VENTILATION SYSTEMS**

The following areas shall be mechanically ventilated to a minimum of 10 air changes per hour:

- Toilet
- Battery room

Supply panels shall consist of a sand trap, fresh air intake louvre, filter and fan section.

Air shall be extracted from each of the rooms by wall mounted extract fans discharging to atmosphere. Extract air volumes shall be 80% of the supply air volumes to maintain a positive pressure in these areas.

Extract ventilation shall be provided in the toilet by surface mounted centrifugal extractors. Each toilet extract unit shall incorporate two fans arranged for automatic changeover in the event of failure.

**12.3 INTERNAL NOISE LEVELS**

The maximum acceptable noise levels in all areas shall have a noise rating (NR) of 40.

All plant and equipment used in the works when operating at the design conditions stated on the drawings shall not result in NR criteria in excess of those shown above.

Where attenuation devices are added into systems to ensure the required room NR levels, the additional resistance to airflow produced by such devices shall be included as part of the system resistance when evaluating fan performance.

**12.4 VIBRATION**

All vibration producing equipment shall be isolated from the substation building by means of anti-vibration and noise isolators. The degree of isolation shall be such that the noise criteria specified above are not exceeded and that no part of the building structure is subjected to vibration amplitudes in excess of the following values.

Frequency (HERTZ)	2	5	10	20	50
Amplitude (MM)	0.2	0.07	0.02	0.008	0.002

## **12.5 RADIO INTERFERENCE SUPPRESSION**

All plant and apparatus, including such items as contactors, starters, relays and the like where the normal operation is such that interruption of low frequency or direct current occur, shall be fitted with means of suppressing all interference frequencies caused.

The standard of interference suppression shall be in accordance with the current edition of BS 800.

Details of the equipment and methods to be used in quantitative assessment of the level of radio interference shall be as specified in BS 727.

For guidance in the installation of electrical equipment to meet the foregoing standards, reference shall be made to BS Code of Practice CP 1006 ‘‘General Aspects of Radio Interference Suppression’’ which deals with interference caused by electrical apparatus and installations.

## **13.0 CABLES**

### **13.1 GENERAL**

All cables shall be suitable in all respects for the site conditions specified in OES 11.

The voltage and other basic characteristics of the systems to which the cables will be connected shall be as specified in OES 4.

Cables shall be suitable for operation at the guaranteed maximum sustained current ratings under the worst climatic conditions to be expected at the site.

Cables shall be capable of withstanding for a period of 3 seconds the maximum fault currents specified in OES 11.

For the purpose of calculating cable current ratings, the ground temperature at 1 metre depth of cover shall be taken as 35 Deg. C and the average thermal resistivity of the soil as 1.50 Deg. C m/w. The average maximum ambient air temperature shall be taken as 50 Deg. C.

### **13.2 CABLE SIZE**

Size of cables shall be as follows:

- a) 132KV feeder circuits to switchgear – 1C x 2000 sqmm/phase XLPE copper conductor.
- b) 132KV switchgear to 132/33KV 125 MVA transformer – 1C x 630 sqmm/phase XLPE copper conductor.
- c) 33KV XLPE cable between 125MVA transformer and 33KV switchboard – 2 Nos. X 1C X 630 sqmm/phase copper conductor.
- d) 33KV cables between 125MVA transformers and appropriate earthing transformers – 1 x 185mm<sup>2</sup>/phase copper conductor XLPE insulated.
- e) 1000V cables between auxiliary earthing transformer and main distribution board – 4C x 300sq.mm XLPE copper.

- f) 1000V cables between main distribution board and sub-board for essential services – 4c x 70mm<sup>2</sup> XLPE/PVC/SWA/PVC copper.

### **13.3 TYPE APPROVAL**

Cables and accessories for voltages of 33KV and above shall have satisfactorily passed type approval test equal to those required by the International Electro Technical Commission and details of the cable designs shall be given.

### **13.4 OUTER COVERINGS**

Unless otherwise specified, the cable outer coverings shall be provided in the form of an extruded continuous black PVC sheath which shall be type Table 1 of BS 6746. As a protection against termite attack, the outer coverings shall contain an evenly dispersed mixture of aldrin and dieldrin in the ratio of 0.25% aldrin and 0.25% dieldrin by weight of PVC, or other suitable detergent.

The PVC outer coverings for cables designed for voltages of 33KV and above must have been subjected to abrasion, penetration and saline bath tests during the type approval programme of tests.

### **13.5 CABLE DRUMS**

Cable drums shall be non-returnable and shall be made of timber, pressure impregnated against fungal and insect attack. Alternatively, cable drums may be made of steel suitably protected against corrosion. They shall be lagged with closely fitting battens in accordance with BS 1559.

Each cable drum shall bear a distinguishing number on the outside of one flange. Particulars of the cable i.e. voltage, conductor size, number of cores, type, length, gross and net weights shall also be clearly shown on one flange. The direction of rolling shall be indicated by an arrow on both flanges. Cable ends shall be sealed at the ends by approved means at the factory after testing.

### **13.6 JOINTING ACCESSORIES**

Cables shall be installed in maximum possible lengths and straight through jointing between shorter lengths, will not be permitted without the prior approval.

Jointing accessories shall include all necessary internal and external fittings, insulating materials and sundries, metal glands, armour clamps, earth bonding, terminals.

Mechanical glands for the termination of elastomeric or thermoplastic insulated cables into straight through joints and termination accessories shall meet the requirements of BS 6121 or equivalent IEC standard and shall be correctly designed for the termination of galvanised steel wire or aluminium armour. The gland shall not only adequately secure the armour to provide efficient electrical continuity, but shall also provide a water tight seal between the over sheath and the inner extruded or taped bedding to prevent the ingress of moisture. Glands shall project at least 25 mm above the gland plate to avoid any condensation flowing into the cable crutch. All glands shall be fitted with a substantial earth bond terminal.

Sealing end porcelains shall be free from defects and thoroughly vitrified so that the glaze is not depended upon for insulation. The glaze shall be smooth and hard, completely cover all exposed parts of the porcelain and for outdoor types shall be a uniform shade of brown.



Porcelain must not engage directly with hard metals and where necessary, gaskets shall be interposed between the porcelain and the fittings. All porcelain clamping surfaces in contact with gaskets shall be accurately ground and free from glaze.

Outdoor sealing ends and fittings shall be unaffected by atmospheric conditions, proximity to the coast, fumes, ozone, acids, alkalis, dust or rapid changes of air temperature between 15 Deg.C and 65 Deg.C under working conditions

All outdoor type sealing ends shall be provided with adjustable arcing horns.

A brass device shall be provided at the base of each sealing end to enable the insulator to be short circuited when required for testing purposes. Sealing end supporting structures shall be constructed of galvanised steel and their design shall be approved.

### **13.7 CABLE JOINTING INSTRUCTIONS**

Copies of the instructions for the jointing of each type of cable terminating and jointing accessories shall be submitted for approval before any work is commenced at site. Further copies of the instructions shall be bound into the Operating and Maintenance Instructions to be supplied at the completion of the contract.

### **13.8 SCHEMATICS AND ROUTING DIAGRAM**

The Contractor shall be required to prepare a comprehensive power and multicore cable schematic and routing diagram, indicating the positions of joints, earthing equipment and terminations of all cables for approval.

### **13.9 132 & 33KV SINGLE CORE XLPE CABLES**

#### **a) General**

The 132KV and 33KV cables shall be constructed in accordance with and conform to IEC Publication 502-1 subject to specific requirements detailed below.

#### **b) Conductor**

Cable conductors shall comprise stranded bare clean smooth annealed copper wires having a conductivity not less than 100% international standard. The surface of the individual strands shall be smooth and clean before applying insulation. The conductor shall comply with BS 6791 or IEC Publication 228.

#### **c) Conductor Shield**

The stranded conductor shall be shielded with an extruded semi-conducting layer before insulation is applied.

#### **d) Insulation**

The insulation shall be cross linked polyethylene meeting the following basic requirements:

- |                                   |            |
|-----------------------------------|------------|
| – Normal operating temperature    | 90 Deg. C  |
| – Permitted over load temperature | 130 Deg. C |
| – Short circuit temperature       | 250 Deg. C |
| – Chemical resistance             | High       |
| – Moisture resistance             | High       |
| – Thermal resistivity             | Low        |
| – Fire resistance                 | Good       |

- Minimum average insulation thickness for 132KV cable 18mm
- Minimum average insulation thickness for 33KV cable 9mm

The insulation thickness and dielectric strength shall be adequate and suitable in all respects for the highest system voltage of 145KV and 36KV continuously, the 132KV system neutral being solidly earthed, 33KV system neutral being earthed through 12.5 Ohm resistance via earthing transformer.

**e) Insulation Shield**

Individual core insulation shall be shielded by a layer of semi-conducting material applied directly over the insulation.

**f) Metallic Layer**

The semi-conducting insulation shield shall be covered by a bare copper shielding tape applied with a lap. The shielding tape shall be further supplemented by high conductivity copper wires in accordance with BS 6260 or IEC Publication 228 to meet the earth fault current specified.

**g) Sheath**

Sheath shall be extruded PVC complying with BS 6746 Table 1 Type 9.

**h) Bedding**

Over the sheath shall be applied a bedding fabric tape.

**i) Armour**

Armouring shall consist of single layer of aluminium strips applied over the bedding.

**j) Overall Serving**

The overall serving shall consist of extruded PVC over the armour. The serving material to be Type 9 Table 1 of BSS 6746.

Cable size, manufacturer's name, nominal voltage and the words Electric Cable shall be embossed on the PVC serving as per BS 6346. The PVC shall be fire retardant and termite resistance. Also, should be embossed on the PVC serving:

**“PROPERTY OF MEW, OMAN”**

**k) Jointing Accessories**

Jointing accessories for stranded copper conductor cables shall be designed for indentation or compression ferrules.

### 13.10 PVC INSULATED POWER AND CONTROL CABLES

**a) General**

This specification is for (A), single core and multicore power cables with conductors of stranded copper wires, and (B) control cables with stranded copper conductors.

All cables shall be PVC insulated, PVC sheathed, galvanised steel wire armoured or aluminium armoured, and PVC sheathed overall. The PVC shall be Type 5 Table 1 of BS 6746.

**b) Design**

PVC insulated cable designs shall meet the requirements of the IEC or of BS 6346 – PVC insulated cables for electricity supply (steel wire or aluminium armour) upto 16 sq.mm or BS 6004 – PVC insulated cables (non armoured) for electric power and lighting.

**c) Conductors**

- i) Except where otherwise specified, stranded copper conductors shall be untinned and comply with IEC or BS 6360. Single strand conductors shall not be permitted.
- ii) Conductors for control cables shall be of copper and have a cross sectional area of 2.5 sq.mm made up of 7/0.67 mm strands. Copper conductors shall meet the requirements of IEC or BS 6360. A minimum of 10% spare cores shall be available generally on all multicore control cables.

**d) Fillers**

Where fillers are necessary to make a circular compact PVC insulated cable, they shall be of PVC. Textile and other hygroscopic materials are not permitted.

**e) Cores Identification and Laying UP**

The cores of all cables shall be identified in accordance with Clause 7 of BS 6346. Multicore control cables shall contain one of the following standard numbers of cores:

4,7,12,19,27,37 and 48. When numerals are used, they shall be printed in black on the white core insulation at intervals not greater than 75mm throughout the length of the core. The print shall be permanent and not easily removed.

**f) Voltage Identification**

- a) The PVC outer sheath of power cables shall be embossed “ELECTRIC CABLES” followed by the voltage in accordance with Clause 14.2 of BS 6346.

- b) The PVC outer sheath of control cables shall be embossed with the legend “ELECTRIC LV CONTROL CABLE”. The letters shall be raised and consist of upright block characters in accordance with the requirements of BS 6346.

In addition, all 600/1000V armoured cables shall be further identified by a varnished yellow paper, cellulose acetate or similar tape, bearing the letter “LV” at intervals not greater than 100mm, applied immediately over the wire. The dimensions of the tape and marking shall comply with BS 6346.

**g) Jointing Accessories**

- a) Jointing accessories for stranded copper conductors shall be designed for compression type conductor jointing ferrules.
- b) The straight through jointing of short lengths of multicore control cables is not permitted.

### **13.11 TELEPHONE TYPE CABLES**

**a) Design**

Telephone type multipair cables shall have tinned copper conductors insulated with PVC, armoured and shall

be sheathed overall with PVC. They shall be suitable for internal and external use in a tropical climate five pair cables shall be used.

**b) Conductor**

Each conductor shall consist of a single tinned annealed copper wire, to BS 6360/1969 or IEC Standard 228 and shall have a nominal diameter of 0.9mm. The DC resistance per km of each conductor in the finished cable at 20 Deg. C shall not exceed 29.67 Ohms.

**c) Insulation**

The conductor insulation shall be extruded PVC type 2 in accordance with BS 6746/1976 and shall have a radial thickness of 0.30mm plus or minus 0.1mm. The insulation thickness shall be determined in accordance with Clause 18 of BS 6346/1969.

**d) Identification of Cores**

The cable shall be made with twin twisted pairs. Cores shall be clearly colour identified.

**e) Twining and Laying Up**

The insulated conductors shall be uniformly twisted together to form a pair and the requisite number of pairs laid up to form a compact and symmetrical cable.

**f) Fillers**

Fillers are not required.

**g) Binders**

A polyethylene terephthalate (PTP) tape having a thickness of not less than 0.013mm shall be applied over the laid up cores with a 50% overlap.

**h) Bedding and Armour**

Cables shall be provided with an armour bedding of extruded black PVC. Type TMI or 6 compound in accordance with BS 6746/1976. The armour shall consist of one layer of galvanised steel wires complying with requirements of BS 1442. The thickness of the bedding shall be 1.0mm and the wire diameter 0.9mm.

**i) Oversheath**

The outer protective covering of the cables shall consist of an extruded PVC sheath in accordance with Clause 4.11.4 The PVC compound shall be Type TMI and coloured black in accordance with BS 6746/1976. The sheath radial thickness shall be 1.4mm and shall be determined in accordance with Clause 19 of BS 6346/1969.

**j) Identification of Manufacturer**

The PVC oversheath shall be embossed with the name of the manufacturer and year of manufacture followed by:

ELECTRIC CABLE – 100V

Embossing shall comply with Clause 14.2 of BS 6346/1969.

**k) Cable Lengths**

The cables shall be supplied in drum lengths of not less than 50m unless shorter lengths are specified or are required to complete a specific item of work.

**l) Joining and Terminating Accessories**

Straight through joining accessories for telephone type cables shall be designed for the accommodation of soldered or crimped ferrules.

All joining and terminating accessory designs for use with telephone type cables shall be submitted to the engineer for written approval before use.

**13.12 CABLE INSTALLATION AND EARTHING**

**General**

This section covers the installation of all cables described in the specification together with the erection of their joining and terminating accessories. It also include the bonding and earthing multicore and single core cables.

All cables laid inside substation boundary wall shall be in concrete trenches in trays with suitable earthed removable covers. Concrete trenches with trays and removable covers shall be provided within the substation boundary for future 33KV outgoing feeders.

**13.13 ERECTION ON STEEL WORK**

**a) Supports and Racks**

shall be of hot dip galvanised steel.

Cable support and rack designs shall be submitted for approval before manufacture and erection. Ten percent (10%) spare space are to be provided on cable racks to allow the installation of future cables.

Multicore cable shall be clamped to the racks with smooth finish split packing pieces or cleats with bores of the correct size for the cable diameters.

The cleats shall be of silicon aluminium, glass filled nylon or other tough non-hygroscopic material. Single core cables shall be erected in close trefoil 3 phase groups in separate non-magnetic clamps.

All cable supports, racks, cleats, trays and sunshields together with all necessary steel work and fixing materials shall be provided and erected.

**b) Erection of Supports**

Rawl bolts shall normally be used for the fixing of supports and associated steel work to masonry.

The fixing of cable supports and associated steel work to building structural steel work, is to be carried out with bolted clamps. Weld gun stud fixing will be allowed subject to the approval on site but the drilling of building structural steel work shall not be allowed.

**c) Cable Trays**

Cable trays shall be of perforated galvanised steel and shall be supported on steel work or masonry as required.

**d) Erection on Racks**

Details of the spacings between supporting clamps proposed by the contractor for cables having a conductor size greater than 125 sqmm shall be stated.

The distance between rack supports for smaller power and for wire armoured multicore control cables shall be one metre for both horizontal and vertical runs.

**13.14 PULLING INTO DUCTS AND TROUGHS**

**a) Cable Ducts**

Cable ducts shall be supplied and installed. They will normally be in the form of asbestos cement or spun concrete pipes having a nominal inside diameter at least 40mm greater than the cable diameter.

Ducts shall be completely embedded in concrete with a minimum 150mm thickness of concrete surrounding the ducts on all sides. Ducts shall be sealed at each end, with foam type fillers or by other approved means to prevent the ingress of water and vermin.

**b) Cable Troughs**

Cable troughs shall be supplied and installed where required.

**13.15 LAYING DIRECT IN THE GROUND**

**a) Excavation of Trenching**

Laying of cable direct in the ground shall be done in accordance with OES 2. All other cables are to be laid to a depth in accordance with OES 2.

**b) Cable Laying and Protection**

Cables shall be laid and protected in accordance with OES 2.

**c) Backfilling**

Backfilling shall be done in accordance with OES 2.

**d) Cable Installation Under Roads**

Cables installed both along and under roads shall be protected by a concrete raft having a minimum thickness of 250mm and a width extending a minimum of 150mm beyond the sides of the cable trench. The concrete raft shall be of a 6-3-1 or 8-4-1 mix and shall be laid immediately below the metalled surface of the road which shall then be reinstated.

**13.16 CABLE PULLING**

Cable pulling shall be carried out in accordance with OES 2.

### **13.17 JOINTING AND TERMINATING**

The contractor shall be wholly responsible for the terminating into sealing ends or end boxes and the jointing of all cables erected. Cable sealing and jointing shall be in accordance with the best current practice and of first class workmanship.

Where cable screens are used as earth continuity conductors, glands shall have the necessary contact surface and bonding clamps to provide a low resistance path under fault conditions.

It is required that the PVC outer covering shall be subjected to periodic HV DC integrity tests. Joints and sealing end boxes shall be efficiently insulated and testing facilities shall be installed with the jointing accessories in an approved manner.

Where cables terminate into marshalling boxes, glanding off and termination shall be carried out. Straight through joints will not be permitted.

### **13.18 CABLE IDENTIFICATION**

#### **a) Core**

The markers and identifying ferrules shall be provided.

#### **b) Cable Route Markers**

Where cables are buried in the ground, cable route markers shall be provided to indicate the location of the cables. All route markers shall be made of reinforced concrete or of other materials approved for the climatic conditions. Suitable materials for their manufacture or alternatively, the completely manufactured article should be assumed to be available locally.

#### **c) Cable Markers**

All power, control and telephone type cables shall be provided with identification markers at their terminations, and where the cables are not laid in the ground at points along the route at intervals of not more than 50 meters apart. Markers shall be made of durable material of an approved type.

#### **d) Core Markers**

Cores of solid dielectric and plastic insulated low voltage multicore control cables shall be identified with lettered and numbered marking ferrules which shall be made of a permanent material and shall be of an approved type.

#### **e) Cable Protection from Sun**

Where cables are installed and exposed to direct solar radiation, sun shields of approved material and design shall be supplied and erected.

### **13.19 BONDING**

#### **a) Pilot Cables**

The armour of pilot cables with extruded outersheaths shall be bonded together and connected to earth at all terminating and jointing accessories. Solid bonding connections shall also be made between adjacent multicore cables at terminations and joints.

**b) Power Cables**

All cables having an extruded outer covering shall be installed as an all insulated system.

Single core cable screens may either be solidly bonded or specially bonded (single point bonded or cross bonded).

Multicore cables shall be solidly bonded at each termination. Details of the proposed bonding system together with a schematic diagram shall be submitted.

**c) Copper Earthing Connectors**

Bonding leads shall be of sufficient cross sectional area to carry the maximum imposed short circuit level. Dimensions shall be submitted.

**14.0 POWER LINE CARRIER**

**14.1 GENERAL**

At present, there is a power line carrier telephone system supplied and installed by Brown Boveri Co Ltd., Baden, Switzerland in the Ministry's 132KV system. This includes tele-protection channels for the 132KV lines and telecontrol for transmitting alarm signals.

The power line carrier system is to be enlarged and extended with such additional equipment as necessary to embrace the new substation in respect of both telephone, Tele-Protection and telecontrol channels.

Duplex carrier communication circuits equipped with transmit/receive high frequency units of the single side band amplitude modulated type shall be provided. The equipment shall be completely compatible with existing Brown Boveri equipment.

**14.2 CARRIER FREQUENCY ALLOCATION**

The design shall include where appropriate, frequency allocation plan to include all the 132KV circuits shown as future in addition to circuits to be connected to the new substations.

All carrier frequency plans shall be agreed with the governing radio frequency licensing authority to ensure non interference with Air Traffic Control, Navigation Beacons etc.

**14.3 HV LINE COUPLING**

**a) General**

The high voltage transmission system is a three phase 50Hz system operating at a nominal 132KV voltage. The system's highest voltages are 10% in excess of the nominal voltage. The system is designed for impulse withstand levels of not less than 650 K Vp.

**b) Method of Coupling**

Coupling of the carrier signals to the transmission line shall be intercircuit between phase of one circuit to phase of the other circuit.

All line traps and mountings, coupling filter, conductor clamps, HF connections, matching transformers, coupling capacitors and mounting pedestals, high frequency cables and glands required to complete the HF installation at each site shall be provided.



The drainage coils comply with IEC Publication 60. Coupling capacitors and coupling filters together with mounting framework and brackets shall be mounted on separate structures as shown in Drawing No. 132KV/125MVA/1. Line traps shall be mounted on coupling capacitors.

The capacitor shall have a rated capacitance of not less than 5000 pF at the working voltage of 132KV and an impulse withstand voltage of 650KVp and meet the insulation and test voltage requirements of IEC recommendation for such devices (IEC Publication 358 – coupling capacitors and capacitor dividers).

#### **c) Line Traps**

The line traps shall have a rated continuous current of not less than 1600 amps and shall be capable of withstanding 31.5KA for a period of 3 seconds. The preferred value of coil inductance shall be 0.2 millihenries although other values will be considered. The line traps shall have a protective device which utilises nonlinear resistor type arrestors (IEC C99-1) and the discharge current shall be less than 10KA.

Line traps shall meet the tests recommended in IEC Publication 353 line traps, with regard to temperature rise, short time current ratings, protective discharge etc. and also the blocking capabilities of the line trap.

All line traps shall be provided with clearly visible rating plates which shall include: manufacturer's name, type, serial number, rated continuous current, rated short circuit current and blocking band etc.

Line trap inounting and connecting details shall be furnished.

#### **d) Coupling Units**

The high frequency coupling units together with mounting bracket shall be suitable for mounting on individual structures as shown in Drawing No. 132KV/125MVA/1. The filters shall be suitable for outdoor use in a hot dusty climate and shall have weatherproof door seals together with breather holes to avoid condensation.

The units shall have an earthing switch which should preferably be interlocked with the box door/lid such that the latter cannot be opened unless the earth switch is closed to earth the device. Clear indication of the ON/OFF position of this switch shall be indicated. The terminal on the filter which shall be connected directly to the substation earth shall be clearly designated.

The intercircuit coupling shall be such as to earth either to the coupling filters and continue with carrier transmissions on a phase to earth basis using the other filter.

The coupling device shall meet in full the safety and protection requirements of the IEC recommendations for such devices (IEC Publication 481 – coupling devices for power line carrier systems).

The tuning range of the coupling unit(s) shall be suitable for the HF carrier frequency allocations proposed and the composite loss over each range shall not be greater than 2db. The line side and equipment side return losses shall be preferably less than 12db over the available band width of the filter. The line side impedance of the device shall be suitable for the range 200-400 ohms for phase to earth coupling whilst the nominal equipment side impedance shall be 75 ohms (unbalanced) or 150 ohms (balanced). The device shall be fitted with a rating plate which shall include manufacturer's name, type, serial number, peak power, bandwidth etc.

**e) High Frequency Cable**

High frequency cable suitable for connecting between the coupling filters and the indoor high frequency units shall be provided. The cable shall have a characteristic impedance of 75 ohms or 150 ohms depending upon the impedance of the coupling filters and the indoor equipment. The cable shall be PVC covered, steel wire armoured with a further outer sheath of PVC. Cross section of the cable showing the construction and make-up shall be furnished together with electrical characteristics and test voltage.

**14.4 POWER LINE CARRIER HIGH FREQUENCY UNITS**

**a) General**

The type of equipment provided shall be of the single side band type constructed on modular basis with modules plugging into shelves. The equipment shall be composed completely of solid state devices – no thermionic devices shall be permitted.

The design and performance requirements to be met by the power line carrier shall include the transmission of any combination of the following types of information:

- a) Speech for telephone communication
- b) Telephone signalling
- c) Coded signals for supervisory/indications/telemetry
- d) Tele-Protection
- e) Teleprinter signalling

40

The equipment shall be suitable to operate at all times within the temperatures specified in OES 11. Manufacturers shall state what precautions have been taken if the air conditioning fails and the equipment is subject to the environmental conditions specified in OES 11.

**b) Technical Details**

The equipment shall be of the single side band type with suppressed or reduced carrier transmission and each channel shall have a 4 KHz bandwidth. The sidebands for a duplex link may be adjacent, inverted or erect; the methods of transmission shall be mainly stated. Any limitations in paralleling their own or other manufacturer's equipment shall be stated with details of necessary frequency spacing.

Each 4 KHz band shall be capable of carrying varying amounts of communication traffic and should preferably be split as follows:

Speech	300-2400 Hz
VFT Channels	2400-4000 Hz

AGC  
Telephone signalling

To be furnished  
To be furnished

A VF allocation plan showing the available channels in line with CCITT recommendations.

The virtual carrier frequency difference, in a pair of terminals, between the VF signal applied to the transmit end and that received at the receive end shall not exceed 2 Hz.

The nominal carrier frequency output power of the PLC terminal with 100% modulation shall be 10/15W and shall be measured at the line.

The nominal impedance at the carrier frequency output shall be 75 ohms (unbalanced) or 150 ohms (balanced) and provision shall be made for terminating the output in an appropriate dummy load. The return loss within the nominal carrier frequency band in the transmit direction shall be less than 10 db.

The maximum line attenuation possible to achieve a signal to noise ratio at all times greater than 26 db should normally be 35 db or higher.

**c) Telephone Channels**

The two way telephone channels shall be suitable for 4 wire working at transit stations as determined by the requirements of the telephone scheme.

However, circuits terminating at a station shall be suitable for connection to a 2 wire telephone exchange and 2/4 wire switching shall, therefore, be available as standard facility.

The preferred method of telephone signalling shall be to utilise the same VF signalling channel as the AGC in order to conserve above speech bandwidth.

The relative four wire levels used for speech transmission and reception shall be stated.

All speech and VF signal input and output circuits shall be balanced and have a nominal impedance of 600 ohms. The return loss within the effectively transmitted frequency bands shall be not less than 14 db.

Telephone facilities shall be provided between bays at each end of a link using a hand set together with an audible form of calling and also a lamp.

Telephone channels shall not require the use of companders although it should be possible to add these in the future should there be a service requirement.

**d) VFT Channels**

The input and output signal levels for the VF channels detailing the method and percentage of modulation under normal working together with a statement regarding the addition of VF channels in the future, shall be furnished.

**e) Receivers**

The method of automatic gain control proposed shall ensure that in the case of a 30 db change in carrier frequency signal level within the regulation range, the change in voice frequency receive levels of both speech and VF signals shall be less than 1 db. A receive level low alarm shall be given some 6 db above a receiver fail alarm when the system has failed completely.

**f) Service Conditions**

The set noise generated within the terminals shall comply with IEC recommendations (Publication 495) as shall the cross talk attenuation between speech and VF signalling channels.

The type of modulation proposed for the speech and VF channels shall be stated.

The level of spurious emission shall be clearly stated in the Schedule of Guarantees together with the frequency response of the speech channel referred to 800 Hz and VF. Signalling channels referred to 3.0 Hz.

The equipment shall operate to its stated performance with a variation in power supply of -100% to + 15% and remain operational with an increase of power supply voltage of up to 20% of the nominal value.

**g) Voltage Withstand Requirements**

The equipment shall be designed to withstand satisfactorily the following insulation tests:

- a) 2KV AC RMS 50 Hz applied for one minute between:
  - i) All terminals (other than earth terminals) connected together and all metallic parts to be earthed in service.
  - ii) Between the output contact terminals with the contacts closed, and all the remaining terminals connected together.
  - iii) Between all electrical circuits of the equipment not intended to be connected together in service except where an earthed barrier exists between the circuits or where the circuits have mating contacts between them.

- b) 1KV AC RMS 50 Hz applied for one minute across each output contact with the contact in the open position. When the carrier frequency terminals are not isolated from earth they shall be capable of withstanding an impulse voltage of 3KV 1.2/50ms applied between each terminal and earth.

The equipment shall not be subject to interference by the presence of electrical noise generated by isolator switching operations. The bandwidth of such noise extends from 10 KHz to 1mHz and can peak to 1200 volts at the coaxial termination. Limiting diodes of the avalanche type should be provided at the HF cubicle terminals in order to limit this voltage to 400V peak to peak.

**h) Test Facilities**

The equipment shall have clearly designated test points on the modules on which adjustments are required together with test points on modules having nominal reference points. It shall be possible to mount a bay transmission measuring set or equivalent instrument in the sub rack to which the various test points can be connected to achieve wideband measurements.

The equipment shall also have a variable level 800 Hz oscillator for injection of test tone when commissioning or maintenance work is performed on the bay. The minimum requirement for alarm lamps shall be receive level low, receiver fail and transmitter fail and "clean" contacts shall be provided to initiate a remote carrier fail alarm.

**i) Mechanical Details**

In addition to the requirements of Section Y of the specification regarding equipment mounting practice the following conditions shall apply to the communications equipment.

- 1) All terminal boards shall be mounted in accessible positions and, when in enclosed cubicles, are preferably to be inclined towards the door. Spacing of adjacent terminal boards shall be not less than 100mm and the bottom of each board shall be not less 200mm above the incoming cable gland plate.

Terminals, mounting arrangements and method of termination shall be subject to the approval of the Engineer.

- 2) Each item of equipment in a group (i.e. a cubicle in a suite of cubicles) shall be individually fused and shall provide an alarm indication on loss of supply. One fused outlet from the main distribution bar shall feed an alarm type fuse panel mounted in the cubicle. This fuse panel shall supply individual items of equipment.
- 3) . It shall be possible to remove/replace cards without damage and without interfering with the operation of the rest of the equipment or system; if necessary consideration should be given to switching off the supplies locally to a card to prevent inadvertent interference to the equipment or system when removing/replacing a card.
- 4) Application of battery or earth via a test lamp to any external interface point or test point shall not lead to any component damage.
- 5) Power supply busbars in cubicles shall be carefully routed and each busbar shall be shrouded. It shall not be possible to inadvertently short busbars either between themselves or to earth.
- 6) Electronic equipment shall not use local internal batteries unless the approval of the Engineer has been obtained. Where approval is given, batteries used inside equipment shall be of the totally sealed, leak proof type.
- 7) Indication of blown fuses shall be clearly displaced by, for example, monitoring of the fuse(s), or by the use of alarm-bead type. Circuits shall be grouped so that, following the operation of a protective device, the minimum practicable loss of facilities occurs.  
The design, location and connections of fuse carriers and bases shall be such that they do not present a danger to an operator when replacing a fuse link with the equipment still connected to the supply and switched on.
- 8) Cubicles shall be complete with all necessary tag blocks, terminal plates and blocks and cable glanding facilities for small wiring and multicore cables. These items shall be located in an approved easily accessible position.

The design and construction of all cubicles, junction boxes etc. shall be such that cable terminations are arranged for either top or bottom cable entry for all cables.

The general design of cubicles shall be subject to approval, but they shall in general be of fabricated steel construction provided with shelves on which mounting plates can be accommodated. The height of cubicles or racks shall not, unless otherwise approved, exceed 2.250 meters in height.

Cubicles shall be free standing and shall permit anchoring to the floor.

The arrangements and method of mounting of all apparatus in the cubicles shall be to the approval of the Engineer.

All ventilation holes and similar external apertures of enclosed equipment shall, wherever necessary, be fitted with a close mesh gauze as a protection against the entry of insects.

- 9) Hinged doors shall be provided and arranged to lie flat back and not restrict access to the apparatus contained within the cubicle. Hinged doors shall be of the lift-off type unless there is wiring on the door, and shall be secured with integral handles and shall be flush fitting and sealed with a gasket of rubber or other approved material to prevent the ingress of dust. Provision shall be made for locking, with two keys provided for each lock. Cubicles and doors shall be structurally sound and not liable to distortion.

Where hinged gates are used for mounting equipment, they shall be provided with adequately protected wiring, of sufficient length and flexibility, to the equipment.

The lowest shelf or mounting plate shall not be less than 250mm from floor level.

Alarm lamps shall be visible externally, with all doors closed.

- 10) Equipment provided in duplicate to function as working and standby units shall be arranged in separate cubicles and separate suites to allow either unit to be set up, powered, and tested independently of the other unit to ensure that the equipments are in the working order to ensure the avoidance of common mode failure.

- 11) The environmental requirements of the Specification shall be taken into account when considering ventilation arrangements.

Heat dissipation of cubicle mounted equipment shall be kept as low as possible. For equipment which will be supplied to this Specification, the average dissipation per cubicle shall be stated.

Natural cooling is preferred. The approval of the Engineer must be obtained in all cases where it is intended to incorporate forced cooling.

Where the use of forced cooling has been approved, means shall be provided for indicating and alarming any significant reduction in air flow, and the equipment shall be so protected that no damage occurs due to failure of the forced cooling.

The full requirements of the performance specification shall be maintained until the protective device operates, and the period for which the equipment can remain in operation at maximum ambient temperature without forced cooling shall be stated.

The effects on its subsequent performance shall so be stated. Air blown through equipment for cooling purposes shall first be passed through an efficient dust filter. Multi stage filters, arranged to permit individual filters to be removed for cleaning, are preferred.

- 12) The shelves which form a sub track shall be suitable for mounting in cubicles which do not require rear access. The cubicles shall be dust and vermin proof.

- 13) Inside the base of the cubicle there shall be a substantial earthing bar with studs to which the substation earth and all internal earthing shall be connected. No reliance shall be placed on the conductivity of metal to metal joints without the use of special connectors.

Connections between circuit and metal work shall only be made for reasons of safety and/or reduction of interference. Where such connections are made, they shall not be used as normal current carrying earth returns.

- 14) The cubicles shall be clearly labelled as to the bay designations and all alarm lamps and LEDs shall be clearly labelled. There shall be at least one external cubicle alarm illumination per internal PLC bay which will indicate the internal fault conditions when the cubicle doors are closed.

All modules and their shelf location shall be cross reference and it is preferred that coded key slots are used in the edge connectors in order that modules cannot be plugged into the wrong shelf position.

The shelves which form a sub rack shall be suitable for mounting in a cubicle with at least two bays in a cubicle of height not exceeding 2.250m. There shall be good access to all cubicle terminals to which all external cubicle cabling shall be connected. There shall be a large gland plate fitted near the base of the cubicle through which all cables shall be glanded.

Inside the cubicle there shall be a substantial earthing bar with studs to which the substation earth and all internal cubicle earthing shall be connected.

All modules shall be identified as to their shelf location and it shall be preferable to use coded key slots in the edge connectors in order that modules cannot be plugged into the wrong position. The cubicles shall be clearly labelled as to the bay designations and all alarm lamps shall also be clearly labelled. There shall be at least one external cubicle lamp per PLC bay which will indicate internal fault conditions when the cubicle doors are closed.

## **14.5 AUTOMATIC TELEPHONE SYSTEM**

### **a) General**

A telephone system shall be provided primarily to operate the HV system i.e. for switching and loading instructions, it will however also be used for maintenance and other purposes. The system shall provide duplex communications between stations.

### **b) HF PAX and Substation Termination Equipment**

HF PAX shall be provided at the substation. The pax shall be register controlled exchange of the semi electronic type with matrix or cross bar switching equipment and shall provide the following facilities:

- a) 4 wire tandem switching
- b) 4 wire long line extensions on pilot cables
- c) Priority breaking and forced release for the distribution control engineer
- d) Closed loop numbering plan

At the substation trunk termination equipment shall be provided for each carrier circuit together with a subscriber's telephone termination panel for the substation control room. The substation control shall be

able to break into the conversation of a transit call in an emergency if no other circuit is available to the central control centre and also be able to call the substation control telephone whether or not the hand set is off the cradle rest.

**c) Closed Loop Numbering Scheme**

The trunk numbering plan shall have three digit numbers which are the same for a given extension regardless from where the call is originated in the system. The first two digits shall designate the station and the third digit the particular subscriber extension within that station.

**d) Telephone Signalling**

The design of the telephone signalling system shall be chosen to best suit the future requirements of the central control scheme having regard to the most economic use of the frequency spectrum available for speech and telegraphing.

**e) PAX Assembly and Mechanical Construction**

The PAX (shall be of modular construction) and shall be housed in a well constructed dust proof cabinet. All equipment, apart from the switches and subscriber line relays shall be mounted on printed circuit cards which shall be plugged into shelves. The logic elements shall be largely built of integrated circuits with discrete components to interface between the relays and the integrated circuits.

**f) Telephone Instruments**

Telephone instruments equipped with cabling facilities push buttons at least one equipment with intrude and breaking.

Main distribution frames (MDF's) shall be provided with each PAX. These MDF's shall be housed in the PAX cubicle. Sufficient cubicles shall be provided initially to accommodate the ultimate number of lines.

The provision and termination of the interconnecting cables between the exchange and the MDF shall be included and also the termination of cabling external to the MDF which may be provided at a later date. External telephone extension shall be provided with fuses and protectors.

**14.6 TECHNICAL SPECIFICATION FOR THE TELECONTROL EQUIPMENT**

**a) General**

Telecontrol equipment shall be provided to transmit alarm signals from substation to the central control station.

**b) Telecontrol Requirements**

Four alarms (urgent, non-urgent and two spares) shall be transmitted from the substation to the central control station. The signalling shall be by means of frequency shift coded signals over one or more VF channels.

**c) Channel Allocations**

The VF allocation required for telecontrol shall be stated.

The equipment shall be mounted on cubicles provided of rigid construction and shall be dust and vermin proof. The cubicle door(s) shall be lockable.



## 14.7 TECHNICAL SPECIFICATION FOR TELE-PROTECTION EQUIPMENT

### a) General

Tele-Protection equipment shall be provided for 'direct' tripping. The tele-signalling channels for the teleprotection shall be routed on the PLC equipment.

### b) Teleprotection Equipment Requirements

#### 1) Direct Tripping

The direct tripping equipment is required to effect the tripping of circuit breakers to disconnect faulted transformers and other main plant from remote current infeeds, for acceleration of distance protection scheme and to relieve abnormal system loading conditions. This type of teleprotection shall operate the remote circuit breaker tripping relays directly and hence shall have inherent security against maloperations due to noise present in the bearer channel.

#### 2) Permissive Tripping

The permissive tripping signals are required to operate remote circuit breaker trip relay in connection with distance protection relays.

#### 3) Blocking Signalling

The blocking signals are required to prevent remote over reaching distance relays from operating for faults external to the protected line section to enable correct discrimination to be achieved.

### c) Technical Data

The tele-protection equipment shall be of modular construction and preferably mounted in the power line carrier units and work satisfactorily under the service conditions detailed in OES 11.

Manufacturers shall clearly state the precautions taken in the design of their receivers to safeguard the trip output against the presence of noise in the VF channel, and show clearly the differences between the equipment used for 'direct' and 'permissive' tripping.

In the case of the 'direct' tripping equipment, it shall not be possible to cause a trip output under any of the following conditions:

- i) Removal of any printed circuit module in either transmitter or receiver of a line including the PLC bays.
- ii) Switching ON/OFF of the power supply to the teleprotection equipment.
- iii) Switching ON/OFF of the power line carrier equipment at either end of the HV line.
- iv) Shorting of the output of the Teleprotection transmitter or shorting of the input to the Teleprotection receiver.
- v) Input signal level to the receiver below the receiver fail alarm thresh-hold.

The 'direct tripping' equipment shall be suitable for use with auto reclose schemes whereby the receiver trip output shall be maintained long enough to prevent the remote circuit breaker reclosing until the faulted plant is disconnected from the HV system. Details of how the equipment meets this type of requirement should be submitted.

The power supply to the tele-protection shall be taken directly from fused outlets on the distribution board and be separate from the PLC bay supply. Similarly each tele-protection equipment shall be separately fed from the 48 volts distribution board.

**d) Signalling Conditions**

The signalling speed of the channel shall be less than 30 milli seconds from the receipt of a trip command to the operation of the trip output at the receiving end, and the equipment shall work completely independently of the PLC speech and VFT channels used for other purposes. The equipment shall perform on a frequency shift principle shall perform on a frequency shift principle and shall if super audio channels are employed, preferably employ a total bandwidth of not greater than 480 Hz. Each Tele-Protection channel shall be completely independent of the other except for the transmission channel. Facilities shall exist such that the following conditions apply to the alarm and output circuitry.

SIGNALLING			
GUARD	OPERATE	FAULTY	OPERATIONAL
ALARM			
YES	NO	NO	NO
NO	YES	NO	YES
YES	YES	YES*	NO
NO	NO	YES*	NO

\* The alarm output shall not occur for at least two seconds however there shall not be any fleeting operational output prior to the alarm condition being given.

**e) Alarm Facilities**

The alarm output shall persist for a minimum period of 100 milli seconds and the operational output shall not be possible until the alarm output condition is removed.

A separate low level alarm shall be given but not prevent operation when the input signal level drops by 6 db from normal. Manufacturers shall state the level at which the receiver will cease to function in line with the above table, this level shall be at least 10 db below normal.

Clean contacts shall be provided for remote alarming purposes suitable for operation at 110 volts DC.

**f) Test Facilities**

Test facilities shall exist whereby important operating values can be checked and a suitable test/normal switch arrangement shall be provided to show that the trip output circuitry is disconnected and functional tests can be safely performed on the equipment.

In the case of the direct tripping equipment the test/normal switch shall be fitted with a lock and key and if more than one equipment is located in the same cubicle then each equipment shall have a different lock.

**g) Protection Interface**

The input/output interface to the protection equipment shall be by means of reed relays and the input/output rack wiring shall be carefully segregated from other shelf/cubicle wiring. The make contacts of the output relays shall be capable of making and carrying at least 250 VA at 110 V DC. The input reed relay shall be operated by "clean" contacts on the HV distance protection.

The isolation requirements of the protection interface shall be for 2KV RMS.

**h) Channel Allocations**

The VF allocations required for tele-protection channels shall be provided.

**i) Mechanical Details**

The equipment shall be mounted cubicles of rigid construction and shall be dust and vermin proof. The cubicles door(s) shall be lockable.

**14.8 ALARM FACILITIES FOR INTERNAL FAULTS**

Each PLC cubicle requisite number of alarm lamps shall be provided for internal fault of PLC equipment such as Inductive failure, Protection fail etc.

**14.9 48V BATTERY CHARGER/BATTERY SUPPLIES**

**a) General**

Two sets of batteries with chargers shall be provided at the substation. The batteries, supplied as two half batteries shall be of the nickel cadmium alkaline type. Each charger shall normally have separate 'boost' and 'float' charge units.

The charger equipment shall comply with the requirements of IEC 146 (BS 4417) and shall be self protecting in the event of overloads.

**b) Battery Chargers**

The 48V batteries shall normally be kept charged by a charger unit comprising of a float charger and a boost charger.

The battery shall be supplied in two 'half' batteries and the charging arrangements such that after an AC mains failure (or for maintenance purposes) it shall be possible to disconnect the one 'half' battery from the load so that it can be boost charged by the boost charger while the float charger supplies the the load with other 'half' battery. When the first 'half' battery is fully charged it shall be possible to switch it to the float charger feeding the load while the other half battery is connected to the boost conditions no volt contactors shall automatically parallel the two half batteries.

**FLOAT CHARGING CONDITIONS**

The automatic charger shall maintain the battery normally floating so that no discharge occurs under normal loading and the battery remains fully charged. Chargers shall be designed for single phase or three phase AC auxiliary supplies with nominal voltages of 240V/415 + 10% 47/53Hz and shall maintain the float charge automatically irrespective of variations in the voltage of the AC supply within the specified limits.

The automatic float charger output voltage shall not vary by more than plus or minus 1% of the nominal float charge value when connected to the load and operating under any combination of the following conditions:

- i) Frequency variation 47 to 53Hz
- ii) Rated output AC voltage variation plus or minus 6%
- iii) Output between 0 and 100% of the rating.

The output voltage regulator shall be adjustable within approved limits and shall be so designed that special tools are not required for such adjustment.

The reference voltage point for control of the charger output voltage shall not be obtained from a source external to the charger.

The output of the charger on float charge shall be equal to the normal battery standing load plus recommended finishing charge rate.

When the battery is connected to the charger, the posphometric noise level at the output for loads between 0% and 100% shall not exceed the equivalent of 2 millivolts at a frequency of 800Hz after weighing as specified by OCCITT.

#### **Boost Charging Conditions**

The boost charger shall recharge the battery after a heavy discharge. The voltage/current characteristics shall have a tapering characteristics in order to minimise gassing during the finishing period of a conditioning charge.

At normal rated input voltage and frequency the boost charger output shall be not less than its specified rating at any battery voltage within the range of nominal rating plus 20% or such other range as is approved. The maximum voltage for the boost charger when delivering the recommended finishing charge shall be not less than 1.7V per cell for nickel or cadmium alkaline batteries.

#### **Indicating Instruments**

The following shall be provided:

- i) input voltmeter
- ii) output voltmeter
- iii) output ammeter
- iv) charge/discharge ammeter

#### **Controls and Alarms**

Each charger shall be equipped with a switch fuse for the incoming AC supply and either an off-load isolator or disconnecting links for the DC output. For the out-station batteries two sets of disconnecting links shall be fitted to the boost charger, one for each section of the battery. All switchgear and isolators shall comply with the requirements of BS 5419.

The following alarms shall be provided as minimum; mains failure, charger fail, high volts, low volts. Clean changeover contacts shall be provided for external alarms.

#### **Distribution Board**

DC distribution panels shall be provided in each charger cubicle for up to 10 outlets. Each main item of equipment shall have a direct power supply connection. Teed connections will not be permitted.

### **c) 48V Batteries**

The batteries shall be of the high performance nickel cadmium type and shall be designed designed for a life expectancy of at least 25 years under the conditions of service likely to be encountered by the equipment detailed in this Specification.

A complete set of test and maintenance accessories suitably boxed shall be provided for each battery. A syringe hydrometer and a durable instruction card shall be included in each set.

Battery cases shall be of high impact polystyrenes translucent plastic.

Cells shall be numbered consequently and terminal cells marked to indicate polarity.

## **15.0 PERFORMANCE PENALTIES**

The following penalties shall be applied in the event of failure to meet guarantees.

– R.O. 1000/- for each KVA less than the nominal rating at the specified guaranteed temperature rises (applied to transformers)

Tolerance 1%

– R.O. 800/- for each KW iron losses exceeding the guaranteed losses (applied to transformers)

– R.O. 200/- for each KW copper and other load dependent losses (applied to transformers)

– R.O. 1000/- for each db exceeding the guaranteed noise level (applied to transformers)

– R.O. 2000/- for 1% current carrying capacity falling short (applied to 132KV busbars, 33KV busbars, 132KV bus coupler, 33KV bus coupler, 132KV feeders and 33KV feeders.

Tolerance 1%

– R.O. 5000/- per 132KV switchgear bay for 1% SF6 gas losses exceeding the rated annual losses.

## **16.0 INSPECTION AND TESTING**

### **PART A – MANUFACTURE**

#### **16.1 GENERAL REQUIREMENTS**

The whole of the plant shall be subject to inspection and test by a designated inspection agency appointed by the purchaser during manufacture, erection and on completion.

The approval of the results of any such inspection or test shall not prejudice the right of the owner to reject the plant if it fails to comply with the specification when erected or to give complete satisfaction in service. The costs of all tests including the provision of the necessary test equipment whether at the manufacturer's works or on site shall be deemed to be included in the price of the plant.

Before any plant is packed or despatched, the works all tests called for shall be successfully carried out. Certificates of all tests carried out shall be submitted.

Adequate notice shall be given when the plant is ready for inspection or test and every facility shall be provided to enable the inspection agency to carry out the necessary inspections and tests.

## **16.2 INSPECTION AND TESTING DURING MANUFACTURE**

Every facility shall be provided to enable the inspection agency to carry out the necessary inspection of the equipment. Costs of all tests during manufacture and preparation of test records shall be included in the price of the equipment.

Test instruments shall be approved and shall if calibrated by the National Physical Laboratory or such other body as may be approved.

Breakdown test voltages shall be measured by means of a crest or electro-static voltmeters connected to the high voltage side of the transformer or by an instrument connected to the low voltage side of the transformer supplying the test voltage, and calibrated in an approved manner by means of a sphere gap. Electrical tests other than impulse tests shall be carried out at a frequency of 50Hz.

## **16.3 TESTS AT MANUFACTURER'S WORKS**

Works tests shall include all routine electrical, mechanical and hydraulic tests in accordance with the relevant standards and this specification and in addition any tests called for by the inspection agency to ensure that the plant being supplied meets the requirements of the specification.

One complete equipment of each type and rating shall be subjected to type tests as specified in the relevant IEC or BS. In the event of certified copies of type test certificates covering equipment of similar design rating and construction type tests may be waived. The price of equipment shall include for the carrying out of such type tests where certificates are not already held.

Should the plant or any portion thereof fail under test to give the required performance, further tests which are considered necessary shall be carried out.

After satisfactory completion of the witnessed tests at the works, the plant shall be submitted for approval during dismantling prior to shipping.

No plant shall be despatched to site until release note is issued by inspection agency.

## **16.4 TEST CERTIFICATES**

Triplicate sets of all principal test records, test certificates and performance curves shall be provided for all tests carried out. The information given on such test certificates and curves shall be sufficient to identify the material or equipment to which the certificate refers.

## **16.5 REJECTION OF PLANT**

Any item of plant or component which fails to comply with the requirements of this specification in any respect whatsoever at any stage of manufacture, test, erection or on completion at site may be rejected in whole or in part as considered necessary.

After adjustment or modification the item of equipment shall be submitted for further inspection and/or tests. Plant or components with defects of such a nature that the requirements of this specification cannot be fulfilled by adjustment or modification shall be replaced at no extra cost.

## **16.6 PART – B : TESTS AT SITE**

Before any part of the plant or equipment is commissioned for commercial use, it shall be subjected to mechanical, electrical, operational and other tests as required to prove its compliance with the specification. All official tests shall be witnessed by the owner's site engineer. The results of all tests carried out, including any tests carried out independently shall be recorded in writing and four copies handed over within 7 days of the test.

All necessary apparatus, instruments, equipment and labour to carry out the tests shall be provided the costs of which shall be included in the contract price.

All materials, plant and equipment which fail to pass the tests due to or arising from faulty design, material or workmanship, or due to incorrect erection shall be replaced, repaired or adjusted and further tests carried out.

Taking over certificate will be issued only when the individual system has been completed, energised and after all tests and adjustments have been carried out.

## **16.7 CIVIL WORKS**

Soil tests, using approved methods and instruments shall be carried out to determine the load bearing qualities of the soil to ensure that the foundation design is suitable for the building and equipment to be placed thereon.

During the course of the building construction works, tests on concrete mixes and other materials shall be carried out in accordance with the specification.

## **16.8 LIGHTING AND SMALL POWER INSTALLATION**

The complete installation or any part thereof shall be tested, both before and after connection as stipulated in OES 4.

## **16.9 SCHEDULE OF TESTS**

### **GENERAL**

The following list gives the minimum requirements:

### **16.10 TRANSFORMERS**

The following tests are to be conducted on transformers:

#### **Work Tests**

##### **1) Summary of Tests**

- a) Transformers – Routine and Type Tests to IEC 76 Parts 1,2,4 and 5 and BS 171 : 1970 in respect of dielectric tests.
- b) Voltage Control Equipment – Routine and Type Tests to IEC 214 : 1976.
- c) Magnetic Circuit – Routine Tests.
- d) Cables Boxes and Disconnecting Chambers – Routine Tests.
- e) Porcelain Insulators – Routine, Sample & Type Tests to IEC : 1973, IEC 233 : 1967 or BS 3297.
- f) Complete Outdoor Bushing Assemblies – Routine Tests including partial discharge measurements for 132KV and higher voltage sample and type tests to IEC 37 : 1973.
- g) Tanks – Routine Tests and Type Tests.

- h) Cooling Plant – Routine Tests.
- i) Gas and Oil – Actuated Relays – Routine Tests.
- j) Galvanising – Routine Tests.

## **A) ROUTINE AND TYPE TESTS**

### **a) Routine Tests**

All transformers shall be subject to the following routine tests:

1. Measurement of winding resistance on all tap positions and phases
2. Ratio, polarity and phase relationship
3. Impedance voltage
4. Load losses
5. No load loss and no load current
6. Induced over voltage withstand including partial discharge measurements to IEC 270 : 1968
7. Separate source voltage withstand
8. Insulation resistance
9. Noise level tests to NEMA Standards Publication TRI . 1962.

### **b) Type Tests**

Temperature Rise Test : The test shall be in accordance with IEC 76 Part 2, and shall be carried out on one transformer of each size and type. Temperature rise tests shall be conducted on the tapping corresponding to the maximum losses.

### **c) Special Tests: Impulse with Voltage Withstand Tests**

They shall be made on one on leg of each transformer and shall include the following requirements:

1. The transformers shall have been subjected to the above routine tests prior to the impulse voltage withstand tests.
2. Impulse test regulating windings shall be carried out on the tap position at which, according to recurrent surge generator tests, the maximum stress occurs.
3. When impulse tests are carried out on LV windings by the transferred surge method, oscilloscope record shall be made of the current flowing to earth from the LV winding.
4. The procedure shall be as required by BS 171: 1970 Clause 35.3, the impulse test voltages being applied successively to each line terminal. Negative polarity is to be used throughout the tests.
5. The sequence of voltage applications shall be:
  - a) Impulse calibration test at 75% of the specified full wave voltage.
  - b) One 100% full wave voltage application.
  - c) Two 115% minimum chopped wave voltage application.
  - d) One 100% full wave application.
  - e) Repeat of calibration test of 75% of the specified full wave voltage.



Oscillographic records of the applied voltage and neutral current and/or transferred voltage are to be taken and included in the records.

Films of the oscillographic records are to be made available to the engineer at the time of the tests for his examination.

External flashover of the bushings during the chopped wave tests is not permitted.

6. At the conclusion of the impulse voltage withstand tests, the transformers shall again be subjected to the routine tests (a-1), (a-5) and (a-8) above.

7. Zero phase sequence impedance measurement. This test shall be carried out in accordance with IEC 76 or BS 171.

## **B) VOLTAGE CONTROL EQUIPMENT**

### **Routine Tests**

Each finished tap changer is to be subjected to the routine test specified in IEC 214 : 1976 /BS 4571 but in addition the mechanical test shall be carried out at rated voltage and no load.

### **Type Tests**

Shall be carried out entirely in accordance with BS 4571/IEC 214.

## **C) MAGNETIC CIRCUIT**

### **Routine Tests**

Each core completely assembled is to be tested for one minute at 2000 volts AC between core bolts, side plates, structural steel work and core at the core and coils stage.

After the transformer is tanked and completed assembled, a further test is to be applied between the core and the earthed structural steel work to prove that the core is earthed through the removable link, at one point only.

## **D) CABLE BOXES AND DISCONNECTING CHAMBERS**

### **Routine Tests**

To meet the requirements of subsection.

## **E) PORCELAIN INSULATORS**

The following tests are to be made on not less than 2% with a minimum of two of the porcelain insulators of each type.

- a) Temperature cycle test
- b) Porosity test

**F) COMPLETE OUTDOOR BUSHING ASSEMBLIES WITH PORCELAIN INSULATORS**

Routine Tests to include:

- a) Oil leakage test
- b) 50Hz dry withstand test
- c) Power factor/voltage test

Type Tests to include:

- 50 Hz wet withstand test
- b) Visible discharge test
- c) Impulse voltage test
- d) Flashover under oil test

**G) TANKS**

**Routine Tests**

Oil leakage – all tanks, conservators and oil filled compartments which are subjected in service or during maintenance to oil pressure are to withstand without leakage, a hydraulic pressure test equal to 69 sq. m or the normal pressure plus 34 Kn/sq.m whichever is the greater, for 24 hours during which time no leakage or oil ingress into normally 34 Kn/sq.m oil free spaces shall occur.

**Type Tests**

Unless type test certificates can be produced for tests carried out on similar equipment, the following tests are to be included for tanks, conservators and pressure relief devices.

- a) Vacuum Test – the equipment is to withstand of 50cm of mercury when empty of oil. The permanent deflection of plates or stiffeners on removal of vacuum is not to exceed the following values:

Length of Plates	Permanent deflection
Less than 1300mm	3.17 mm
1300 to 2500mm	9.5 mm
Greater than 2500mm	12.7 mm

- b) Pressure Test - the equipment is to withstand a pressure corresponding to 69 Kn/sq. m or the normal pressure plus 34 Kn/sq. m whichever is greater. The permanent deflection of plates or stiffeners on removal of pressure is not to exceed the value stated in respect of the vacuum test in the preceding paragraph.

**H) COOLING PLANT**

**Routine Tests**

- a) Coolers – pressure test to be as specified in section (G) – (b) above.
- b) Oil Pumps, oil pipework and valves – a hydraulic withstand pressure of 138 Kn/m<sup>2</sup> for 15 minutes.
- c) Water pumps, water pipework and valves – a hydraulic withstand pressure of 345 Kn/m<sup>2</sup> for 15 minutes.
- d) Motor and control gear – to the requirements of Clauses 0.51 and 0.52.

## **I) GAS AND OIL - ACTUATED RELAYS**

### **Routine Tests**

- a) Oil leakage – when subject to an internal oil pressure of 207 Kn/m<sup>2</sup> for 15 minutes.
- b) Gas collection
- c) Oil surge
- d) Performance test under service conditions including starting and stopping of oil pumps
- e) Voltage – 2KV for one minute between electrical circuits casing.

## **J) GALVANISING**

### **Routine Tests**

To the requirements of OES 11.

## **K) SITE TESTS**

All apparatus, instruments and connections for the tests after the completion of the erection work on Site shall be provided.

The following tests shall be performed:

- a) Insulation resistance tests
- b) Insulation resistance test at 500V between core and core clamping structure
- c) Voltage withstand tests on transformer oil to BS148
- d) Ratio
- e) Phase relationship
- f) Magnetisation characteristics of current transformers of winding temperature devices
- g) Calibration of winding temperature devices
- h) Tap selector and diverter switch alignment
- i) Calibration of automatic voltage control equipment
- j) Magnetisation characteristics and polarity tests on current transformers where provided and installed in terminal bushings under this contract.

## **16.11 CABLES**

Cables shall be tested as follows:

### **A) GENERAL**

The cables shall be inspected and tested in accordance with Section 13 of this Specification.

### **B) HIGH VOLTAGE/PARTIAL DISCHARGE TEST**

Each completed cable drum shall be subjected to a combined high voltage/partial discharge test to measure the permissible discharge. The AC test voltages shall be applied between the conductor and the core screen which shall be connected to earth. The tests shall be made at room temperature.

Rated Voltage E	132 KV		33KV			
Step No	1	2	3	1	2	3
Test Voltage (KV)	100	185	100	26	49	26
Permission						
Discharge (pc)	5	30*	5	10	30*	10

\* For cables having extruded outer semi conducting screen.

\* No breakdown of the insulation shall occur. The permissible break down discharge noise levels shall be less than 2.5 pc for 132KV cables and 5.0 pc for 33KV cables.

**C) CONDUCTOR RESISTANCE TEST**

The DC resistance of the conductor of the completed cable shall be measured and when corrected to 20 Deg. C shall not exceed the guaranteed values stated in the Schedule of Particulars and Guarantees.

**D) CAPACITANCE TEST**

The capacitance of each core of every drum length of completed cable shall be measured at room temperature and recorded on the test certificate.

**E) INSULATION THICKNESS MEASUREMENT**

The measurement of the insulation thickness shall be determined from a representative sample of the cable not more than 150mm in length taken not less than 300mm from the end of each factory length. Measurements shall be made by an optical method in which the error of determination does not exceed 0.025 mm.

The measurements shall be made at six approximately equally spaced points round the periphery of the sample and care shall be taken to ensure that the minimum thickness is measured.

The minimum average of the measurements shall be not less than the value stated in the Schedule of Particulars and Guarantees.

**F) VOLTAGE TEST ON OUTER COVERING**

Each drum length of completed cable shall withstand a voltage test for one minute between the metal screen and the external conducting surface of the extruded PVC oversheath. The DC test voltage shall be equal to 8 KV/mm thickness of covering with a maximum of 25 KV or, alternatively, the AC test voltage shall be 4 KV/rms per mm thickness with a maximum of 12.5KV. The minimum average thickness of oversheath specified shall be used for calculating the test voltage.

If the cable oversheath is not provided with a packed on graphitic coating, the cable drum length shall be completely immersed in water for the execution of this test.

**G) MEASUREMENT OF EXTRUDED BEDDING & OVERSHEATH THICKNESS**

The thickness of the bedding and oversheath shall be measured on a representative sample taken from the cable, not less than 150mm from the end of a manufacturing length, by a method in which the error or determination does not exceed 0.025mm (e.g. by use of a micro meter or an optical device).

**H) CAPACITANCE TEST**

The electrostatic capacitance of each cable core shall be accurately measured and the results, converted to microfarads per 1000 meters shall be recorded on Test Certificate.

**I) INSULATION RESISTANCE TEST**

The insulation resistance of EPR insulated cable only, heated to the rated maximum temperature for the installation shall be made between each conductor and its core screen and earth at room temperature. The DC test voltage shall be any constant value between 3000 volts and 500 volts and shall be applied for a sufficient time, of not less than a minute to reach a steady measurement.

#### **J) PARTIAL DISCHARGE TEST**

All components of the test equipment shall have a sufficiently low noise level in order to achieve the required sensitivity.

The alternating test voltage, at any frequency between 49Hz and 61Hz shall be raised sufficiently to result in clear indications of detection circuit response to partial discharge within the cable sample under test, except that, if the existence of discharges is not evident after the voltage has been raised to a value of 20% in excess of the required partial discharge extinction voltage, i.e. 12% of 1.25 times working voltage to the cable shall be considered to have satisfied this test.

The partial discharge extinction voltage level shall not be lower than 1.25 E<sub>0</sub> for approval when measured as stated in IEC Standard 540. The actual value for each core shall be recorded on the sample test certificate.

#### **K) BENDING TEST**

After the electrical tests specified above the cable shall undergo at ambient temperature, which shall normally be higher than 4 Deg. C a bending test round a test cylinder. The diameter of the cylinder shall be not greater than 18D for single core cable and 16D for three core cables where D = Outer diameter of cable.

Each bending cycle shall consist of winding the cable onto the test drum unwinding, rewinding onto the test drum in the reverse direction and unwinding. The cable shall be bent along the same axis in each case and the full cycle shall be completed three times.

#### **L) VOLTAGE TEST**

After completion of the bending test the cable shall be subjected to an AC voltage test of 3.5 E<sub>0</sub> at a frequency of 49-61Hz between the conductor and the core screen which shall be connected to earth for a period of one hour.

The voltage shall then be decreased gradually to 2.5 E<sub>0</sub> and kept at that value for one minute. The permissible discharge shall be measured and shall not be greater than 30 pc.

The discharge extinction voltage shall then be measured using an applied AC voltage at any frequency between 49 and 61Hz and the results shall be stated on the sample test certificate.

#### **M) ROUTINE TESTS ON SITE**

##### **1) Conductor Resistance Test**

When the installation of cables and associated jointing accessories has been completed, the DC resistance of each conductor shall be measured and recorded and when corrected to 20 Deg. C, shall not exceed the guaranteed value given in the Schedule of Particulars and Guarantees.

##### **2) High Voltage Test**

After the conductor resistance test, each cable shall be subjected to a DC voltage of 2E (where E is the rated voltage) applied for a period of 15 minutes between the conductor and the core screens which shall be connected to earth. The test voltage shall be raised gradually to the specified value at which point the test period shall begin. There shall be no breakdown of the electrical insulation.

### 3) Voltage Test On Outer Covering

The outersheath of each cable length shall be tested after laying but prior to jointing and backfilling above concrete slabs. The DC voltage shall be equal to 4KV for each mm of thickness of oversheath with a maximum of 10KV.

After completion of the installation, all insulating provisions, including external joint insulation, terminal base insulation, bonding leads etc. shall withstand a high voltage DC test equal to 2KV for each mm thickness of oversheath with a maximum of 5KV DC. The test voltages shall be calculated on the minimum average thickness stated in the Schedule of Particulars and Guarantees. The duration of the tests shall be one minute and the leakage current recorded for each cable.

This test shall be repeated every six months during the maintenance period.

## 16.12 POWER LINE CARRIER AND ASSOCIATED EQUIPMENT

The power line carrier, Tele-Protection, automatic telephone exchange and other equipment shall be tested as follows:

### A) GENERAL

The inspection and testing of the equipment specified shall comply with the general requirements specified.

### B) BARRIER ISOLATION TESTS

#### 1) General

The following "barrier isolation" tests shall be carried out on power supplies and connections to/from HV plant:

- Damage Tests: no permanent damage to the equipment shall be observed. For convenience, except for tests on power supplies, the equipment need not normally be energised for these tests.
- Mal Operation Tests: with the equipment energised, no mal operation shall occur as a result of these test, i.e. no false trips or control operations.

#### 2) Power Supplies

- Damage Tests : 24/48 V DC withstand application of any voltage upto 30/60 V.
  - 220 AC and/or 110V DC and/or 48V DC and/or 24V DC
- Withstand application of up to 10 times.

AMPLITUDE	DURATION
% of Supply RMS or DC Voltage	Min - Seconds
100	10
200	1
300	0.02
500	0.005

Withstand upto 10 times each, interruption of supplies for periods of 5 mS, 100mS and 500mS (BS 4509, Clause 2.4.13.2) and upto 20 seconds.

### 3) Connection To/From HV Plant

- Damage Tests: withstand application of BEAMA 219: 1966 test i.e. 5KV, 0.5 Joule for 1/50 microseconds, between terminals of the same circuit and between circuits not normally connected together.
- Normally open contacts of relays feeding outwards from the tele-control equipment shall withstand a voltage of 1KV RMS 50 Hz AC for 1 minute between all terminals connected together and earth and between circuits not normally connected together (BS 142:1966 Section 14 Clause 46.1.4).
- The insulation resistance shall not be less than 20 megohms when measured at 500V AC RMS, 50 Hz or 750 V DC applied for a period not exceeding one minute between all terminals connected together and earth and between circuits not normally connected together.

### 4) Mal Operation Tests

1000V RMS 50Hz AC (source impedance – 150 Ohms) shall be applied for a minimum of 1 second between earth and the signal terminal via a 0.2 uF capacitor for DC isolation.

## C) TESTS AT MANUFACTURERS WORKS

### 1) Operating Tests – Carrier Equipment (Routine)

Back to back system tests shall be carried out including overall frequency response, speech and signalling tests.

In addition, the contractor shall carry out factory tests to determine the characteristics including, but not limited to:

- Transmitter frequency stability
- Receiver sensitivity
- Receiver signal to noise ratio
- Receiver selectivity
- Receiver base band regulation
- Transmission frequency response
- Transmitter harmonic distortion
- Overall loop gain
- Line trap tuning
- Capacitance of the coupling capacitors
- Coupling unit characteristics

and any other reasonable tests which engineer so requires providing notice is given of such tests.

### Operating Tests – Telephone Equipment (Routine)

Back to back tests shall be carried out to check correct functioning of the exchange at normal and low supply volts. Priority tests etc. shall also be conducted as Shall transit working.

### Operating Tests – TeleProtection Equipment (Routine)

Back to back tests shall be carried out via the PLC links to determine the satisfactory operation of the Tele-Protection as in Section 11 of the Specification.

### **Operating Tests – System**

Full system tests shall be carried out to prove the compatibility of all the various types of equipment being supplied with each other and that all system requirements have been achieved as specified. The contractor must also prove that the equipment being supplied is totally compatible with any existing equipment.

## **2) Routine Tests**

The routine tests shall include, but shall not be limited to, the following:

### **Relay Adjustments**

All relays which are specified to have individual adjustments shall be checked in accordance with the data sheets.

### **Insulation Tests for Relays**

Windings and all spring combinations of each relay shall be tested at 500V or 2KV (as may be specified) to the yoke. Where the relay is intended to be insulated from its mounting, a similar test shall be made between yoke or relay frame and the mounting and cover.

### **Wiring**

All apparatus on each panel, cubicle or rack shall be tested to a voltage equal to the test voltage specified for the apparatus connected to it.

### **Line Isolation Equipment – 2KV or 5KV**

Line isolation equipment specified to withstand 2000V AC or 5000V AC shall be tested at these voltages between the line terminals and the apparatus terminals and the frame work and covers.

## **3) Test Schedule**

The contractor shall submit a proposed test schedule for the system tests and shall state in the schedule the total allowable outage time for the system.

The test schedule shall include:

- Test of the whole system to check its performance operationally
- Facility check of power line carried system
- Facility check of automatic telephone system
- Check foregoing against specified variation in power supplies

## **D) ACCEPTANCE CONDITIONS**

The tests shall only be deemed to be successful if the following conditions apply:

- i) No breakdown of any part of the system in excess of that detailed in the test schedule and the total allowable outage time is not exceeded.



- ii) No series of errors/faults on a particular item indicating a design weakness.

Should any plant or any portion thereof fail under test to give the required performance, further tests which are considered necessary by the site engineer shall be carried out and cost of the completed tests shall be included in the price of works.

After satisfactory completion of the witnessed tests at the works, plant shall be submitted for approval for dismantling prior to shipping. NO item of plant shall be despatched to site until the inspection agency has given its approval in writing.

#### **E) SYSTEM TESTS ON SITE**

All plant shall be submitted for site tests and inspection as required by the site engineer. During the course of erection, the site engineer shall have full access for inspection of the progress of the work and for checking workmanship and accuracy as may be required.

On completion of the work prior to commissioning, all equipment shall be tested to the satisfaction of the site engineer to demonstrate that it is entirely suitable for commercial operation. In connection with this, the owner will provide only electricity, fuel and water for the purpose of carrying out the tests and such labour and materials and apparatus that may be required shall be supplied.

Commissioning tests shall be carried out in the presence of and to the satisfaction of the site engineer.

All apparatus shall be tested on site conditions in which it will normally work with additional arrangements as required to prove the capacity for working under the worst combination of conditions.

The commissioning tests shall be exhaustive and shall demonstrate that the overall performance of the works satisfied every requirement specified.

The tests to be carried out shall be:

- i) Based on such routine tests as can conveniently be applied on site together with any other test required.
- ii) A system test embracing all the equipment to satisfy the requirements.

#### **F) TEST CERTIFICATES**

Triplicate sets of all principal test records, test certificates and performance curves shall be supplied for all tests carried out in accordance with the provision of this specification. These test certificate records and performance curves shall be supplied for all tests, whether or not they have been witnessed by the site engineer. Information given on such test certificates and curves shall be sufficient to identify the material or equipment to which the certificate refers.

#### **G) REJECTION OF PLANT**

Any item of plant or component which fails to comply with the requirements of this specification in any respect whatsoever at any stage of manufacture, test, erection or on completion at site may be rejected either in whole or part as deemed the contrary.

After adjustment or modification if so directed by the engineer the contractor shall submit the item for further inspection and/or tests.

Plant or components with defects of such nature that the requirements of the specification cannot be met by adjustments or modification shall be replaced by the contractor at his own expense and to the satisfaction of the engineer.

#### **16.13 SWITCHGEAR AND OTHER SUBSTATION EQUIPMENT**

The following list gives the minimum requirements for switchgear and other substation equipment:

##### **WORK TESTS**

##### **1) Complete Switchgear Requirements**

Routine high voltage  
Electrical type tests

##### **2) Circuit Breakers**

###### **Routine Tests**

One circuit breaker of each type ordered shall be fully assembled at the manufacturer's works and subjected to routine tests in accordance with BS 5311 or IEC 56 and shall comprise:

- a) Operation tests
- b) Millivolt drop test
- c) Power frequency voltage test

The remaining circuit breakers of each type shall be either fully assembled at the manufacturer's works and subjected to tests (a) and (c) above or where not assembled at works, separate power frequency voltage tests shall be performed on all major insulation components.

###### **Type Tests**

Making and breaking capacity tests for circuit breakers are to be in accordance with BS 5311 or IEC 56.

##### **3) Bushings**

Routine, sample and type tests to BS 223 or IEC equivalent.

**4) Current and Voltage Transformers**

Routine tests to IEC 185, 186, 186A and 358 requirements or BS 3938 and 3941.

Type tests IEC 185, 186, 186A requirements or BS 3938 and 3941 and including impulse tests.

**5) Capacitor Couplers and Line Traps**

Routine Tests : Ratio and phase angle errors of capacitor divider.

**6) Surge Arrestors**

Routine tests to IEC 99 requirements or BS 2914 Type tests to IEC 99 requirements or BS 2914.

**7) Neutral Earthing Resistors**

Routine leakage and over voltage tests.

**8) Capacitors**

Routine tests to IEC 70 requirements or BS 1650. Type tests to IEC 70 requirements or BS 1650.

**9) Auxiliary Transformers, Motors, Rectifiers, Contractors and Control Gear**

As appropriate IEC requirements or BS and as required by this Specification.

**10) Protective Relaying Equipment**

Routine tests to BS 142 and checking of correct operation of all relays as appropriate.

Routine testing of sets of differential current transformers.

Type tests of each type of protective scheme simulating service conditions as closely as possible, to prove sensitivity, stability and operating times.

**11) Control and Indicating Panels, Instruments, Wiring, Metering Equipment Etc.**

Routine tests to the appropriate IEC or BS requirements and high voltage tests.

**12) Batteries and Chargers**

Material tests as required. Sample tests on cells for repeated discharge/charge/discharge (alkaline only).

**16.14 SITE TESTS**

- 1) Soil resistivity tests and electrode and earthing system tests as specified.
- 2) Routine high voltage tests.

In the case of 132KV equipment other than cables will not be required to provide a high voltage test set. A working voltage test will be made by arrangement with the Employer.

For cables site testing is required in accordance with the appropriate IBC requirement or BS and the Contractor is to provide the necessary test facilities.

- 3) Insulation resistance tests.
- 4) Continuity tests.
- 5) Oil tests.
- 6) Tests to prove correct operation of interlocks, tripping and closing circuits, indications etc.
- 7) Vector group, phasing and synchronising tests.
- 8) Operation of all protective gear circuits by primary and secondary injection and where necessary system fault tests to check sensitivity and stability.
- 9) Protective gear limiting tests as may be necessary.
- 10) Test operation of alarm devices.
- 11) Rotational tests on all motors
- 12) Battery capacity test.

#### **16.15 COMMISSIONING TEST**

Details for the following shall be submitted to the employer for review and approval prior to the start of commissioning activities.

##### **a) Commissioning Procedures**

The draft procedural details shall highlight the method of conducting the site tests as per the requirement under item 16.14. The details shall mainly cover the circuit diagram of test set up wherever applicable and a tabular form to record the test results. Each test record shall have provision to record the serial number and name plate details of the relevant equipment under test. The formats will be reviewed and approved by the Employer.

- b)** A check list shall be prepared listing out the check on Interlocks closing/opening operation, protection tripping etc. for each equipment or system.
- c)** Detailed calculations for arriving at the protective relay settings for incomers and feeder circuits, transformers, protection shall be prepared. The relay settings shall be shown in a tabular form showing the circuit description, type of relay, available setting range and recommended setting.
- d)** Protective relay coordination curves plotted on log scale shall be furnished to the Employer along with the relay recommended settings.

**STANDARD OES-27**  
**132/33KV SUBSTATION**  
**VOLUME - 1**

**SCHEDULE - A**  
**SCHEDULE OF REQUIREMENTS**

**1.0 132KV OUTDOOR SWITCHGEAR**

Equipment for four line bays comprising:

- a) Two (2) galvanised steel structures complete with facilities for terminating the slack spans and earth conductors for incoming and outgoing. Feeder lines, access ladders, earth peak, screens etc.
- b) Four (4) three phase sets of 132KV surge arrestors with connectors and support structures.
- c) Four (4) sets of 132KV cable sealing ends with connectors.
- d) Four (4) sets of post insulators, if required, with connectors and support structures.
- e) Two (2) sets of lightning masts or earth screens as required.
- f) Four (4) sets of connections, connectors, clamps, jumpers, earthing etc. to complete.
- g) Two (2) three phase 132KV sets of portable earthing equipment.

**2.0 132KV INDOOR SWITCHGEAR**

- 2.1** Seven (7) bays 132KV indoor switchgear, the duplicate busbar switchgear, the duplicate busbars designated as Busbar I and Busbar II and the 7 bays classified as follows:

BAY NO.	DESIGNATION	BAY TYPE	DUTY
1	Feeder	A	132KV Feeder TX.
2	Feeder	B	132KV Feeder
3	125MVA Tx. No. 1	C	125MVA Tx.
4	Bus Coupler	D	Bus Coupler
5	125MVA Transformer	C	125MVA Tx.
6	Feeder	B	132KV Feeder
7	Feeder	A	132KV Feeder Tx.

The equipment requirement are as follows:-

Bay type	Quantity	Description
A	2	<p>a)</p> <p>2000 A Busbars (site ratings)</p> <p>1-3 Pole circuit breaker 1250 A</p> <p>2-3 Pole busbar selection isolators 1250 A</p> <p>3-3 Pole hand operated earthing switches</p> <p>1-3 Pole disconnecting switch 1250A</p> <p>1-3 Pole high speed earthing switch</p> <p>1-3 Pole termination unit for 3 single core XLPE cables</p> <p>- Auxiliary switches to include these for future supervisory and indications spares.</p>
		<p>b)</p> <p>Current transformers of required class and accuracy to meet IEC and B.S.:</p> <p>3- Distance protection C.T's ratio 1600/800/1 Class X</p> <p>3- Overcurrent and earth fault C.T's ratio 1600/800/1 Class 5p</p> <p>3- Bus zone, differential C.T's of ratio 2000/1 Class X</p> <p>3- Bus zone, differential check CT's of ratio 2000/1 Class X</p>
		<p>c)</p> <p>3- Single phase voltage transformers.</p> $\frac{132000}{\sqrt{3}} \bigg/ \frac{110}{\sqrt{3}} \bigg/ \frac{110}{3} \text{ V.100 VA}$ <p>for instruments, protection, synchronizing and metering.</p>
		<p>d)</p> <p>Local control cubicle with:</p> <p>1- Ammeter and selector switch or 3 Ammeters</p> <p>1- Voltmeters and selector switches (6 positions)</p> <p>1- Local/Remote selector switch</p> <p>- Annunciator block</p> <p>- Set of mimic and control dia grams.</p>
		<p>e)</p> <p>Secondary terminals, terminal blocks, wiring, fuses/MCB's links, labels etc. to complete</p>
Bay Type	Quantity	Description
B	2	<p>a)</p> <p>2000A busbars (site rating)</p> <p>1-3 Pole circuit breaker 1250A</p> <p>2-3 Pole busbar selector isolator 1250 A</p> <p>3-3 Pole hand operated earthing switches</p> <p>1-3 Pole disconnecting switch 1250A</p> <p>1-3 Pole high speed earthing switch</p> <p>1-3 Pole termination unit for 3 single core XLPE cables</p> <p>- Auxiliary switches to include those for future supervisory indication and spare.</p>
		<p>b)</p> <p>Current transformers of required class and accuracy to meet IEC and B.S.:</p> <p>3- Distance protection C.T's ratio 1600/800/1 Class X</p>

- 3- Directional overcurrent and earth fault C.T's ratio 1600/800/1 Class 5P
- 3- Bus zone differential C.T's of ratio 2000/1 Class X
- 3 Bus zone check C.T's of ratio 2000/1 Class X.
- c) 3- Single phase voltage Tx.

$$\frac{132000}{\sqrt{3}} \div \frac{110}{\sqrt{3}} \quad V \text{ 100 VA suitable for instruments, protection}$$

synchronizing and metering.

- d) Local control cubicle with:
  - I- Ammeter and selector switch or 3 Ammeters
  - I- Voltmeter and selector switch (6 positions)
  - I- Local/Remote selector switch
  - I- Annunciator block
  - Set of receive and control diagram
- e) Secondary terminals, terminal blocks, wiring, fuses/MCB's links, labels etc. to complete.

C 2

- a) As type "A" bay – item (a)
- b) Current transformers of required class and accuracy to meet IEC and B.S.:
  - i) 3- Restricted earth fault and transformer differential C.T's ratio 800/1 Class X
  - ii) 3- Overcurrent and earth fault and metering CT's ratio 800/1 Class 5P
  - iii) 3- Bus zone differential C.T's of ratio 2000/1 Class X
  - iv) 3- Bus zone check C.T's of ratio 2000/1 Class X.
  - c) Local control cubicle – As type 'A' bay : Item (d)
  - d) As type 'A' bay : Item (e)
  - a) 2000A busbars (site rating)
    - i-3 Pole circuit breaker 2000A (site rating)
    - 2-3 Pole load-break switch sectionalizers on busbar I
    - 2-3 Pole busbar selection isolators 2000A (site rating)
    - 2-3 Pole high speed earthing switches (for earthing for busbar)

D

- b) Current transformers of required Class and accuracy to meet IEC and B.S..
  - i) 2 x3 bus zone differential C.T's of ratio 2000/1 Class X
  - ii) 3 overcurrent and earth fault and metering C.T's, of ratio 2000/1 Class 5P.
- c) 6 Single phase voltage transformers  $\frac{132000}{\sqrt{3}} \div \frac{110}{\sqrt{3}} \quad V$  suitable for instruments, synchronizing and metering
- d) Local control cubicle with:
  - I - Ammeter and selector switch or 3 ammeters
  - 2 - Voltmeters and 2 selector switches (each with 6 positions)
  - Local/Remote selector switch
  - Annunciator block
  - Set of mimic and control diagrams
  - Set of materials such as panel, wiring etc.
- e) Secondary terminals, terminal blocks, wiring, fuses/MCB's links, labels etc. to complete.

## General

### 4 Future Bays

Two bays at each end of the 132KV switchgear : building and related works only for installing extension bays in the future.

## 2.2 Control Board for 132KV Switchgear

Circuit Type	Quantity	Description
A	2	Control equipment for 132KV feeders comprising:  Section of mimic diagram including discrepancy type. Control switches for circuit breaker, isolators, high speed earthing switch and discrepancy type position indication for hand operated earthing switches
B	2	
C	2	Control equipment for 125MVA transformers comprising:  Section of mimic diagram including discrepancy type control switches for circuit breaker isolators and high speed earthing switch and discrepancy type position indicator for hand operated earthing switch
D	1	Control equipment for Bus coupler comprising:  Section of mimic diagram including discrepancy type control switches for circuit breaker, load break sectionalisers, isolators and high speed earthing switches.



- 1 - “Trip circuit healthy” white indication lamp
- 1 - “Fault trip” amber indication lamp
- 1 - Remote/Supervisory selector switch
- 1 - Ammeter scaled 0-2000 A
- 2 - Busbar voltmeters scaled 0-150 K V with selector switch
  - Wiring, cables glands, fuses, links, terminal blocks, terminals, labels etc. to complete
- 1 - Push button for “dead busbars” closing
- 1 - Socket for synchronising equipment
- 1 - Synchronising selector switch
- 1 - Hinged panel mounted on the bus coupler control panel complete with synchroscope, synchronizing lamps, voltmeters, switches, wiring, labels etc.

### 2.3 Relay panels for 132 KV Switchgear

Circuit	Quantity	Description
A	2	<p>Relay panel for 132KV feeder transformer equipped with:-</p> <ul style="list-style-type: none"> <li>1 - Overcurrent and earth fault relay with three IDMT overcurrent elements and one IDMT earth fault element</li> </ul> <p>Relay settings ranges:-</p> <ul style="list-style-type: none"> <li>- Overcurrent IDMT 50 - 200%</li> <li>- Earth Fault IDMT 10 - 40%</li> </ul>
B	2	<p>Relay panel for 132KV feeder equipped with:-</p> <ul style="list-style-type: none"> <li>1 - Distance protection relay</li> <li>1 - Tripping relay</li> <li>1 - Trip circuit supervision relay</li> </ul> <p>Wiring, fuses, links, terminal blocks, cable glands, CT test blocks with shorting/isolating links, labels etc.</p>
C	2	<p>Relay panel for 125MVA transformer feeder equipped with:-</p> <ul style="list-style-type: none"> <li>1 - Directional overcurrent and earth fault relay with three overcurrent IDMT elements and one IDMT earth fault element</li> </ul> <p>Relay setting ranges:-</p> <ul style="list-style-type: none"> <li>- Overcurrent IDMT 50 - 200%</li> <li>- Earth Fault IDMT 10 - 40%</li> </ul> <p>1 - Distance protection relay</p> <p>1 - Tripping relay</p> <p>1 - Trip circuit supervision relay Wiring, fuses, links, terminal blocks, cable glands, CT test blocks with shorting/isolating links, labels etc. to complete</p>

- 1 - Overcurrent and earth fault relay with three IDMT over-current elements and one IDMT earth fault relay

Relay settings ranges:-

- Overcurrent IDMT 50 - 200%
- Earth Faults IDMT 10 - 40%

1 - Restricted earth fault relay (132KV)

1 - Tripping relay

1 - Neutral earth fault relay (132KV)

1 - Trip circuit supervision relay Wiring, fuses, links, terminal blocks, terminals, CT test blocks with shorting/isolating links, labels etc. to complete.

D 1 Relay panel for bus coupler equipment with:

1 - Overcurrent and earth fault relay with three IDMT overcurrent elements and one earth fault relay

Relay setting ranges:-

- Overcurrent IDMT 50 - 200%
- Earth Fault IDMT 10 - 40%

1 - Busbar and breaker back-up protection including facilities for modification and extension as well as for monitoring and testing and auxiliary equipment  
1 - Trip circuit supervision relay Wiring, fuses, links, terminal blocks, cable glands, C.T. test blocks with shorting/isolating links, labels etc.

### 3.1 Twenty four (24) panel 33KV Indoor Single Busbar Switchgear in two separate switchboards designated No. 1 and No. 2 and classified as below:

Panel No.	Designation	Panel Type	Duty
A) 33KV Switchboard No. 1			
1	Feeder	B/C	O/H line/UG cable feeder
2	Feeder	B/C	O/H line/UG cable feeder
3	Feeder	B/C	O/H line/UG cable feeder
4	125MVA Tx. 1	A	125MVA Transformer
5	20MVA Tx. 1 33/11KV	D	33/11KV Transformer
6	Feeder	B/V	O/H line feeder/UG Cable
7	Feeder	B/C	O/H line UG/Cable feeder
8	Feeder	B/C	O/H line/UG cable feeder
9	125MVA Tx. 2	A	125MVA Transformer
10	Feeder	B/C	O/H line/UG cable feeder
11	Feeder	B/C	O/H line/UG cable feeder
12	Feeder	B/C	O/H line/UG cable feeder
Busbar V.T.		D	

**B) 33K V Switchboard No.2**

13	Feeder	B/C	O/H line/UG cable feeder
14	Feeder	B/C	O/H line/UG cable feeder
15	Feeder	B/C	O/H line/UG cable feeder
16	125MVA Tx. 1	A	125MVA Transformer
17	20MVA Tx. 1	D	33/11KV Transformer
18	Feeder	B/C	O/H line feeder/UG cable
19	Feeder	B/C	O/H line/UG cable feeder
20	Feeder	B/C	O/H line/UG cable feeder
21	125MVA Transformer	A	125MVA Transformer
22	Feeder	B/C	O/H line/UG cable feeder
23	Feeder	B/C	O/H line/UG cable feeder
24	Feeder	B/C	O/H line/UG cable feeder

Busbar V.T.

The requirements are as follows:

Panel Type	Quantity	Description
A	4	<p>a)</p> <p>1600A busbar chamber and feeder termination and current transformer chamber and 1600A circuit breaker on truck with auxiliary switches shunt trip mechanism, closing mechanism. Busbars shall be rated 1600A under site conditions. Local control switch with pistol grip handle.</p> <ul style="list-style-type: none"> <li>- Local/Remote selector switch</li> <li>- Circuit breaker “closed” indication</li> <li>- Circuit breaker “Open” indication</li> <li>- Cable box for associated copper conductor XLPE cables</li> <li>- Auxiliary switches to include those for future supervisory indication</li> <li>- Terminals, terminal blocks, wiring, fuses, links, labels etc. to complete.</li> </ul> <p>b)</p> <p>Current transformers of required class and accuracy to meet IEC and B.S..</p> <ul style="list-style-type: none"> <li>i) 2 metering commercial grade CT's ratio 1600/1 Class 0.5</li> <li>ii) 3 restricted earth fault and transformer differential CT's ratio 2400/1 Class X or equivalent</li> <li>iii) 3 overcurrent and earth fault CT's ratio 3200/1 Class 5P</li> <li>iv) 3 bus zone, differential CT's of ratio 1600/1 Class X</li> <li>v) 3 bus zone differential CT's of ratio 1600/1 Class X</li> </ul> <p>33KV/110V 3 phase voltage transformer suitable for instruments, automatic voltage regulatory, protection, synchronising and metering.</p> <p>B As required a) Feeder panels each equipped as for panel A (a), except for 630 A circuit breaker and cable box suitable for 3 core 300 sq.mm copper XLPE steel wire armoured cables</p>

- b) Current transformer:-
  - i) 3 overcurrent and earth fault and metering CT's ratio 400/1
  - ii) 3 CT's suitable for distance protection ratio 400/1 for overhead line feeders
  - iii) 3 bus zone differential CT's ratio 1600/1
  - iv) 3 bus zone check CT's ratio 1600/1

C As required a) Feeder panels each equipped as for panel type A (a) except for 630A breaker and cable box suitable for 3 core 300 sqmm copper XLPE steel wire armoured cables

- b) Current transformers:
  - 3 overcurrent and earth fault and metering CT's ratio
  - 3 bus zone differential CT's of ratio 1600/1
  - 3 bus zone check CT's of ratio 1600/1
  - 3 400/1 Class X CT's for Pilot wire protection

2 Busbar 33KV/110 volt voltage transformers for instrumentation and feeder distance protection

## General

4 – Future Panels (2 at the end of each switchboard building and related works only for future use.

### 3.2 Control Board for 33KV Switchgear

Circuit Type	Quantity	Description
A	4	Control equipment for 125MVA transformer type A comprising:  Section of mimic diagram, circuit breaker control discrepancy type switch, discrepancy type position indication for 33KV isolators and 33KV neutral isolators.  1 - "Springs charged" blue indication lamp 1 - "Trip circuit healthy" white indication lamp 1 - "Fault trip" amber indication lamp 1 - Remote/Supervisory selector switch 1 - Ammeter selector switch 1 - Voltmeter scaled 0-40 KV with fuses 1 - Push button for "dead busbars" closing 1 - Socket for synchronising equipment 1 - Synchronising selector switch - Wiring, cable glands, fuses, links, terminal blocks, terminals, labels etc. to complete.

B/C/D

Control equipment for Feeder type B comprising:

Section of mimic diagram including circuit breaker control discrepancy type switch, discrepancy type position indication for 33KV isolators

- 1 - "Spring charged" blue indication lamp, if applicable
- 1 - "Trip circuit healthy" white indication lamp
- 1 - "Fault trip" amber indication lamp
- 1 - Remote/Supervisory selector switch
- 1 - Ammeter selector switch
- 1 - Ammeter scaled 0-300A and 0-600A on reverse side
  - Wiring, cable glands, fuses, links, terminal blocks, terminals, labels etc. to complete.
- 1 - Commercial grade kwh meter including maximum demand indication.

General                    2                    Busbar voltmeters scaled 0-40KV with fuses.

1                    Hinged panel mounted in a suitable location on the control board complete with synchroscope, synchronising lamps, voltmeters, switches, wiring, labels etc.

### 3.3 Relay Panels for 33KV Switchgear

Circuit Type	Quantity	Description
A	2	Relay panel for each 125MVA transformer equipped with:- <ul style="list-style-type: none"><li>2 - Overcurrent and earth fault relays with three IDMT overcurrent elements and one IDMT earth fault relay.</li></ul>
		Relay setting ranges: <ul style="list-style-type: none"><li>- Overcurrent IDMT 50 - 200%</li><li>- Earth fault IDMT 10 - 40%</li></ul>
		<ul style="list-style-type: none"><li>1 - Transformer differential relay</li><li>1 - Restricted earth fault relay (33 KV)</li><li>1 - Tripping relay</li><li>1 - Buchholz auxiliary flag relay</li><li>1 - W.T. auxiliary flag relay</li><li>1 - 2 Stage standby earth fault relay (33KV)</li><li>1 - Trip circuit supervision relay<ul style="list-style-type: none"><li>- Wiring, fuses, links, terminal blocks, terminals, C.T. test blocks with shorting/isolating links, labels etc. to complete.</li></ul></li><li>1 - HV interposing CT for transformer differential protection</li><li>2 - LV interposing CTs for transformer differential protection</li></ul>

**B** As required Relay panel for feeder type B equipped with:  
1 - Overcurrent and earth fault relay with three IDMT overcurrent elements, and one IDMT earth fault element

Relay setting ranges:

- Overcurrent IDMT 50- 200%
- IDMT earth fault 10 - 40%

1 - Auto reclose relay

1 - Distance Protection Relay

1 - Tripping relay

1 - Trip circuit supervision relay

- Wiring, fuses, links, terminal blocks, cable glands, CT test blocks with shorting/isolating links, labels etc.

**C** As required Relay panel for feeder type C equipped with:

1 - Overcurrent and earth fault relay with three overcurrent IDMT elements, and IDMT earth fault element

Relay setting ranges:

- Overcurrent IDMT 50 - 200%
- IDMT earth fault 10 - 40%

Pilot wire protection relay to match Solkor RF at the other end insulated to 15KV

complete with:

- Surge proof intertripping relay (send)
- Surge proof intertripping relay (receive)
- Pilot wire supervision equipment

**General** 1 Busbar protection panel for 33KV switchgear protection including relays, switches, indicating lamps, CT test/isolating links, wiring, terminal blocks, terminals, fuses, links, labels etc.

### 3.4 Tap Changer Control Panels for 125MVA Transformers

2 - Tap changer control panels including automatic voltage regulator, control "raise" and "lower" push buttons, "tap change in progress" lamps, "tap change in progress" buzzer, tap position indicator, voltmeter, and all necessary equipment for the provision of a master-follower tap change control scheme between the 125MVA transformers.

### 3.5 Metering for 125MVA Transformer 33KV Circuits

1 - Metering panel complete with all necessary terminals, terminal blocks, glands, connectors, wiring, trunking, CT test/isolating links etc. for incoming 33KV metering circuits for 125MVA transformers including:

- i) 2 - Kwh meters including maximum demand indication.
- ii) 2 - KVArh meters including maximum demand indication.
- iii) 1 - Set of summation equipment including printometer as specified in Section 4.6.
- iv) 1 - 110Volt DC time clock for measuring half hour intervals.

### 3.6 Alarm Panel

1 - Alarm panel, including facias for general substation alarms, transformer alarms etc. Flasher relay, bell, buzzer, switches, wiring, terminals, fuses, links and all necessary equipment to provide alarm system specified in Section 4.6.

The following alarms shall be included on the facias:

#### Transformer No. 1

Buchholz alarm  
 Buchholz trip  
 Winding temperature alarm  
 Winding temperature trip  
 Cooler supply fail  
 Tap changer out of step  
 Main protection operated  
 Back-up protection operated  
 Tap-changer supply fail  
 V.T. fail

#### Transformer No. 2

As for Transformer No. 1

General:

Trip supply fail  
 Battery fault (110 volt)  
 132KV circuit breaker tripped  
 33KV circuit breaker tripped  
 Fire alarm  
 132KV busbar protection operated  
 33KV busbar protection operated  
 LVCA fail (essential services)  
 Battery fault (48 volt)  
 132KV distance protection operated  
 33KV distance protection operated

### 4.0 TRANSFORMERS

Transformers shall comply with the requirements of Section 5.0.

Description	(a) Power Tx. 125 MVA	(b) Earthing Tx. 315 KVA
Quantity	2	2
Number of Phases	3	3
Normal ratio of Transformation KV	132/33	33/0.415
Max. continuous rating (See Cl. 4.1.4)	125MVA	315KVA
Vector Group Reference	Yd 5	Zn Yn11
Type of cooling (See Cl. 4.1.3)	ONAN/ONAF	ONAN
Range of Tx. taps %	- 15% + 5%	- + 5%

Size of transformation ratio steps	1.1%	2.5%
Terminal arrangements:		
- 132 KVx	Cable Box	---
- 132 KV Neutral	Bushing	---
- 33KVx	Cable Box	Cable Box
- 33KV Neutral	---	Bushing
- 415 Volts	---	Cable Box
Impedance voltage at 75 Deg. C and CMR at normal rating between HV and LV windings approx.	17 - 20%	
Supply voltage for control circuits – Vdc	110	---
AVR ref. voltage – Vdc	110	---
Zero sequence impedance (earthing transformer)		5 Ohm/phase
<b>Description</b>		
System highest voltages	KV	145/36
Min. withstand voltages full wave impulse	KV	650/170
Induced over voltage KV		230/70
Power frequency withstand of neutral	KV	40/-
Type of transformer base required	skid or flat	skid or flat
Whether anti-vibration pads required	Yes, if flat base	Yes, if flat base
Rating of interconnected star winding on 30 sec. basis neutral Amps	----	1500
132KV Neutral current Tx. for neutral fault (ratio 600/1 accuracy Class 5P) and restricted earth fault protection (ratio 600/1 Class X) to be incorporated in the 132KV neutral bushing	One set on each Tx.	
<b>5.0 415VOLT SWITCHBOARDS, LIGHTING AND SMALL POWER</b>		
5.1 Main Distribution Board for 415/240 volt substation services. The board shall include manually operated switch fuse units for incoming circuits from 33/0.415KV transformers, bus section isolator interlocked with incoming switch fuse units, switch fuse units for outgoing supplies from each bus section to the essential service board, miniature circuit breakers or fuses for lighting and small power circuits, ammeter and associated current transformers on each incoming circuit, voltmeter with voltage selection switch on each section of busbar, labels etc.		
5.2 Essential Services sub-distribution board. The board shall include an automatic changeover contactor, incoming supply isolator, no volt relay, ammeter and associated current transformer, voltmeter, miniature circuit breakers or fuses for essential services circuits, labels etc.		
5.3 Complete set of lighting and small power equipment for the substation including outside lighting, emergency lighting, socket outlets, TPN outlet suitable for oil treatment plant to be supplied under Schedule E, tools and appliances, wiring etc. to comply with Section 4.10 of the specification.		
5.4 Air conditioning for control/relay room and power line carrier rooms. 132KV and 33KV switchgear room.		
5.5 Ventilation for toilet, battery room LVAC room to comply.		
<b>6.0 BATTERIES, CHARGERS AND D.C. SWITCHBOARDS</b>		
6.1 Set of two 110 volt 100% duty nickel cadmium batteries, control and charging equipment and one DC distribution board.		



Control and charging equipment shall include an automatic float charger and boost charger. Each charger shall be complete with a switch fuse for incoming AC supplies and either an off load isolator or disconnecting links for the DC output, incoming AC indicating lamp, input voltmeter with low voltage alarm contact, output ammeter, voltage failure detecting device etc.

- 6.2** DC distribution board shall include double pole switches and fuses for outgoing DC circuits, double pole isolators for incoming DC supplies, voltmeter and centre zero ammeter on each incoming battery circuit, earth fault detecting relays, battery low voltage alarm device, double pole changeover contactors etc.

## **7.0 EARTHING**

Complete earthing system as required in the specification including connections to all equipment supplied under this contract and to any existing earthing at the substation.

## **9.0 FIRE FIGHTING EQUIPMENT**

- 9.1** 2 - Wall mounted 10KG portable dry powder extinguishers each provided with 4 re-chargers for control/relay room.
- 9.2** 2 - Wheeled trolley type 50KG dry powder extinguishers provided with 4 re-chargers.
- 9.3** 1 X 10KG dry powder wall mounting extinguishers.
- 9.4** Water sprinklers for transformer fire protection.

## **10.0 CABLES AND TERMINATIONS**

The following cables and terminations shall be included and installed as necessary to complete the works in accordance with Section 4.11 of the specification.

<b>ITEM</b>	<b>DESCRIPTION</b>
<b>10.1</b>	132KV XLPE cables between 132KV Indoor Switchgear and 132KV overhead line circuits shall be single core 2000 sq.mm XLPE PVC/Al. armoured/PVC.
<b>10.2</b>	132KV XLPE cables between 132KV Indoor Switchgear and 125MVA Transformers Nos. 1 and 2 cables shall be single core 630 sq.mm XLPE/PVC/Al. armoured/PVC
<b>10.3</b>	33KV XLPE cable between 125MVA Transformer Nos. 1 and 2 and 33KV Switchboard Nos. 1 and 2. Cables shall be 2 x single core per phase 630 sq.mm XLPE insulated.
<b>10.4</b>	33KV Cables between 125MVA Transformer Nos. 1 and 2 the appropriate earthing transformer. Cables shall be 185sq.mm single core copper conductor XLPE.
<b>10.5</b>	1000 volt cables between auxiliary earthing transformers and main distribution board.  Cables shall be 300 sq. mm copper conductor, XLPE insulated and sheathed armoured 4 core or equivalent single core cables.

10.6 1000 Volt cables between main distribution board and sub-board for essential services. Cables shall be 70sq.mm copper conductor XLPE insulated and PVC sheathed non-armoured 4 core cable.

10.7 Multi core and telephone cables to complete control, alarm, indication and tele-communication circuits etc.

## **11.00 POWER LINE CARRIER EQUIPMENT**

<b>ITEM</b>	<b>DESCRIPTION</b>
<b>11.1 Power Line Carrier Equipment (sending end substation – New S.S)</b>	
<b>A Outdoor Equipment</b>	
	Inter circuit phase/phase coupling to Ghubrah Power Station No. 1 and No. 2 132KV lines.
	2 - 1250 Amp line trap complete with all necessary fittings, clamps etc. for mounting on the 132KV coupling capacitor.
	2 - 132KV coupling capacitor complete with all fittings for mounting the line traps on topo.
	2 - Galvanised steel frame work mounted on terminal tower cross arms for supporting the coupling capacitors.
	2 - High frequency coupling units complete with coupling filters and protection circuits with all necessary mounting details.
	High frequency cable to connect to the HF coupling units with the associated PLC terminals.
<b>B Indoor Equipment</b>	
	2 - Carrier terminal equipment comprising signal generators, modulators, line amplifiers, filters, speech circuits, telephone signaling (dialling) and bandwidth for teleprotection as necessary and future telecontrol from supervisory control centre.
<b>11.2 Power Line Carrier Equipment New S.S – S.S at the end of the feeder</b>	
<b>A Outdoor Equipment</b>	
	Inter-circuit phase/phase coupling to outgoing feeder and No. 2 132KV lines.
	2 - 800 Amp line trap as item 11.1A.
	2 - 132KV coupling capacitors as item 11.1 A.
	2 - Galvanised steel framework as item 11.1 A.
	2 - HF coupling units as item 11.1 A.
	HF cable as item 11.1 A.
<b>B Indoor Equipment</b>	
	2 – Carrier terminal equipment as item 11.1 B to S.S. at the other end of outgoing feeder.

### **11.3 Automatic Telephone Equipment**

1 - Private automatic telephone exchange (PAX) equipped initially for 20 local extensions, 4 links and 6 trunk terminating units sending end substation and to the S.S. at the end of outgoing feeder.

8 - Telephone instruments

1 - Main distribution frame

### **11.4 Telecontrol Equipment**

1 - Set of VF transmit equipment to code and transmit found alarm signals to supervisory control centre (one urgent, one nonurgent and spare)

### **11.5 Teleprotection Equipment**

2 - Sets of duplex “direct tripping” high speed teleprotection equipment to directly trip the 132KV circuit breakers at sending end from the Distance Protection at new substation and to trip the 132KV circuit breakers at new S.S. from the protection at sending end station.

2 - Set of duplex “direct tripping” high speed teleprotection equipment to directly trip the 132KV circuit breaker at new substation in the event of transformer fault at other end of the outgoing feeder and to trip the 33KV circuit breakers at substation on the end of the outgoing feeder from the distance protection of new substation.

### **11.6 Power Supplies**

2 - Set Battery of sufficient capacity for the equipment requirements including future circuits together with battery stand.

2 - Set of battery charger equipment of sufficient rating for the above battery together with the necessary distribution panel.

### **CRANE FOR 132KV SWITCH-HOUSE**

Gantry Crane hand operated from the operating floor. The crane should be capable to lift the heaviest part in its operating area (minimum 5 tons). The crane shall be complete, including girder(s), crab, long travel runway rails with supports (civil works included), base plates, buffers and all fastening material, hoisting machinery with brakes, all lubricating devices, ropes, shelves, hooks and protecting devices. A complete set of lifting and rigging ropes and chains for each crane to handle all equipment the crane is designed for, shall be provided, also a storage rack for all ropes and/or chains suitably located.

**SCHEDULE - "B"**  
**TECHNICAL PARTICULARS AND GUARANTEES**

**1.0 132KV OUTDOOR EQUIPMENT**

**ITEM**

**132KV**

**a) Surge Arrestors**

Manufacturer	
Type of Arrestor	
Class and Duty	
Rated Voltage	
Rated Current	
50Hz sparkover voltage	RMS KV KA
100 percent impulse sparkover on 1.2/50 micro second wave	RMS KV Peak KV
100 percent impulse sparkover on AIEE steep fronted wave	
Discharge residual voltage based on 10/20 wave at:	
A) 5KA	Peak KV
B) 10KA	Peak KV
C) 20KA	Peak KV

Current discharge capacity:

A) 5/10 second wave	Peak KV
B) 2000 second rectangular wave	Peak KV

Minimum rescal voltage	RMS KV
Total height of arrestor	mm
Total weight of arrestor	kg
Type of surge counter	

**b) Cable Sealing End - Bushing Insulators**

Maker	
Insulator material	
Maker's type reference and rated voltage	mm approx.
Pitch circle diameter and drilling of flange	mm
Length of insulator (overall)	kg
Weight of insulator	pF
Electrstatic capacity of complete bushing	
50Hz dry voltage withstand	Kv
Lightning impulse flashover voltage (1/2/50 Wave)	Kv
Full wave lightning impulse voltage withstand	Kv
50Hz wet withstand voltage without arcing horns	Kv
Total creepage distance of shedding (see Cl. 4.7.1)	mm
Protected creepage distance of shedding	mm

## 2.0 132KV INDOOR SWITCHGEAR

ITEM	
Manufacturer	
Type Number	
Class SF6	
Number of phases	
Rated design voltage	KV
Impulse withstand on 1.2/50 microsec wave	
– Phase to earth	KV
– Phase to phase (for three phase encapsulation)	KV
Frequency	Hz
Normal busbar current rating (site)	A
Overload rating (emergency) % of normal	
Duration in any 24 hour period	Hrs
	Ambient Temp. °C

### Voltage Transformers

Manufacturer	
Type	
Rated burden per phase	VA
Class	
Maximum ratio error with rated burden and 5% normal primary voltage	%
Maximum phase angle error with rated burden and 5% normal primary voltage	Deg.
Total weight of 3 phase unit	Kg
Total weight of 1 phase unit	Kg

### Busbars

Maximum temperature rise at rated busbar current (site)	°C
Material used for busbar	
Cross section of busbar	sq.mm
Insulators material and type	
Partial discharge test voltage on insulators	KV
Single phase/Three phase encapsulation	
Encapsulation material	
Diameter of encapsulation tubing	mm
Rate pressure of SF6	
Maximum admissible pressure of SF6	Bar
Minimum permissible pressure of SF6	Bar

### Type Tests

Short time withstand current of switchgear

A) One Second	RMS KA
B) Three Second	RMS KA

Breaking capacity	
A) Symmetrical	RMS kA
B) Asymmetrical	RMS kA

Rated short circuit making current	Peak kA
Rated cable charging breaking current	A
Rated capacitor breaking current	A
Rated inductive breaking current	A
Rated line charging breaking current	A

### Operating Particulars

Opening time	ms
A) Without current	ms
B) At 100% of rated breaking current	
Max. arc duration of any duty cycle	ms
Duty cycle on which max. arc duration occurs	%
Making time	ms
Minimum time from arc extinction to contact remake when adapted for auto reclosing	ms
Time of arc duration	ms
Time from closing of control switch to completion of closing stroke with making current	ms

### Constructional Features

Circuit breaker:	
Single phase/three phase encapsulation	
Method of closing: Type and details of operating mechanism	
Method of tripping	
Operating mechanism motor voltage	Vdc
Operating mechanism motor current	A
Closing release coil current	A
Closing release coil voltage	A
Trip coil current	A
Trip coil voltage	Vdc
Is the circuit breaker trip free?	

- Details of the diversion of gas tight compartments of each switchgear bay
- Fault arc withstand duration for each gas compartment ms
- Details of rupture diagrams fitted on each gas compartment
- Details of static filters fitted on each gas compartment

**Dimensions etc.**

Weight of ricruit breaker unit complete	Kg
Weight of whole switchgear bay complete with switches operating mechanism and all fittings as in service	Kg
Maximum shock load imposed on floor or foundations when openign under fault conditions (state whether tension or compression)	Kg
Maximum pressure rise in circuit breaker due to the making or breaking of rated current	N/m2
Routine pressure test on circuit breaker containers	N/m2
Pressure type test on circuit breaker containers	N/m2

**SF6 Gas Losses**

Percentage of gas loss per year for each switchgear bay	%
Overall dimensions of each switchgear bay (complete equipment)	33KV

A) Height	mm
B) Length	mm
C) Width	mm

**Isolator**

Type	
Rated current	A
Rating of drive motor – Voltage	V
– Current	A

**Load Break Switch**

Type	
Rated current	A
Load break capacity	A
Rating of drive motor – Voltage	V
– Current	A

**High Speed Earthing Switch**

type	
Rated current	A
Fault making capacity	KA
Rating of drive motor – voltage	
– current	

**Hand Operated Earthing Switch**

Type	
Rated	

### 3.0 KV INDOOR SWITCHGEAR

Manufacturer	
Type Number	
Class (i.e. SF6/Vacuum)	
Number of phases	KV
Rated Design Voltage	
Impulse withstand on 1.2/50 microsec wave	KV
Frequency	KV
Normal busbar current rating (site)	Hz
Overload rating (emergency) % of normal	A
Duration in any 24 hour period hours Ambient Temp. °C	
<b>Voltage Transformers</b>	
Manufacturer	
Type	VA
Rated burden per phase	
Class	
Maximum ratio error with rated burden and 5% normal primary voltage	%
Maximum phase angle error with rated burden and 5% normal primary voltage	Deg.
Total weight of 3 phase unit	Kg
Total weight of 1 phase unit	Kg
<b>Busbars</b>	
Maximum temperature rise at rated busbar current (site)	°C
Material used for busbar	
Cross section of busbar	
Insulation material	
<b>Type Tests</b>	
Short time withstand current of switchgear:	
A) One Second	RMS KA
B) Three Second	RMS KA
Breaking capacity:	
A) Symmetrical	RMS KA
B) Asymmetrical	RMS KA
Rated short circuit making current	Peak KA
Rated cable charging current	A
Rated capacitor breaking current	A
Rated inductive breaking current	A
Rated line charging current	A
<b>Operating Particulars</b>	
Opening time:	
A) Without current	ms
B) At 100% of rated breaking current	ms



Maximum arc duration of any duty cycle	ms
Duty cycle on which maximum arc duration occurs	%
Making time	ms
Minimum time from arc extinction to contact remake when adapted for auto reclosing	ms
Time of arc duration	ms
Time from closing of control switch to completion of closing stroke with making current	ms

### Constructional Features

Method of closing	Vdc
Method of tripping	A
Rated voltage for spring winding motor for closing	A
Spring winding motor current	A
Closing release coil current	Vdc
Closing release coil voltage	A
Trip coil current	Vdc
Trip coil voltage	
Is the circuit breaker trip free?	
Type of arcing contacts or arc control device	
Type of main contact	
Material of contact surfaces	
Number of breaks per phase	
Length of each break	
Length of stroke	
Dimensions etc.	

Weight of circuit breaker unit complete

Kg

Weight of whole circuit breaker equipment and all fittings as in service

Kg

Maximum shock load imposed on floor or foundations when opening under fault conditions (state whether tension or compression)

Kg

Maximum pressure rise in circuit breaker due to making or breaking or rated current

N/m<sup>2</sup>

Routine pressure test on circuit breaker containers

N/m<sup>2</sup>

Pressure type test on circuit breaker containers

N/m<sup>2</sup>

Minimum clearances in air:

A) Between phases

mm

B) Phase to earth

mm

C) Across circuit breaker poles

mm

Minimum clearances in oil:

A) Between phases

mm

B) Phase to earth

mm

C) Between live parts of one phase

mm

Material of container

Material of moving contact tension rod

W

Loading of heaters for circuit breakers

Details of floor plates or rails – if provided

Overall dimensions of each circuit breaker unit: 33KV

A) Height

mm

B) Length

mm

C) Width

mm

#### 4.0 TRANSFORMERS

##### POWER TRANSFORMERS

Description		Item	125MVA Tx. 132/33KV	Earthing Tx. 33/0.415KV (315KVA)
Type of cooling				
On-load voltage control equipment				
A) Type				
B) HV or LV winding				
C) Range on-load	%			
D) Power frequency with stand test voltage IEC 214:1976 between first and last contacts of the selector switch	KV			
Between any two adjacent contacts of the selector	KV			
Between open diverter switch contacts	KV			
E) Type test certificate reference	%			
Size of tapping step	MVA			
Approx. ONAN rating of forced cooled Tx.				
Hot spot temperature at CMR under service conditions stated in schedule	°C			
Max. top oil temperature (average daily ambient air temperature 30 Dec.C)	°C			
A) C.M.R.	°C			
B) ON rating	°C			
Max. flux density in iron at normal voltage and frequency and at normal ratio				
A) Cores	Tesla			
B) Yokes	Tesla			
Description				
	Item	125MVA Tx. 132/33KV	Earthing Tx. 33/0.415KV (315KVA)	
Magnetizing current (approx) no-load losses (excluding cooling plant losses) at rated voltage ratio and frequency	KW			
Cooling plant losses at C.M.R.	KW			
Load losses at 75 Deg. C and normal ratio:				
A) C.M.R.	KW			
B) ONAN rating	KW			
Total losses at 75 Deg. C and normal ratio:				

- A) C.M.R. including input to cooling plant      KW
- B) ONAN rating      KW

Regulation at 75 Deg. C/ and normal ratio:

- A) At unity power factor      %
- B) At 0.9 lagging power factor      %

Maximum current density in winding at C.M.R.

- A) HV W/Snding      A/mm<sup>2</sup>
- B) LV Winding      A/mm<sup>2</sup>

#### POWER TRANSFORMERS

Description	Item	125MVA	132/33KV
	Tap	- 15	0      5%

Assumed simultaneous operating conditions under which maximum flux density is attained.

Frequency	Hz	48	
Voltage HV	KV	145	145
LV	KV	36	36
Load MVA at 0.8 pf lagging		162.5	0      162.5

Maximum flux density in iron under these conditions      Tesla

Impedance voltage at 75 Deg. C and CMR between:

H.V. and L.V. windings at highest transformation ratio      %

Temperature rise of windings at CMR above specified design ambient

The tenderer shall enter the terminal voltages appropriate to the stated loading in accordance with IEC 354 : 1972 and the impedance offered.

125MVA Tx.  
132/33KV

#### Details of Construction

Types of winding:

- A) H.V.
- B) L.V.

Insulation of:

- A) H.V. Winding
- B) L.V. Winding

**Insulation of tapping connections Insulation of:**

- A) Core bolts
- B) Side plates
- C) Core laminations

Winding connections brazed or crimped

Is facility provided for adjustment of axial pressure on windings

Yes/No

Thickness of transformer tank

- A) Sides mm
- B) Bottom mm

Material used for gaskets for oil tight joints

**Radiators and Fans**

Thickness of radiator plates and/or cooling tubes mm

Equipment for ON cooling state (A) or (B)

- A) Radiators on main tank
- B) Separate cooler banks

Auxiliary equipment for ONAF cooling – state (A) or (B)

- A) Forced air cooling of radiators on tank
- B) Separate forced air cooler bank

Number of coolers/radiators or cooler banks per transformer

Thermal rating of each cooler/radiator bank

Number of air blowers per Tx.

Speed of air blowers

B.S. rating of each air blower motor

Starting current of each blower motor

KW  
RPM  
KW  
A

**Oil Volumes and Weights**

Total oil required including cooler system

Volume of oil above level of the top yoke

Total volume of conservator

Volume of oil in tap changer

Volume of oil in coolers

Volume of oil in conservator between highest and lowest visible

Weight of core and winding assembly

Weight of tap changer gear

Weight of OLTC and compartment

Weight of cooling equipment complete

Weight of conservator tank

Total weight of largest section arranged for transport

Total weight of transformer for operation but excluding weight of coolers if these are not supported on transformer tank

(including oil) KG

Overall dimensions of transformers complete with top

changer gear:

Width	mm
Length	mm
Height	mm

## 5.0 PROTECTION, METERING AND CONTROL

Description	Panel
A) 132KV Distance Protection	
Manufacturer	
Type of relay and measuring system	
Minimum setting for near end fault:	
Single phase to earth	
Phase to phase	
Three phase	
Minimum setting for faults at remote end:	
Single phase to earth	
Two phase to earth	
Phase to phase	
Three phase	
Minimum length of transmission line which can be protected	KM
Maximum length of transmission line which can be protected	KM
Maximum time delay between initiation of fault in first zone and energising of trip circuit:	
a) At a current equal to CT rating	
b) At a current equal to five times CT rating	
C) At a current equal to 20 times CT rating	
Range of adjustment for time delay relays	
a) Second zone	
b) Third zone	
Burden imposed by protective equipment: Resistive –	
a) Current circuits (at 20 times CT RATING)	VA
b) Voltage circuits (at normal rated voltage)	VA
Reactive –	
a) Current circuits (at 20 times CT rating)	VA
b) Voltage circuits (at normal rated voltage)	VA

**B) 132KV Busbar Protection**

Manufacturer

Type of equipment (solid state/electro-mechanical)

Minimum sensitivity:

- A) Earth faults % of C.T. rating
- B) Phase faults % of C.T. rating

Maximum through fault stability

Operating time fault initiation to trip initiation at:

- A) Current 3 times minimum setting milli secs.
- B) Current 10 times minimum setting milli secs.

**C) Transformer biased differential protection**

Manufacturer

Type of description of system

Range of operating coil settings

Range of bias coil settings

Recommended operating coil setting

Recommended biased coil setting

% of C.T. rating  
% of C.T. rating

**Description**

Sensitivity for earth faults at recommended settings:

- A) Least sensitive phase % of C.T. rating
- B) Most sensitive phase % of C.T. rating

Sensitivity for phase faults at recommended settings:

- A) Least sensitive phase % of C.T. rating
- B) Phase faults % of C.T. rating

Maximum through fault at which the protective equipment is stable with recommended settings:

- A) Earth faults % of C.T. rating
- B) Phase faults % of C.T. rating

Maximum time delay between initiation of fault and energising of breaker trip current milli secs

Details of magnetizing inrush current bias unit for stability of protection under switching surges

**D) Transformer restricted earth fault protection**

Manufacturer	
Type of relay	
Sensitivity	% of C.T. rating
Magnitude of external phase or earth fault up to which the protection is stable	% of C.T. rating
Burden for current transformer	VA
Time delay between initiation of fault and energising of breaker trip coil at twice	

Time delay between initiation of fault and energising of breaker trip coil at 10 times CT rating	milli secs
--	------------

**E) Inverse Time Overcurrent and Earth Fault Protection**

Manufacturer  
Type of relay  
Range of current settings:

A) Overcurrent elements	% of C.T. rating
B) Earth fault elements	% of C.T. rating
C) High set instantaneous elements	% of C.T. rating

Range of timing setting sat 10 times C.T. rating	Secs
Burden of relay at 10 times C.T. rating	VA

**F) Standby Earth Fault Protection**

Manufacturer  
Type of relay  
Type of time delay relay  
Range of fault settings  
Range of setting of definite time delay relay:

	% of C.T. rating
--	------------------

A) First stage	Secs
B) Second stage	Secs

Burden of relay at 10 times C.T. rating	
Percentage of current setting at which relay will reset	%

**G) Distance Protection Relays**

Manufacturer  
Type of relay and measuring system  
Type of starting system  
Minimum setting for near end fault:

Single phase to earth  
Phase to phase  
Three phase

Minimum setting for faults at remote end:

Single phase to earth

Two phase to earth

Phase to phase

Three phase

Minimum length of transmission line which can be protected

Maximum length of transmission line which can be protected

KM  
KM

Maximum time delay between initiation of fault in first zone and emerging of trip circuit:

a) At a current equal to CT rating

b) At a current equal to five times CT rating

c) At a current equal to 20 times CT rating

Range of adjustment for time delay relays

a) Second zone

b) Third zone

Burden imposed by protective equipment: Resistive –

a) Current circuits (at 20 times CT rating)

b) Voltage circuits (at normal rated voltage)

VA  
VA

Reactive –

a) Current circuits (at 20 times CT ratings)

b) Voltage circuits (at normal rated voltage)

VA  
VA

## H) 33KV Busbar Protection

Manufacturer

Type of equipment (solid state/electro mechanical)

Minimum sensitivity:

A) Earth faults

B) Phase faults

% of C.T. rating  
% of C.T. rating

Maximum through fault stability

Operating time fault initiation to trip initiation at:

A) Current 3 times minimum setting

B) Current 10 times minimum setting

milli secs.  
milli secs.



**1) Neutral Earth Fault Protection**

Manufacturer	
Type of relay	
Type of time delay relay	
Range of fault settings	
Range of setting of definite time delay relay	% of C.T. rating
Burden of relay at 10 times C.T. rating	Secs
Percentage of current setting at which relay will reset	V/A

**Signature** : .....

**Designation** : .....

**Name of Tenderer** : .....

**Date** : .....

**AUXILIARY AND EARTHING TRANSFORMERS**

Description	Item	Earthing TX. 33/0.415 KV
Current density in interconnected star winding with specified fault current	A/mm <sup>2</sup>	
Current density in interconnected star winding at 3 second rating	A/mm <sup>2</sup>	
Continuous earth fault current rating	A	
CMR of lower voltage star winding	KVA	
Impedance voltage at CMR of lowr voltage winding between HV and LV winding	%	
Resistance of higher voltage winding at 75 Deg. C	Ohms per phase	
Zero phase sequence impedance at 75 Deg. C with LV windings open circuited	Ohms per phase	
Total oil required	litres	
Weight of complete transformer (including oil)	Tonnes	

Overall dimensions of transformers:

Width	mm
Length	mm
Height	mm

## METERING

Description		Kilowatt Hour with MDI	Kilowatt Hour
Integrating Meters			
Type		gmcm	
Torque at full load		gm	
Wt. of main shaft assembly		% per %	
Temp. coef.			
Excess current coils will carry safely:			
a) Continuously			% FL
b) For 30 min.			% FL
Number of revolutions of rotor at full load		RPM	
Minimum number of revs. of rotor per impulse Wt.		KG	
Finish of case			
Demand printers KWH and KVARH			
Type			
Integrating Period		mins	
No. figs. recorded by printer			
Frequency of chart replacement			
Max. error in transmission between meters and printers			
Max. rate of impulsing			
Standard value of impulse		per 1/2 hour Kwh Kvar/ imp.	
Consumption of operating coils		W	
Consumption of operating motor(s)		W	
Operating supply		V AC/DC	
Time Switch			
Type (Electronic/Mechanical)			
Operating voltages			
Setting ranges			
No. of ON/OFF cycles			
Accuracy			
Rating of operating contacts			
6.0 LIGHTING AND SMALL POWER			
Item	415 Volt Switchboards	Main Distri- bution Board	Essential Services
Manufacturer			
Type			
Busbar rating		Amps	
Breaking capacity		MVA	

Type and manufacture of fuses  
 Type and manufacture of changeover contactor  
 Rating of contactor hold-in coil  
 Pick-up voltage of contractor coil  
 Drop-off voltage of contractor coil  
 Range of adjustment in drop-off time Secs

V/A  
 V  
 V

## 7.0 BATTERIES, CHARGERS AND D.C. SWITCHBOARDS

Description	
<b>Batteries</b>	
Manufacturer	
Type	
Electrolyte	
Voltage	V
Capacity at 10 hour rate	A.H.
Number of cells	
Voltage per cell	V
Normal charging rate	A
Ampere hour efficiency at 10 hour rate	%
Dimensions of cells	mm
Dimensions of battery complete	mm
Weight of cell complete with electrolyte	KG
Total weight of battery complete	KG
Internal resistance per cell when full charged	Ohms
Battery voltage at end of the duty cycle specified	V

<b>Charger</b>	
Manufacturer	
Type	
A.C. Input to charger	KVA
D.C. Output to charger	KW
Type of D.C. voltage control	V
Range of D.C. voltage control	%
Regulation	
Overall dimensions	mm
Total weight	KG

Boost charge contactors:

a) Manufacturer

b) Maximum current rating

c) Coil rating

d) Method of inter-locking

A  
 W

**Item**

Alarm relays:

- a) Manufacturer
- b) Type and reference
- c) Power consumption:
  - i) Quiescent
  - ii) Operated

W  
W

Number and rating distribution circuits

Overall dimensions

mm

Total weight

KG

**D.C. Switchboards**

Manufacturer

Type of construction

Busbars:

- a) Maximum current rating
- b) Dimensions

A  
mm

**3.0**

**NEUTRAL EARTHING EQUIPMENT**

**Item**

**Neutral Isolators**

Manufacturer

Type

Number of breaks per pole

Type of contacts

Material of contact surface

Normal rated current

A

Maximum short time current (3 seconds)

RMS KA

Air gap between poles of one phase

mm

Type of operating mechanism

Total weight of single phase isolator complete

KG

Design voltage

KV

Minimum dry flashover

KV

Minimum wet flashover

KV

1 minute dry test

KV

Overall dimensions

mm

**Resistors**

Type (liquid or metal grid)

Current rating (10 Secs)

Amps

Resistance at 30 Deg. C

Ohms

Electrolyte quantity (where applicable)

Litres

Dimensions:	
Height overall	m
Diameter	m
Plate thickness	mm

Bushings and electrode supports:	
Nominal voltage	KV
Minimum dry flashover externally	KV
Minimum wet flashover internally (in air above electrolyte)	KV
1 Min. dry test	KV

Neutral Current Transformers	
Design voltage	KV
Minimum dry flashover	KV
Minimum wet flashover	KV
1 Min. dry test	KV
Overall dimensions	mm

## 9.0 FIRE FIGHTING EQUIPMENT

Item	
10 Kg Dry Powder Wall Mounting Extinguisher	
Manufacturer	m
Dimensions	Kg
Weight	
Type of dry powder	Kg/cm2
Test pressure	Kg/cm2
Working pressure	

45 KG Dry Power Mobile Extinguisher	
Manufacturer	
Dimensions	
Weight	Kg
Length of hose	m
Type of dry powder	
Test pressure	Kg/cm2
Working pressure	Kg/cm2

### 100 Litres Foam Mobile Extinguishers

Manufacturer	m
Dimensions	Kg
Weight	m
Length of hose	
Type of dry powder	Kg/cm2
Test pressure	Kg/cm2
Water Sprinklers	

### 10.0 132KV and 33KV – XLPE CABLES

S.No.	Description	
1	Make	
2	Standard to which cable conforms	
3	Voltage between phases of 3 phase circuit	KV
4	Number of cores	
5	CONDUCTOR (Cross Sectional Area Material Design Overall dimensions	mm2 mm
6	CONDUCTOR SCREEN (Material thickness)	mm
7	INSULATION (Material Min. radial thickness)	mm
8	CORE SCREEN (Material Nominal thickness)	mm
9	METALLIC LAYER OF SHEATH (Material No. of strips – Size of strips – Nominal thickness	mm
	Outer diameter	mm
10	OUTER COVERING (Material Min. thickness Anti termite deterrent)	mm
11	COMPLETED (Overall diameter Weight per metre Max. drum length	mm Kg m
12	MAXIMUM DIELECTREIC STRESS at the conductor screen (assumed smooth)	MV/m

13	MAXIMUM CONDUCTOR TEMPERATURE Laid direct in ground Drawn into ducts Erected in air	°C °C °C
14	MINIMUM RADIUS OF BEND round which cable can be laid (Laid direct (In ducts (In air	m m m
15	Nominal internal diameter of pipes or ducts through which cable may be pulled mm	
16	MAXIMUM D.C. RESISTANCE of conductor per metre of cable at 20 Deg. C	Ohm
17	MAXIMUM A.C. RESISTANCE of conductor per metre of cable at max. conductor temperature	Ohm
18	EQUIVALENT STAR REACTANCE permetre of 3 phase circuit at 50Hz	Ohm
19	MAXIMUM ELECTROSTATIC CAPACITANCE per metre of cable	pF
20	MAXIMUM CHARGING CURRENT per conductor per metre of cable at nominal voltage	mA
21	CURRENT CARRYING CAPACITY (See Ref. 25) Laid in the ground :  Drawn into single : Way ducts : In air :	One circuit A Two circuit A One circuit A Two circuit A One circuit A
22	CONDUCTOR SHORT CIRCUIT CURRENT carrying capacity for one second, cable loaded as above second, cable loaded as above before short circuit and final conductor temperature 250 Deg. C	KA
23	METALLIC LAYER OR SHEATH LOSS of cable per metre of 3 phase circuit at normal voltage, normal frequency and operating oil pressure at circuit rating as stated in Ref : 20.	W
24	METALLIC LAYER OR SHEATH EARTH FAULT CURRENT carrying capacity for one second, cable fully loaded prior to earth fault and final screen temperature of	°C
25	CABLE DRUMS (Diameter (Width (Weight loaded	m m Kg

26	Conditions upon which current carrying capacities are based	mm	
	Axial spacing between phase cables	mm	
	Axial spacing between circuits	mm	
	Soil thermal resistivity	Deg. C-m	
	Ground temperature	°C	
	Air temperature	°C	
	Burial depth	m	
	Type of earth bonding		

## 11.0 AUXILIARY LV POWER CABLES

Ref.	Description	Unit	Types
1	Voltage	Volts	
2	Class of cable		
3	No. of cores		
4	Conductor c.s.a. Type and Materials	mm <sup>2</sup>	
5	Insulation Material Thickness	mm	
6	Armour Thickness		mm
7	Armour – No. of wires Dia. of wires		
8	Other covering material thickness	mm	
9	Completed cable overall dia. Weight per metre	Kg	
10	Maximum D.C. resistance of conductor at 20 Deg. C.	Ohms	

## 12.0 AUXILIARY CONTROL CABLES

Ref.	Description	Unit	Types
1	Voltage	Volts	
2	Class of cable		
3	Number of cores		
4	Conductor (Cross section area (Type and material	mm <sup>2</sup>	



5	Insulation (Material Thickness	mm
6	Armour Bedding (Thickness	mm
7	Armour (No. of wires (Diameter of wires	mm
8	Outer covering (Material Thickness	mm
9	Completed Cable (Overall diameter (Weight per metre (Maximum drum length	Kg m
10	Maximum D.C. resistance of conductor per km of cable at 20 Deg. C	Ohm

### 13.0 POWER LINE CARRIER

#### Description

#### HIGH FREQUENCY LINE COUPLING EQUIPMENT

##### Line Traps

Manufacturer	
Type of numbers	Amps
Nominal current rating	Kg
Coil inductance	°C
Weight of line trap	
Temperature rise at normal rating	
Thermal short circuit rating	
2 seconds	KA
3 seconds	KA
Dynamic short circuit rating	KA
Temperature rise at short circuit rating	°C
Working tension of strain mounted units	Kgm
Bandwidth blocked	KHz
Attenuation in blocking band	db
Minimum impedance in working bandwidth	Ohms
Non compatibility with IEC	
Recommendations 353	Yes/No
If yes, enter in Schedule M	
Departures from specification	

##### HF COUPLING UNITS

Manufacturer  
Type of number

Available bandwidth	KHz
Tuning range	KHz
Composite loss over tuning range	db
Line side impedance range	
Phase/Earth coupling	Ohms
Phase/Phase coupling	Ohms
Equipment side impedance	Ohms
Drain coil current carrying capacity	
Continuous	Amps
For 1 second	Amps
Isolation transformer voltage	
For 1 minute	KV
Main arrester voltage	KV
Secondary arrester voltage	volts
Earth switch interlock with door	Yes/No
Non compatibility with IEC Recommendation 481	Yes/No
If yes, enter in Schedule A Departures from Specification	

### COUPLING CAPACITORS

Manufacturer	
Type of number	
Mounting	
Weight	
Rated capacitance	pF
Coupling capacitor insulation	
Test	
AC test	KV
Impulse withstand voltage	KV
Suitability for line trap	
Mounting	
Creepage distance	Yes/No

### HIGH FREQUENCY CABLE

Manufacturer	
Type of number	
Coaxial or Quad	
Surge impedance	Ohms
Voltage withstand	
Between conductors	KV
Between cores and armouring	KV
Attenuation per kilometre	
At 50 KHz	db
At 500 KHz	db

### CARRIER HIGH FREQUENCY UNITS

Manufacturer  
Type number

Working temperature range	°C to °C
Working voltage	V
Normal D.C.	+ or -
Normal A.C.	V
	+ or -
Supply frequency	Hz
Power consumption of fully equipped terminal	Watts
Side bands (4 kHz)	
Type	
Transmit/Receive spacing	kHz
Transmit/Transmit spacing	kHz
Speech bandwidth	Hz
VFT channel working availability	Hz
Automatic gain control	Hz
Telephone signalling	Hz
Channel synchronising	Hz
Virtual carrier frequency stability	Yes/No
Carrier frequency variations with temperature (state range) Hz	°C to °C
I.F. modulation frequency	kHz
Terminal power at output to coupling equipment	Watts
Carrier terminal output impedance	Ohms
Transmit return loss	db
Maximum transmitting level for parasitic signals	
At 300 Hz outside the limits of the H.F. channel	
At more than 12 Hz outside the limits of the H.F. channel	
Receiving level range at H.F. input	dbm
Maximum	dbm
Minimum	dbm
Output power (PEP) before hybrid	Watts
At coaxial cable	db
Variation of speech level with respect to recieved H.F. level	
Speech channel characteristics without companders	
Nominal overall frequency response,	
4 Wire to 3 wire relative to 800 Hz	
300 Hz	dBm0
1000 Hz	dBm0
1600 Hz	dBm0
2000 Hz	dBm0
2400 Hz	dBm0
Overall 800 Hz transmission loss	
4 wire to 4 wire	db
2 wire to 2 wire	db
4 wire/2 wire switching availability	Yes/No
Nominal levels	
4 wire transmit	dBr
4 wire receive	dBr
2 wire transmit	dBr
2 wire receive	dBr

VFT channel characteristics	
Nominal levels	
4 wire transmit	dBr
4 wire receive	dBr
Frequency difference between VFT input and VFT output between a pair of terminals	Hz
Weighted telephone noise measured at the speech output of a pair of terminals without companders	dBm0P
Pulse distortion of the signalling channel at a speed of 10 pulses per second	
Non compatibility with IEC recommendation 495	Yes/No
If yes, enter in Schedule M Departure from specification	

#### TELE PROTECTION EQUIPMENT – ‘DIRECT’ TRIPPING

Manufacturer	
Type	V + or -
Power consumption	Watts
a) Quiescent	
b) Tripping	
VFT channel allocations	Hz
VFT channel oscillator accuracy	+ or - Hz
VFT channel bandwidth required	Hz
Detail coding of signals	
Channel signalling speed from receipt of initiation to output control closure	m Sec
Duration of output pulse	m Sec
Dependent of duration of input pulse	Yes/No
Alarm facilities	
Transmitter fail	Yes/No
Receiver level low	Yes/No
Receiver fail	Yes/No

#### TELE SIGNALLING EQUIPMENT FOR TELE CONTROL SYSTEM

Bandwith per channel	Hz
Speed of channel	+ or - Hz
Centre frequencies	db
Vf channel frequency accuracy	V
Minimum signal/Noise ratio	Ohms
Modern power supply	Ohms
Input impedance	Ohms
Output impedance	°C to °C
Temperature range	
CCITT recommendation compatibility	

#### TELEPHONE EQUIPMENT

Manufacturer and Type Nos.	
Working voltage	V + or -
Normal	
Types and lengths of signalling impulses for	
Selecting	
Seizing of a carrier channel	

Releasing of a carrier channel

Selective releasing of break in communications

Private exchanges

Number of HF Lines

Number of extensions

Number of simultaneous conversations

a) Trunk lines to extensions

b) Extension to trunk lines

c) Extension to extension

d) Transit calls

Current consumption when all common equipment is in use

Amps

## **BATTERIES, CHARGERS AND D.C. SWITCHBOARDS ETC.**

Batteries

Manufacturer

Type

Voltage

Electrolyte

Capacities at 10 hour rate

Number of cells

Voltage per cell

Normal float charge rate

Maximum boost charge rate

Ampere hour efficiency at 10 hour rate

Ampere hour efficiency at 1 hour rate

Size of cell

Weights of cell complete with electrolyte

Internal resistance of batteries when charged

Volts  
A.H.  
Volts  
Amps  
Amps  
%  
%  
hxwx dx  
Kg  
Ohms

Chargers

Manufacturer

Type rectifiers

Nominal input voltage

D.C. output of rectifiers

Type of D.C. voltage control

Range of float D.C. voltage control

Hand control

Automatic control

Range of boost D.C. voltage control

Hand control

Automatic control

Rectifier transformer input rating

D.C. switchboard

Type of switches

Type of fuses

Distribution circuits (numbers and ratings)

Amps


Volts  
Volts  
KVA

## DETAILED SCHEDULE OF EQUIPMENT

Item No.	Item
1	<p>Telephone exchange (PAX) capacity</p> <p>a) Number of extensions</p> <p>b) Number of trunk lines</p> <p>c) Number of connecting links</p>
2	<p>Power line carrier equipment</p> <p>a) Maximum output power, per carrier terminal to line</p> <p>b) Sideband configuration erect/inverted</p> <p>c) VF frequencies proposed for tele protection</p>
3	<p>Power supplies</p> <p>a) Battery type</p> <p>b) Total battery capacity at 10 hour rate</p> <p>c) Maximum simultaneous demand on battery</p> <p>d) Charger type</p> <p>e) Charger rating</p> <p>f) D.C. distribution board</p> <p>i) Mounting in charger</p> <p>ii) External to charger</p> <p>iii) Number and rating of fused outlets (Positive leg of outlet to include link)</p> <p>g) Number of cells</p>
4	<p>Dimensions of Apparatus cubicles length x depth x height metres</p> <p>a) Telephone exchange</p> <p>b) Power line carrier equipment</p> <p>c) Battery charger</p> <p>d) Teleprotection channels</p> <p>e) Isolation transformers</p>


**132KV 3 POLE DISCONNECTOR AND EARTHING SWITCH**


<b>S. No.      Description</b>		<b>Particulars</b>
1	Manufacturer	
2	Disconnector type	
3	Type of number	
4	Isolator/Earthing switch type No.	
5	Isolator/Earthing switch drive	
6	Rated voltage	KV
7	Rated frequency	Hz
8	Rated current	A
9	Short time switch stand current (isec) (isolator KA rms)	
10	Ditto – but for earth switch	KA rms
11	Peak withstand current (isolator)	KA peak
12	Peak withstand current (earth switch only)	KA peak
13	Making current (peak, earth switch only)	KA peak
14	Lightning impulse voltage (1.2/50 us) withstand of disconnector – line to earth – across open isolator	KV peak KV peak
15	One min. power frequency withstand – line to earth (50 Hz) – across open insulator (50 Hz)	KV rms
16	Insulator creepage distance	mm
17	No. of snapre auxiliary contacts	





SULTANATE OF OMAN MINISTRY OF ELECTRICITY & WATER		
2x125MVA132/33KV SUBSTATION (TYPICAL)		
132/33KV SINGLE LINE DIAGRAM		
DRAWN	CHECKED	APPROVED
FRANCIS	<i>[Signature]</i>	
DRAWING NO:	DATE	
MEW/132/33KV/002	13.12.89	








MINISTRY OF ELECTRICITY & WATER			
DIRECTORATE GENERAL OF ELECTRICITY			
PLANNING DEPARTMENT			
132/33KV SUBSTATION (TYPICAL).			
SINGLE LINE DIAGRAM FOR PROTECTION			
ON 125MVA TRANSFORMERS & 33KV FEEDERS			
DRAWN BY	CHECKED	APPROVED	
FRANCIS	<i>Francis</i>		
SCALE 'N.T.S.	DATE.	01. 12.	90
DRG. NO. MEW/132/33KV/004			



SULTANATE OF OMAN  
 MINISTRY OF ELECTRICITY & WATER  
 132/33 KV SUBSTATION (TYPICAL)  
 SINGLE LINE DIAGRAM OF 125 MVA  
 TRANSFORMER METERING

DRAWN	CHECKED	APPROVED
FRANCIS	<i>Francis</i>	<i>Francis</i>
DRAWING NO:	DATE	
MEW / 132/33 KV / 005	01 12 - 90	



MINISTRY OF ELECTRICITY & WATER  
DIRECTORATE GENERAL OF ELECTRICITY  
PLANNING DEPARTMENT


132/33KV SUBSTATION (TYPICAL)  
SINGLE LINE DIAGRAM OF  
A.C. AUXILIARIES SUPPLIES



DRAWN BY	CHECKED	APPROVED
----------	---------	----------

FRANCIS

SCALE N.T.S. DATE - 02-12-90





DWG No. MEW/132/33KV/ 006





SECTION A-A

SULTANATE OF OMAN		
MINISTRY OF ELECTRICITY AND WATER		
2x125MVA 132/33KV TRANSFORMER FEEDER		
OUT DOOR YARD ARRANGEMENT		
DRAWN	CHECKED	APPROVED
FRANCIS.		
DRAWING NO MEW/132/33KV/008		
SCALE: N T S	DATE	07.11.1989.



132 KV SUBSTATION

(TYPICAL)

FRANCIS

CHECKED

APPROVED

DRAWING NO. NEW/132/33KV/001

DATE

24-04-1989

SULTANATE OF OMAN  
MINISTRY OF ELECTRICITY AND WATER